

## APPENDIX F: Certification Form

### Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(To certify electronic delivery of the CCR, use the certification form on the State Board's website at [http://www.swrcb.ca.gov/drinking\\_water/certific/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certific/drinkingwater/CCR.shtml))

Water System Name: The Oaks Mobile Home Park

Water System Number: 0310020

The water system named above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: Teresa Bailey

Signature: Teresa Bailey

Title: Community Manager

Phone Number: ( 209 ) 274-6056

Date: July 1, 2019

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: mailed via USPS.

☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

☒ Posting the CCR on the Internet at www.TheOaksCommunityAssoc

☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)

☐ Advertising the availability of the CCR in news media (attach copy of press release)

☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)

☒ Posted the CCR in public places (attach a list of locations) Inside clubhouse & outside Bulletin Board

☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools

☐ Delivery to community organizations (attach a list of organizations)

☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

*This form is provided as a convenience for use to meet the certification requirement of the California Code of Regulations, section 64483(c).*



## 2018 Consumer Confidence Report

### The Oaks Community Association

We are pleased to present to you this year's annual Consumer Confidence Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. **Our water source is Lake Amador, which undergoes a filtration treatment/disinfection process.**<sup>1</sup>

The Board of Directors meetings are held in the clubhouse at 6:00PM, the 3<sup>rd</sup> Tuesday of each month. If you have any questions about this report or concerning your water utility, contact the office at (209) 274-6056.

**Espanol – (Spanish): Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.**

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**In order to ensure** that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the State Water Resources Control Board Division of Drinking Water prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**All drinking water, including** bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at 1-800-426-4791.

**Contaminants that may be present** in source water include:

- *Microbiological contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be a result of oil and gas production and mining activities.

**A source water assessment** was conducted in December 2015 by the Department. The raw water source is considered most vulnerable to the following activities associated with contaminants detected in the water supply: metal plating/finishing/fabricating and wastewater treatment plants. In addition, the source is considered most vulnerable to these activities: gas stations, historic gas stations, dry cleaners, airports-maintenance/fueling areas, mining operations-historic, and historic waste dumps/landfills. To review or obtain a copy of the assessment, call the Oaks at (209) 274-0656 or the Department at (209) 948-7696.

**Some people may be more vulnerable** to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

<sup>1</sup> In 2019 The Oaks began purchasing treated water from JVID. The water source for JVID is Pardee Reservoir.



## W A T E R   Q U A L I T Y   D A T A

The Oaks Community Association routinely monitors for constituents in your drinking water according to Federal and State laws. Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. Unless otherwise indicated, the data contained in this report are for the monitoring period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2018. The table does not include contaminants that were not detected by laboratory testing. The Department allows most systems to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the results in this report, though representative, may be more than a year old.

### TERMS USED IN THIS REPORT:

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Primary Drinking Water Standards (PDWS):** MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Maximum Residual Disinfectant Level (MRDL):** The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U.S. Environmental Protection Agency.

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (ug/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**Table 1 – Sampling Results Showing The Detection Of Coliform Bacteria\***

Microbiological Contaminants	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical source of Bacteria
Total Coliform Bacteria	(In a month) None	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal coliform or <i>E. coli</i>	(In the year) None	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform of <i>E.coli</i>	0	Human and animal fecal waste

**Total Coliform:** Water systems are required to meet a strict standard for coliform bacteria. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If the standard is exceeded, the water supplier must notify the public. The Oaks Community Association is pleased to inform you, no coliform bacteria were detected in any of the monthly distribution samples on 2018.



**Table 2 – Sampling Results Showing The Detection Of Lead And Copper**  
**Sample Dates 9/14/16 & 9/15/16**

Lead and Copper (reporting units)	No. of samples collected	90 <sup>th</sup> percentile level detected	No. Sites exceeding AL	AL	MCLG	Typical Source of Contamination
Lead (ppb)	12	ND	none	15	2	Internal corrosion of household plumbing systems, erosion of natural deposits.
Copper (ppm)	12	0.089	none	1.3	0.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

**Lead** - If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Oaks Community Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**Copper** - is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time may experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years may suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

**Table 3 –Sodium and Hardness Lake Amador Raw Water**

Chemical or Constituent (reporting units)	Sample Date(s)	Level Detected	Range of Detections	PHG (MCLG)	MCL	Typical Source of Contamination
Sodium (ppm)	2/05/18	7.4	NA	none	none	Generally found in ground and surface water
Hardness (ppm)	2/05/18	79	NA	none	none	Generally found in ground and surface water

**Table 4 - Detection Of Contaminants With A Primary Drinking Water Standard**

Chemical or Constituent (reporting units)	Violation Y/N	Level Detected	Range of Detection	PHG	MCL	Typical Source of Contaminant
<b>Inorganic Contaminants Lake Amador Raw Water Sampled in 2/05/2018</b>						
Fluoride (ppm)	N	ND	NA	1.0	2.0	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate as Nitrogen (ppm)	N	ND	NA	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>+Disinfection Byproducts, Disinfectant Residuals, and Disinfection Byproduct Precursors, Treated Water 2018</b>						
Total Trihalomethanes (ppb) Average	N	32.1	21 - 40	NA	80	By-product of drinking water chlorination
Haloacetic Acids (ppb) Average	N	34.2	30 - 52	NA	60	By-product of drinking water disinfection
Chlorine (ppm) (Monthly samples)	N	1.6	0.45 – 3.2	MRDLG = 4.0	MRDL = 4.0	Drinking water disinfectant added for treatment
DBP precursors TOC Average	N	2.0	1.4 – 2.6	NA	TT	Various natural and manmade sources

+ Quarterly reporting is once every three months



**Table 5 - Detection Of Contaminants With A Secondary Drinking Water Standard <sup>(a)</sup>  
Sampled Monthly in 2018 otherwise indicated**

Chemical or Constituent (reporting units)	Violation Y/N	Level Detected	Range of Detection	PHG	MCL	Typical Source of Contaminant
Aluminum (ppm) Average	N	ND	ND	0.6	1	Erosion of natural deposits; residue from some surface water treatment processes
Chloride (ppm)	N	7.9	NA	NA	500	Runoff/leaching from natural deposits; sea water influence
Color*	N	5	NA	NA	15	Naturally-occurring organic materials
Conductivity $\mu$ S/cm (Sampled 2/5/2018 & 5/7/2018) Lake Amador	N	200	190-200	NA	1600	Substances that form ions when in water; sea water influence
Iron (ppb) Average treated water	N	<20	<20	NA	300	Leaching from natural deposits; industrial wastes
Manganese (ppb) Average treated water	N	<20	<20	NA	50	Leaching from natural deposits
Odor – Threshold (units) (Sampled 2/5/2018) Lake Amador	N	None Detected	NA	NA	3	Naturally-occurring organic compounds
Sulfate (ppm) (Sampled 2/5/2018) Lake Amador	N	25	NA	NA	500	Runoff/leaching from natural deposits; industrial wastes
Turbidity (units) (Sampled 2/5/2018) Lake Amador	N	1.3	NA	NA	5	Soil runoff
Total Dissolved Solids (ppm) (Sampled 2/5/2018) Lake Amador	N	110	NA	NA	1000	Runoff/leaching from natural deposits

(a) There are no PHGs, MCLGs, or mandatory standard health effects language for constituents with secondary drinking water standards because secondary MCLs are set on the basis of aesthetics.

\*Note: The Treated Water was all None Detected at <3 Color except on the month of June 2018 at 5 with the Raw Water resulted as 14 Color.

**The Oaks Community Association is pleased to inform you, there were no violations to report in  
Tables 1, 2, 3, 4, or 5.**

On 2/01/2016, Annual Water Quality sampling was done which also included the Perchlorate to meet regulatory sampling requirements. The results were less than the reporting limits with none detection.

**For Systems Providing Surface Water as a Source Of Drinking Water:**

<b>Table 7 - Sampling Results Showing Treatment Of Surface Water Sources</b>	
<i>Treatment Technique</i> <sup>(a)</sup> (Type of approved filtration technology used)	Conventional Filtration System
Turbidity Performance Standards <sup>(b)</sup> (that must be met through the water treatment process)	<u>Turbidity of the filtered water must:</u> 1 – Be less than or equal to 0.3 NTU in 95% of measurements in a month. 2 – Not exceed 1.0 NTU for more than eight consecutive hours. 3 – Not exceed 1.0 NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	100%
Highest single turbidity measurement during the year	0.331 NTU (July 23, 2018)
Number of violations of any surface water treatment requirements	None

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

On 3/5/2018, 6/4/2018, 9/4/2018, & 12/7/2018, Synthetic Organic Contaminates was sampled to meet regulatory sampling requirements. The results were less than the reporting limits with none detection.

Chemical	Detected Level	Health Effects Language
1,2,3-Trichloropropane (ng/L or PPT)	ND	Some people who drink water containing 1,2,3-trichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.

Report prepared 5/26/2019 by Alpha Analytical Laboratories, Inc., using *CCR Guidance for Water Suppliers* available at, [http://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml), employing due diligence with instructions given. Data contained in this report are based on the analytical results generated by Alpha Analytical Laboratories and its subcontract laboratories.