

# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at  
[http://www.swrcb.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name:	<b>HUMBOLDT WOODLANDS MUTUAL WATER COMPANY</b>
Water System Number:	<b>CA0400149</b>

The water system named above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Michelle Eaton	
	Signature:	<i>Michelle Eaton</i>	
	Title:	Water Board President	
	Phone Number:	( 530 ) 343-3371	Date: April 25, 2022

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

- ☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

Email 4/25/2022

- ☒ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☒ Posted the CCR on the internet at [http:// app.townsq.io/](http://app.townsq.io/)
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> \_\_\_\_\_

- ☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

# 2021 Consumer Confidence Report

Water System Name: HUMBOLDT WOODLANDS MUTUAL WATER COMPANY Report Date: April 2022

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2021.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 1 source(s):** Well

**Opportunities for public participation in decisions that affect drinking water quality:** Meetings are announced via email to all water members 4 or more days before meetings, and are currently held using ZOOM due to COVID. Outside of COVID at 14954 Woodland Park Dr. Forest Ranch, CA. 95942

For more information about this report, or any questions relating to your drinking water, please call 5303433371 and ask for Michelle Eaton or email [HOAWaterBoard@gmail.com](mailto:HOAWaterBoard@gmail.com).

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

## **Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables and 1 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

## **No contaminants were detected in the 2021 water analysis.**

### **Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead Specific Language for Community Water Systems:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Humboldt Woodlands M.W.C.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

# **2021 Consumer Confidence Report**

## **Drinking Water Assessment Information**

### **Assessment Information**

A source water assessment was conducted for the WELL of the HUMBOLDT WOODLANDS MUTUAL water system in February, 2001.

Well - is considered most vulnerable to the following activities not associated with any detected contaminants:  
Injection wells/dry wells/ sumps

### **Discussion of Vulnerability**

The source is considered vulnerable to the listed activities located near the source. The most significant potentially contaminating activities are those associated with the onsite sewage collection systems and sewage sump pumps.

### **Acquiring Information**

A copy of the complete assessment may be viewed at:  
Butte County Environmental Health  
202 Mira Loma Dr.  
Oroville, CA 95965

You may request a summary of the assessment be sent to you by contacting:  
Butte County Environmental Health  
Program Manager  
530-552-3880  
530-538-2165 (fax)

**Humboldt Woodlands M.W.C.**  
**Analytical Results By FGL - 2021**

**No contaminants were detected in the 2021 water analysis.**

# Humboldt Woodlands M.W.C.

## CCR Login Linkage - 2021

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
CuPb-SS01	CH 2076335-1	2020-08-03	Metals, Total	Holroyd Res	Copper & Lead Monitoring
CuPb-SS03	CH 2076335-3	2020-08-03	Metals, Total	Kopp Res	Copper & Lead Monitoring
CuPb-SS05	CH 2076335-5	2020-08-02	Metals, Total	Lampe Res	Copper & Lead Monitoring
LOT30HB	CH 2171266-1	2021-02-22	Coliform	Lot 30, Hose Bib	Bacteriological Even
	CH 2171565-1	2021-03-09	Coliform	Lot 30, Hose Bib	Drinking Water Monitoring
	CH 2172946-1	2021-04-28	Coliform	Lot 30, Hose Bib	Bacteriological Even
	CH 2174522-1	2021-06-22	Coliform	Lot 30, Hose Bib	Bacteriological Even
	CH 2176953-1	2021-08-23	Coliform	Lot 30, Hose Bib	Bacteriological Even
	CH 2178775-1	2021-10-21	Coliform	Lot 30, Hose Bib	Bacteriological Even
	CH 2190142-1	2021-12-20	Coliform	Lot 30, Hose Bib	Bacteriological Even
LOT6	CH 2170703-1	2021-01-25	Coliform	Lot 6 Sample Port	Bacteriological Odd
	CH 2171993-1	2021-03-24	Coliform	Lot 6 Sample Port	Bacteriological Odd
	CH 2173433-1	2021-05-18	Coliform	Lot 6 Sample Port	Bacteriological Odd
	CH 2176150-1	2021-07-29	Coliform	Lot 6 Sample Port	Bacteriological Odd
	CH 2177958-1	2021-09-27	Coliform	Lot 6 Sample Port	Bacteriological Odd
	CH 2179438-1	2021-11-17	Coliform	Lot 6 Sample Port	Bacteriological Odd
CuPb-SS04	CH 2076335-4	2020-08-01	Metals, Total	Miller Res	Copper & Lead Monitoring
CuPb-SS02	CH 2076335-2	2020-08-03	Metals, Total	Thomas res	Copper & Lead Monitoring