

For water testing
performed in 2025

FIND OUT MORE ABOUT
YOUR WATER DISTRICT:
www.PIDWater.com

Paradise Irrigation District *Annual Consumer Confidence Report*



*Este informe contiene información
muy importante sobre su agua potable.
Tradúzcalo, o hable con alguien que lo
entienda bien.*

Learn about our community's water quality

This annual "consumer confidence" water quality report covers all Paradise Irrigation District testing performed between Jan. 1 and Dec. 31, 2025, or earlier. The State Water Board allows certain chemicals to be monitored less than on a yearly basis because the concentrations of the substances are not expected to change significantly. In these cases, the most recent sample data are included, along with the year in which the sample was taken. Both "regulated" and "unregulated" contaminants are tested for; this report provides results only for contaminants detected in PID's system—tests with non-detected (ND) results are not listed.

For information, contact Rebekah Tyson at (530) 877-4971 or visit PID at 6332 Clark Road, Paradise; we are open from 9 am to 4 pm, Monday - Friday.

This Consumer Confidence Report (CCR) reflects changes in drinking water regulatory requirements during 2019. All water systems are required to comply with the state Total Coliform Rule. Beginning April 1, 2016, all water systems were also required to comply with the federal Revised Total Coliform Rule. The new federal rule maintains the purpose to protect public health by ensuring the integrity of the drinking water distribution system and monitoring for the presence of microbials (e.g., total coliform and E. coli bacteria). The U.S. EPA anticipates greater public health protection as the new rule requires water systems that are vulnerable to microbial contamination to identify and fix problems. Water systems that exceed a specified frequency of total coliform occurrences are required to conduct an assessment to determine if any sanitary defects exist. If found, these must be corrected by the water system.

Substances that could be in drinking water...

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of plants, animals or from human activity.

To make sure our tap water is safe to drink, the U.S. Environmental Protection Agency (US EPA) and the State Water Resources Control Board (State Board) prescribe regulations limiting the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that must provide the same level of protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small

amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health. Additional information on bottled water is available on the California Department of Public Health website (<https://www.cdph.ca.gov/Programs/CEH/DFDCS/Pages/FDBPrograms/FoodSafetyProgram/Water.aspx>).

Contaminants that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;

Inorganic Contaminants, such as salts and

metals, that can be naturally occurring or can result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, that may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and which can also come from gas stations, urban stormwater runoff, agricultural applications, and septic systems;

Radioactive Contaminants, that can be naturally occurring or can be the result of oil and gas production and mining activities.

More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

Lead and copper

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. PID is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing compo-

nents in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You

can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact PID t 530-877-4971. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>

DEFINITIONS USED:

RAL (Regulatory Action Level): Concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

µS/cm (microsiemens per centimeter): A unit expressing the amount of electrical conductivity of a solution.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. Primary (health-related) MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs (SMCLs) are set to protect the odor, taste and aesthetic appearance and use of the drinking water.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the USEPA.

MFL (million fibers per liter): A measure of the

presence of asbestos fibers that are longer than 10 micrometers.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable.

ND (Not detected): The substance was not found by laboratory analysis.

NS: No standard.

NTU (Nephelometric Turbidity Units): Measurement of the clarity/cloudiness—or turbidity—of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

PDWS (Primary Drinking Water Standard): MCLs and MRDLs for contaminants that affect health, along with their monitoring and reporting requirements and water treatment requirements.

PHG (Public Health Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California EPA.

ppm (parts per million): One part substance per million parts water (or milligrams per liter). Imagine one ping-pong ball in an Olympic-sized swimming pool.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter). Imagine one ping pong ball in 1,000 Olympic-sized swimming pools.

pCi/L (picocuries per liter): A measurement of radioactivity.

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.

Sampling results Paradise Irrigation District has taken thousands of regulated and unregulated water samples during the past years to determine the presence of any radioactive, biological, inorganic, volatile and synthetic organic contaminants and monitor the treatment process. The tables below show only those contaminants that were detected in the water; some that were not detected are listed because our customers may be interested in seeing the results. The State Water Resources Control Board (State Board) requires us to monitor for certain substances less than once per year because the concentrations of these substances do not change significantly. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

SECONDARY AESTHETIC STANDARDS

		Surface Water Supply			Groundwater Supply			MAJOR SOURCE IN DRINKING WATER
CHEMICAL (UNIT OF MEASURE)	MCL	YEAR SAMPLED	AVERAGE DETECTED	RANGE LOW-HIGH	YEAR SAMPLED	AVERAGE DETECTED	RANGE LOW-HIGH	
Chloride (ppm)	500	2020	2	2	2023	ND	ND	Natural occurring substance.
Hardness (ppm)	~	2020	31.4	31.4	2023	77	77	Natural occurring substance.
Sulfate (ppm)	500	2020	1.4	1.4	2023	ND	ND	Natural occurring substance.
Total Dissolved Solids (ppm)	1000	2020	70	70	2023	160	160	Natural occurring substance.
CORROSIVITY								
Specific Conductance (uS/cm)	1600	2020	89	89	2023	171	171	A measurement of water's conductance.
Langelier Saturation Index *	Non-Corro-sive	2020	-2.2	-2.2	2023	-1.2	-1.2	Indicator of corrosiveness of water.
Aggressive Index	Non-Corro-sive	2020	9.6	9.6	2023	10.7	10.7	Indicator of corrosiveness of water.
Zinc (ppm)(TT)	5	2024	0.28	.13-.36	2023	ND	ND	Water additive used to control corrosion.
Orthophosphate (ppm)(TT)	~	2024	.77	.53-.97	NA	NA	NA	Water additive used to control corrosion.
Iron (fe) (ppm)	300	2020	ND	ND	2023	880	880	Leach natural deposits; industrial waste.
Color (units)	15	2020	ND	ND	2023	12	12	Natural occurring organic materials.

* The Langelier Saturation and Aggressive Indices and Specific Conductance are tests to measure the corrosivity of water. The results indicate that PID water is mildly corrosive. Zinc orthophosphate (ZOP) is added at the treatment plant in an attempt to control corrosion of metallic piping in the distribution system.

No ground water used; the well is run (to waste) strictly for sampling purposes. Iron levels can be elevated due to sitting water in iron well casing with no use.

PRIMARY HEALTH STANDARDS		Surface Water Supply			Groundwater Supply			MAJOR SOURCE IN DRINKING WATER
SUBSTANCE (UNIT OF MEASURE)	MCL	YEAR SAMPLED	AVERAGE DETECTED	RANGE LOW-HIGH	YEAR SAMPLED	AVERAGE DETECTED	RANGE LOW-HIGH	
INORGANIC								
Chromium (Total) (ppb)	50	2020	ND	ND	2023	ND	3.4	Erosion of natural deposits
Hexavalent Chromium (ppb)	10	2025	ND	ND	2025	1	1	Oxidized Chromium. Erosion of Natural Deposits
Nitrate (ppm)	10	2025	ND	ND	2025	0.4	0.4	Runoff and leaching from fertilizer use
CLARITY								
Turbidity (NTU) (prior to treatment, raw water)	~	2025	1.10	0.30-6.55	2023	0.8	0.18	Soil runoff
Turbidity (NTU) (TT) (treated water)	0.2	2025	0.04	0.03-0.09	NA	NA	NA	Soil runoff
Turbidity is a measurement of the cloudiness of the water. Turbidity measurement is a good indicator of the effectiveness of the filtration system. PID's permit with State Drinking Division requires PID to deliver water with no more than 0.2 NTU.								
RADIOLOGICAL								
Gross Alpha Particle Activity, (pCi/L)	15	2024	0.232	0.232	2024	0.881	0.881	Erosion of natural deposits.
Radium 228 (pCi/L)	5	2017	2.2	2.2	2017	2.93	2.93	Erosion of natural deposits.
DISINFECTANT								
Chlorine, Free Residual as Cl2 (ppm) (TT)	4	2025	0.66	0.28-1.09	NA	NA	NA	Water additive used to control microbes.
DISINFECTANT BY-PRODUCTS								
Trihalomethanes, Total (ppb)	80	2025	35.6	26-42	NA	NA	NA	Drinking water disinfection.
Haloacetic Acids, Total (ppb)	60	2025	38.9	29-55	NA	NA	NA	Drinking water disinfection.
DISINFECTANT BY-PRODUCT PRECURSOR								
Total Organic Carbon (prior to treatment)	~	2025	1.25	0.7-1.6	NA	NA	NA	Decay of natural organic matter.
REGULATED VOCS								
Volatile Organic Compounds	~	~	~	~	2024	ND	ND	Industrial waste, agricultural runoff.

UNREGULATED AND OTHER SUBSTANCES		Surface Water Supply			Groundwater Supply			MAJOR SOURCE IN DRINKING WATER
CHEMICAL (UNIT OF MEASURE)		YEAR SAMPLED	AVERAGE DETECTED	RANGE LOW-HIGH	YEAR SAMPLED	AVERAGE DETECTED	RANGE LOW-HIGH	
Alkalinity as CaC03 (ppm)		2020	30	30	2023	90	90	Natural occurring substance.
Bicarbonate Alkalinity (ppm)		2020	40	40	2023	110	110	Natural occurring substance.
Calcium (ppm)		2020	6	6	2023	16	16	Natural occurring substance.
Magnesium (ppm)		2020	4	4	2023	9	9	Natural occurring substance.
Sodium (ppm)		2020	3	3	2023	6	6	Natural occurring substance.
pH		2025	7.2	7.1-7.3	2024	7.4	7.1-7.6	Slightly basic water.
Potassium (K) mg/L		2020	ND	ND	2023	2	2	Natural occurring substance.
Vanadium (µg/L)		2020	ND	ND	2023	15	15	Natural occurring substance.

Fluoride is not added to the District's drinking water; fluoride concentration in the raw water is not detectable.
 No ground water used; the well is run (to waste) strictly for sampling purposes.

TOTAL COLIFORM AND E.COLI SAMPLING IN 2024

MICROBIOLOGICAL CONTAMINANTS (AND REPORTING UNITS)	HIGHEST NUMBER DETECTED	# MONTHS IN VIOLATION	MCL	IN COMPLIANCE?	MAJOR SOURCE IN DRINKING WATER
Total Coliform	0	0	1 sample	Yes	Naturally present in environment.
Fecal Coliform or E.coli (State Total Coliform rule)	0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or E. coli positive	Yes	Human and animal fecal waste.
Fecal Coliform or E.coli (Federal Revised Total Coliform rule)	0	0	Routine and repeat samples are total coliform-positive and either is E. coli positive or system fails to take repeat samples following E. coli-positive routine sample or system fails to analyze total coliform-positive repeat sample for E. coli	Yes	Human and animal fecal waste.

LEAD & COPPER ANALYSES

PID will be collecting the routine three-year lead and copper samples during the summer of 2026. PID has not experienced any issues with lead and copper analyses in the past and does not expect any in the future. Consistent with 40 CFR sections 141.84(a)(7) and 40 CFR 141.153(h)(8)(ii), a service line inventory has been prepared, the service line inventory is available at the district office for anyone who may be interested. PID has not found any lead service lines in the inventory of our system.

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	VIOLATION?	AL	PHG (MCLG)	AMOUNT DETECTED (90 TH %TILE)	SITES ABOVE AL/ TOTAL SITES	TYPICAL SOURCE
Copper (ppm at the 90th percentile)	2023	No	1.3	0.3	0.073	0/20	Internal corrosion household plumbing.
Lead (ppb at the 90th percentile)	2023	No	15	0.2	ND	0/20	Internal corrosion household plumbing.

PID continued to collect “non-detect” PFAS results in 2025

PID remains proud of its leadership in water quality.

In April 2024, the U.S. Environmental Protection Agency (EPA) issued the final National Primary Drinking Water Regulation (NPDWR) for Per- and Polyfluoroalkyl Substances (PFAS). This rule

- For information regarding the upcoming regulations, go to EPA.gov
- Samples from PID’s Water Treatment Plant and well continue with non-detect results.

requires all community and non-transient non-community water systems to complete initial PFAS monitoring by April 26, 2027. PID has participated in this testing and continues to produce non-detect results

PID began testing for PFAS in 2023 and

have repeated this sampling at the Water Treatment Plant and district well in 2025.

PID remains committed to transparency and public trust by voluntarily conducting PFAS testing and openly sharing results.

We will not be complacent when it comes to protecting our community’s water—our proactive approach reflects our ongoing dedication to safety, quality, and accountability.



All current samples for PFAs were “non-detect” results. This includes samples from PID’s Treatment Plant as well as the district well.

The state of Paradise’s water supply—it’s good news!

- As of April 1, 2026 the combined raw water storage at the Paradise Lake and Magalia Reservoir was 12,151 acre-feet.
- From Jan. 1, 2025 to Dec. 31, 2025 PID’s Water Treatment Plant produced 3,761.53 acre-feet of drinking water to provide to the community.
- On average, the combined Paradise household has an annual demand of 2,324.3 acre-feet and the average individual Paradise household has an annual demand of .386 acre-feet.
- At current production rates, PID has approximately 3.064 years of storage if we receive no incoming water to our reservoirs.*



Inside...

All about your water!

- Annual water report

Your water district in 2025

- By the numbers!

Tips for your household

- Benefits of Dropcounter



**Our water.
Our future.**

Paradise Irrigation District

6332 CLARK ROAD
PARADISE, CA 95969
(530) 877-4991

Documentary about PID's restoration of water system to air in July

"Water After Wildfire," a documentary about the recovery efforts by PID to restore healthy, safe water to our community after the Camp Fire, will be aired in July on local television station KHSL, channel 12.


The documentary, in production over the past year, may be viewed on July 11 as well as July 25 at 7:30 pm. Additionally, the documentary will be available

on Channel 12's website through mid-August (actionnewsnow.com).

After that, PID will host the document on its own YouTube channel.

The documentary details the fire "experience" of many PID employees working that day and immediately after the fire as well as the experts consulted with and the multitude

of recovery efforts as the district worked to successfully restore water to the Paradise community.



Source Water Assessment available at PID office

PID's 2021 Source Water Assessment is a report of the area of influence around our listed "raw" water sources through which contaminants, if present, could reach our source water. It includes an inventory of potential sources of contamination within the area and a determination of the water supply's susceptibility to contamination by the identified potential sources including:

Ground Water Supply (Well at D Tank): High-density septic systems and automobile repair shops.

Surface Water Supply (Little Butte Creek Watershed): High-density septic systems and historic mining operations.

The Source Water Assessment is also available at the State Water Resources Control Board Division of Drinking Water (Redding office): 364 Knollcrest Dr., Suite 101; Redding, CA 96002; (530) 224-4800

PID's water treatment process from start to your home:

Raw water from Magalia Reservoir or Little Butte Creek through the Magalia Bypass is treated before being distributed to Paradise residents. The treatment process consists of coagulation, clarification, filtration and disinfection. The coagulation process consists of adding alum and polymer to the water to chemically bond very small particles in the water into larger particles. Coagulated water is passed through a bed of coarse granulated media in the absorption clarifiers. Coarse media in the clarifier removes most of the coagulated particles.

Clarified water flows downward through tri-media filters consisting of anthracite, sand, and fine garnet to remove the remaining particulates and "polish" the finished water. A minimum amount of chlorine is added to the finished water to meet California state requirements. Chlorine can be added either to the raw water prior to filtration or to the filtered water. Filtered water is routed through a treated water storage tank to provide sufficient time for the chlorine to kill any bacteria remaining in the water. This water is then routed to off-site reservoirs for distribution to Paradise residents.

Health information for the medically-vulnerable

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking treated water from their health care providers.

The US EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants



are available from the Safe Drinking Water Hotline at (800) 426-4791 or <http://water.epa.gov/drink/hotline>.

Paradise Irrigation District is a special district governed by a local board of directors elected by community residents. You can get involved with PID's governance by attending PID Board of Director meetings; the regular meeting is held at 9 am on the third Wednesday of each month at the district office, 6332 Clark Road, Paradise. You can also attend online using the Zoom link under Meetings/Agendas on this page: PIDWater.com. Meeting agendas are linked on the same page.