

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG) or Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the USEPA. PHGs are set by the California EPA.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring, reporting and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MDL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (ug/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picograms per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

*Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Colusa County Water a 530-237-2651 para asistirlo en español.*

For questions or concerns about your drinking water, you may attend a board meeting on the 3<sup>rd</sup> Tuesday of each month or contact:

Lance Swift  
530-520-1311

# 2025 Consumer Confidence Report Colusa County WWD #1 – Grimes

Here at Colusa Co WD Grimes, we want you to understand the efforts we make to provide you with a safe and dependable drinking water supply. We continually monitor our drinking water quality and strive to protect our water resources. We regularly test our drinking water for many different constituents as required by State and Federal Regulations. This “Water Quality Report” includes those constituents that were *detected* in 2025 and may include earlier monitoring data.

Our drinking water is supplied by two treated groundwater wells (Well 01 and Well 02). Well 02 is a standby well.

In 2025, we began constructing a new well and planning a treatment facility to address ongoing arsenic detections in Well 01.

Additionally, during the 2025 monitoring period, the required number of Lead and Copper Rule samples were not collected. We have scheduled the collection of these samples for the summer of 2026 to return the system to full compliance.

A source water assessment was completed by the Division of Drinking Water on August 1, 2000, to determine if there were possible contaminating activities that might

compromise the quality of the water. At the time, there were no associated contaminants detected in the water supply, however both sources were still considered vulnerable to a low density (less than 1 per acre) of septic systems located in the area. As well as historic gas stations located in the area. A copy of the complete report is available at 364 Knollcrest Drive, Suite 101, Redding, CA 96002.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants (such as viruses and bacteria) that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;

Inorganic contaminants (such as salts and metals) that can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and herbicides that may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses;

Organic chemical contaminants, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems

Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Please note that drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. US EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

For information on the system's Lead Line Inventory reach out to the system contact below, or go to:

[https://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/lead-copper-rule/service-line-data.html](https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/lead-copper-rule/service-line-data.html)

These tables list all of the drinking water contaminants that were **detected** during the most recent sampling for each constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked and explained below.

**TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA**

| Microbiological Contaminants  | Highest No. of detections | No. of months in violation | MCL | MCLG | Typical Source of Bacteria   |
|---|---------------------------|----------------------------|-----|------|------------------------------|
| <i>E. coli</i>  | 0 (in the year)           | 0                          | (a) | 0    | Human and animal fecal waste |
| (a) Routine and repeat samples are total coliform-positive and either is <i>E. coli</i> -positive, or system fails to take repeat samples following <i>E. coli</i> -positive routine sample or system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> . |                           |                            |     |      |                              |

**TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

| Lead and Copper         | No. of samples collected | 90 <sup>th</sup> percentile level detected | Range of Detections | No. sites exceeding AL | AL  | PHG | Typical Source of Contaminant   |
|-------------------------|--------------------------|--|---------------------|------------------------|-----|-----|---|
| Lead (ppb)<br>09/2025   | 5                        | 5.8  | 0.9 - 7.4           | None                   | 15  | 0.2 | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits |
| Copper (ppm)<br>09/2025 | 5                        | 0.036                                      | 0.007 - 0.036       | None                   | 1.3 | 0.3 | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives               |

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Colusa Co WWD1 is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Colusa Co WWD1 530-520-1311. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

**TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL  | PHG (MCLG) | Typical Source of Contaminant  |
|---|-------------|----------------|---------------------|------|------------|--|
| Sodium (ppm)                                  | 2019        | 55             | 53 - 57             | None | None       | Salt present in the water and is generally naturally occurring   |
| Hardness (ppm)                                | 2019        | 50             | 48 - 52             | None | None       | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

**TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

| Chemical or Constituent (and reporting units)   | Sample Date | Level Detected | Range of Detections | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant   |
|---|-------------|----------------|---------------------|------------|--------------------|---|
| Arsenic (ppb)   | 2025        | <b>22.8*</b>   | <b>21.9 - 23.7</b>  | 10         | 0.004              | Erosion of natural deposits; runoff from orchards; glass and electronics production wastes  |
| *Some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems, and may have an increased risk of getting cancer. |             |                |                     |            |                    |   |
| Chromium (hexavalent) (ppb)   | 01/23/25    | 0.1            |                     | 10         | 0.02               | Erosion of natural deposits; transformation of naturally occurring trivalent chromium to hexavalent chromium by natural processes and human activities such as discharges from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities. |
| Total Trihalomethanes - TTHM (ppb)  | 08/21/25    | 17             |                     | 80         | N/A                | Byproduct of drinking water disinfection  |

**TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | SMCL | PHG (MCLG) | Typical Source of Contaminant                                 |
|---|-------------|----------------|---------------------|------|------------|---|
| Chloride (ppm)                                | 2019        | 7.6            | 7.3 - 7.9           | 500  | N/A        | Runoff and leaching from natural deposits; seawater influence |
| Manganese (ppb)                               | 2019        | 37.4           | 34.7 - 40.0         | 50   | N/A        | Leaching from natural deposits                                |
| Specific Conductivity (µS/cm)                 | 2019        | 316            | 315 - 317           | 1600 | N/A        | Substances that form ions when in water; seawater influence   |
| Sulfate (ppm)                                 | 2019        | 3.9            | 3.7 - 4.1           | 500  | N/A        | Runoff and leaching from natural deposits; industrial wastes  |
| Total Dissolved Solids (ppm)                  | 2019        | 203            | 194 - 212           | 1000 | N/A        | Runoff and leaching from natural deposits                     |

\*\* There are no PHGs, MCLGs, or mandatory standard health effects language for these constituents because secondary MCLs are set on the basis of aesthetics.