

2024 Consumer Confidence Report

Water System Name: MORNING STAR PKG. CO.-WMS.

Report Date: March 2025

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2024.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 3 source(s): WELL 01 - RAW, WELL 02 and WELL 03

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not being held. However, The Morning Star Packing Co. includes any and all CCR documents in their annual orientation packets that are distributed to all colleagues pre-season.

For more information about this report, or any questions relating to your drinking water, please call or visit our website at www.morningstarco.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	2/year (2024)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2022)	69	66 - 74	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2022)	215	210 - 223	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2022 - 2023)	ND	ND - 2	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Hexavalent Chromium (ug/L)	(2024)	2.1	ND - 4.3		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.

Fluoride (mg/L)	(2022 - 2023)	0.3	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2023 - 2024)	0.8	0.6 - 1.1	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2017)	ND	ND - 0.5	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2018)	2.76	1.52 - 3.99	15	(0)	Erosion of natural deposits.

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2022)	45	41 - 48	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ug/L)	(2022)	523	ND - 1210	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2022)	27	ND - 50	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2022)	698	665 - 726	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2022)	68.1	65.2 - 69.6	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2022)	430	410 - 440	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2017)	7.7	0.3 - 15.1	5	n/a	Soil runoff

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects
Boron (mg/L)	(2022)	0.2	0.2 - 0.3	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Vanadium (ug/L)	(2023)	5	n/a	50	Vanadium exposures resulted in developmental and reproductive effects in rats.
Manganese (ug/L)	(2022)	27	ND - 50	500	Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.

Table 6 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2022)	45	39 - 48	n/a	n/a
Magnesium (mg/L)	(2022)	25	22 - 28	n/a	n/a
pH (units)	(2022)	7.76	7.5 - 8.1	n/a	n/a
Alkalinity (mg/L)	(2022)	223	220 - 230	n/a	n/a
Aggressiveness Index	(2022)	12.2	11.9 - 12.5	n/a	n/a
Langelier Index	(2022)	0.29	0.06 - 0.6	n/a	n/a

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
--	-------------	------------------------	---------------------	------------	------------	-----------	--------------------------------

Chlorine, Free (mg/L)	(2024)	1.03	ND - 2.20	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ug/L)	(2022)	1	n/a	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts if some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *The Morning Star Packing Company-DW* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language

Total Coliform Bacteria				Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.
Iron				Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.
Manganese				Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.
Turbidity				Turbidity is Secondary Drinking Water Standards and has found no health effects. However, high levels of turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.
Citation #21-24C-006 8/16/2024	FAILURE TO FOLLOW STATE BOARD-APPROVED BACTI SAMPLE SITING PLAN, FAILURE TO COLLECT ALL REPEAT BACTI SAMPLES FOR JULY 2024		CERTIFICATION OF COMPLETION OF PUBLIC NOTIFICATION 8/27/2024	

2024 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 01 - RAW and WELL 02 of the MORNING STAR PKG. CO.-WMS. water system in April, 2003.

- WELL 01 - RAW - is considered most vulnerable to the following activities not associated with any detected contaminants:
Chemical/petroleum processing/storage
- WELL 02 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Chemical/petroleum processing/storage
- WELL 03 - does not have a completed assessment on file.

Discussion of Vulnerability

Well 01 - There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Well 02 - There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Well 03 - Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

A copy of the complete assessment may be viewed at:

Redding Field Operations Office
364 Knollcrest Drive, Suite 101
Redding, CA 96002

You may request a summary of the assessment be sent to you by contacting:

Rebecca Tabor
District Engineer
530-224-2487
530-224-4844 (fax)
Rebecca.Tabor@waterboards.ca.gov

For more info you may visit https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/DWSAP.html or contact the health department in the county to which the water system belongs as indicated on this following link: https://www.waterboards.ca.gov/drinking_water/programs/documents/ddwem/DDWdistrictofficesmap.pdf

The Morning Star Packing Company-DW

Analytical Results By FGL - 2024

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	2 - 2
Bacti-Well 01-Raw	CH 2478145-1					2024-08-29	<1.0		
Bacti-Well 01-Raw	CH 2472196-1					2024-03-26	2		
Grade Station	CH 2478146-1					2024-08-29	Absent		
Grade Station	CH 2472019-1					2024-03-21	Absent		
Laboratory	CH 2476479-2					2024-07-18	Absent		
Outside Shipping Office	CH 2491549-1					2024-12-19	Absent		
Outside Shipping Office	CH 2490804-1					2024-11-21	Absent		
Outside Shipping Office	CH 2475094-1					2024-06-24	Absent		
Outside Shipping Office	CH 2473688-1					2024-05-09	Absent		
Outside Shipping Office	CH 2470628-1					2024-01-25	Absent		
Rail Dock	CH 2490052-1					2024-10-29	Absent		
Shipping Office	CH 2471329-2					2024-02-26	<1.0		
Truck Dock	CH 2476479-1					2024-07-18	Absent		
Truck Dock	CH 2476338-1					2024-07-16	Present		
Truck Dock	CH 2470935-1					2024-02-08	Absent		
Truck Shop	CH 2479048-1					2024-09-26	Absent		
Truck Shop	CH 2473257-1					2024-04-25	Absent		
Truck Shop	CH 2471329-1					2024-02-26	<1.0		
Fecal coliform and E. coli				0	n/a			ND	-
Bacti-Well 01-Raw	CH 2478145-1					2024-08-29	<1.0		
Bacti-Well 01-Raw	CH 2472196-1					2024-03-26	<1.0		
Grade Station	CH 2478146-1					2024-08-29	Absent		
Grade Station	CH 2472019-1					2024-03-21	Absent		
Laboratory	CH 2476479-2					2024-07-18	Absent		
Outside Shipping Office	CH 2491549-1					2024-12-19	Absent		
Outside Shipping Office	CH 2490804-1					2024-11-21	Absent		
Outside Shipping Office	CH 2475094-1					2024-06-24	Absent		
Outside Shipping Office	CH 2473688-1					2024-05-09	Absent		
Outside Shipping Office	CH 2470628-1					2024-01-25	Absent		
Rail Dock	CH 2490052-1					2024-10-29	Absent		
Shipping Office	CH 2471329-2					2024-02-26	<1.0		
Truck Dock	CH 2476479-1					2024-07-18	Absent		
Truck Dock	CH 2476338-1					2024-07-16	Absent		
Truck Dock	CH 2470935-1					2024-02-08	Absent		
Truck Shop	CH 2479048-1					2024-09-26	Absent		
Truck Shop	CH 2473257-1					2024-04-25	Absent		
Truck Shop	CH 2471329-1					2024-02-26	<1.0		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			0	5
Breakroom	CH 2376795-4	ug/L				2023-08-17	ND		
Mens Bathroom	CH 2376795-1	ug/L				2023-08-17	ND		
Office	CH 2376795-3	ug/L				2023-08-17	ND		
QC Lab	CH 2376795-5	ug/L				2023-08-17	ND		
Shipping Office	CH 2376795-2	ug/L				2023-08-17	ND		
Copper		mg/L		1.3	.3			0	5
Breakroom	CH 2376795-4	mg/L				2023-08-17	ND		
Mens Bathroom	CH 2376795-1	mg/L				2023-08-17	ND		
Office	CH 2376795-3	mg/L				2023-08-17	ND		
QC Lab	CH 2376795-5	mg/L				2023-08-17	ND		
Shipping Office	CH 2376795-2	mg/L				2023-08-17	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			69	66 - 74
WELL 01 - RAW	CH 2270194-1	mg/L				2022-01-11	68		
WELL 02	CH 2270194-2	mg/L				2022-01-11	74		
WELL 03	CH 2270194-3	mg/L				2022-01-11	66		
Hardness		mg/L		none	none			215	210 - 223
WELL 01 - RAW	CH 2270194-1	mg/L				2022-01-11	223		
WELL 02	CH 2270194-2	mg/L				2022-01-11	213		
WELL 03	CH 2270194-3	mg/L				2022-01-11	210		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			ND	ND - 2
WELL 01 - RAW	CH 2275674-1	ug/L				2022-07-14	2		
WELL 02	CH 2275674-2	ug/L				2022-07-14	2		
WELL 03	CH 2371580-1	ug/L				2023-03-09	ND		
Hexavalent Chromium		ug/L			0.02			2.1	ND - 4.3
WELL 01 - RAW	CH 2490050-1	ug/L				2024-10-29	ND		
WELL 02	CH 2490050-2	ug/L				2024-10-29	2.0		
WELL 03	CH 2490050-3	ug/L				2024-10-29	4.3		
Fluoride		mg/L		2	1			0.3	0.3 - 0.3
WELL 01 - RAW	CH 2270194-1	mg/L				2022-01-11	0.3		
WELL 02	CH 2270194-2	mg/L				2022-01-11	0.3		
WELL 03	CH 2371580-1	mg/L				2023-03-09	0.3		
Nitrate as N		mg/L		10	10			0.8	0.6 - 1.1
Well 01 - Raw	CH 2476337-1	mg/L				2024-07-25	0.6		
WELL 01 - RAW	CH 2376001-1	mg/L				2023-07-27	0.6		
Well 02	CH 2476337-2	mg/L				2024-07-25	0.7		
WELL 02	CH 2376001-2	mg/L				2023-07-27	1.0		
WELL 03	CH 2472017-1	mg/L				2024-03-21	1.1		
Nitrate + Nitrite as N		mg/L		10	10			ND	ND - 0.5
WELL 01 - RAW	CH 1777513-1	mg/L				2017-08-31	0.5		
WELL 02	CH 1777513-2	mg/L				2017-08-31	ND		
Gross Alpha		pCi/L		15	(0)			2.76	1.52 - 3.99
WELL 01 - RAW	CH 1874410-1	pCi/L				2018-06-14	3.99		
WELL 02	CH 1874410-2	pCi/L				2018-06-14	1.52		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			45	41 - 48
WELL 01 - RAW	CH 2270194-1	mg/L				2022-01-11	47		
WELL 02	CH 2270194-2	mg/L				2022-01-11	48		
WELL 03	CH 2270194-3	mg/L				2022-01-11	41		
Iron		ug/L		300	n/a			523	ND - 1210
WELL 01 - RAW	CH 2270194-1	ug/L				2022-01-11	ND		
WELL 02	CH 2270194-2	ug/L				2022-01-11	1210		
WELL 03	CH 2270194-3	ug/L				2022-01-11	360		
Manganese		ug/L		50	n/a			27	ND - 50
WELL 01 - RAW	CH 2270194-1	ug/L				2022-01-11	ND		
WELL 02	CH 2270194-2	ug/L				2022-01-11	50		
WELL 03	CH 2270194-3	ug/L				2022-01-11	30		
Specific Conductance		umhos/cm		1600	n/a			698	665 - 726
WELL 01 - RAW	CH 2270194-1	umhos/cm				2022-01-11	702		
WELL 02	CH 2270194-2	umhos/cm				2022-01-11	726		
WELL 03	CH 2270194-3	umhos/cm				2022-01-11	665		
Sulfate		mg/L		500	n/a			68.1	65.2 - 69.6

WELL 01 - RAW	CH 2270194-1	mg/L				2022-01-11	69.6		
WELL 02	CH 2270194-2	mg/L				2022-01-11	69.6		
WELL 03	CH 2270194-3	mg/L				2022-01-11	65.2		
Total Dissolved Solids		mg/L		1000	n/a			430	410 - 440
WELL 01 - RAW	CH 2270194-1	mg/L				2022-01-11	440		
WELL 02	CH 2270194-2	mg/L				2022-01-11	440		
WELL 03	CH 2270194-3	mg/L				2022-01-11	410		
Turbidity		NTU		5	n/a			7.7	0.3 - 15.1
WELL 01 - RAW	CH 1777513-1	NTU				2017-08-31	0.3		
WELL 02	CH 1777513-2	NTU				2017-08-31	15.1		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			0.2	0.2 - 0.3
WELL 01 - RAW	CH 2270194-1	mg/L				2022-01-11	0.2		
WELL 02	CH 2270194-2	mg/L				2022-01-11	0.3		
WELL 03	CH 2270194-3	mg/L				2022-01-11	0.2		
Vanadium		ug/L		NS	n/a			5	5 - 5
WELL 03	CH 2371580-1	ug/L				2023-03-09	5		
Manganese		ug/L		NS	n/a			27	ND - 50
WELL 01 - RAW	CH 2270194-1	ug/L				2022-01-11	ND		
WELL 02	CH 2270194-2	ug/L				2022-01-11	50		
WELL 03	CH 2270194-3	ug/L				2022-01-11	30		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			45	39 - 48
WELL 01 - RAW	CH 2270194-1	mg/L				2022-01-11	48		
WELL 02	CH 2270194-2	mg/L				2022-01-11	39		
WELL 03	CH 2270194-3	mg/L				2022-01-11	48		
Magnesium		mg/L			n/a			25	22 - 28
WELL 01 - RAW	CH 2270194-1	mg/L				2022-01-11	25		
WELL 02	CH 2270194-2	mg/L				2022-01-11	28		
WELL 03	CH 2270194-3	mg/L				2022-01-11	22		
pH		units			n/a			7.76	7.5 - 8.1
WELL 01 - RAW	CH 2270194-1	units				2022-01-11	7.5		
WELL 02	CH 2270194-2	units				2022-01-11	8.1		
WELL 03	CH 2270194-3	units				2022-01-11	7.68		
Alkalinity		mg/L			n/a			223	220 - 230
WELL 01 - RAW	CH 2270194-1	mg/L				2022-01-11	220		
WELL 02	CH 2270194-2	mg/L				2022-01-11	230		
WELL 03	CH 2270194-3	mg/L				2022-01-11	220		
Aggressiveness Index					n/a			12.2	11.9 - 12.5
WELL 01 - RAW	CH 2270194-1					2022-01-11	11.9		
WELL 02	CH 2270194-2					2022-01-11	12.5		
WELL 03	CH 2270194-3					2022-01-11	12.1		
Langelier Index					n/a			0.29	0.06 - 0.6
WELL 01 - RAW	CH 2270194-1					2022-01-11	0.06		
WELL 02	CH 2270194-2					2022-01-11	0.6		
WELL 03	CH 2270194-3					2022-01-11	0.2		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chlorine		mg/L		4.0	4.0			1.03	ND - 2.20
Bacti-Well 01-Raw	CH 2472196-1	mg/L				2024-03-26	ND		
Average Bacti-Well 01-Raw								0	
Grade Station	CH 2478146-1	mg/L				2024-08-29	ND		

The Morning Star Packing Company-DW

CCR Login Linkage - 2024

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Bacti-Well 01-R	CH 2472196-1	2024-03-26	Field Test	Bacti-Well 01-Raw	Bacteriological Source Monitoring
	CH 2472196-1	2024-03-26	Coliform	Bacti-Well 01-Raw	Bacteriological Source Monitoring
Bacti-ssWell01	CH 2478145-1	2024-08-29	Coliform	Bacti-Well 01-Raw	Bacteriological Source Monitoring
0605002_DST_LCR	CH 2376795-4	2023-08-17	Metals, Total	Breakroom	MORNING STAR PKG. CO.-WMS.
Tck Shp	CH 1476624-1	2014-08-28	EPA 552.2	DBPR - RSS Truck Stop	DBP Monitoring
Bacti-ss03	CH 2472019-1	2024-03-21	Coliform	Grade Station	Bacteriological Monitoring 3
	CH 2472019-1	2024-03-21	Field Test	Grade Station	Bacteriological Monitoring 3
	CH 2478146-1	2024-08-29	Field Test	Grade Station	Bacteriological Monitoring 3
	CH 2478146-1	2024-08-29	Coliform	Grade Station	Bacteriological Monitoring 3
LAB	CH 2476479-2	2024-07-18	Field Test	Laboratory	Drinking Water Monitoring
	CH 2476479-2	2024-07-18	Coliform	Laboratory	Drinking Water Monitoring
0605002_DST_LCR	CH 2376795-1	2023-08-17	Metals, Total	Mens Bathroom	MORNING STAR PKG. CO.-WMS.
	CH 2376795-3	2023-08-17	Metals, Total	Office	MORNING STAR PKG. CO.-WMS.
Bacti-ss01	CH 2470628-1	2024-01-25	Field Test	Outside Shipping Office	Bacteriological System Monitoring-1
	CH 2470628-1	2024-01-25	Coliform	Outside Shipping Office	Bacteriological System Monitoring-1
	CH 2473688-1	2024-05-09	Coliform	Outside Shipping Office	Bacteriological System Monitoring-1
	CH 2473688-1	2024-05-09	Field Test	Outside Shipping Office	Bacteriological System Monitoring-1
	CH 2475094-1	2024-06-24	Coliform	Outside Shipping Office	Bacteriological System Monitoring-1
	CH 2475094-1	2024-06-24	Field Test	Outside Shipping Office	Bacteriological System Monitoring-1
	CH 2490804-1	2024-11-21	Coliform	Outside Shipping Office	Bacteriological System Monitoring-1
	CH 2490804-1	2024-11-21	Field Test	Outside Shipping Office	Bacteriological System Monitoring-1
	CH 2491549-1	2024-12-19	Field Test	Outside Shipping Office	Bacteriological System Monitoring-1
	CH 2491549-1	2024-12-19	Coliform	Outside Shipping Office	Bacteriological System Monitoring-1
0605002_DST_LCR	CH 2376795-5	2023-08-17	Metals, Total	QC Lab	MORNING STAR PKG. CO.-WMS.
Bacti-ss05	CH 2490052-1	2024-10-29	Field Test	Rail Dock	Bacteriological Monitoring 5
	CH 2490052-1	2024-10-29	Coliform	Rail Dock	Bacteriological Monitoring 5
DBPR-ss01	CH 2276785-1	2022-08-11	EPA 552.2	RSS Truck Stop	DBP Monitoring
0605002_DST_LCR	CH 2376795-2	2023-08-17	Metals, Total	Shipping Office	MORNING STAR PKG. CO.-WMS.
CuPb-ss02	CH 2471329-2	2024-02-26	Coliform	Shipping Office	Drinking Water Monitoring
	CH 2471329-2	2024-02-26	Field Test	Shipping Office	Drinking Water Monitoring
Bacti-ss02	CH 2470935-1	2024-02-08	Coliform	Truck Dock	Bacteriological System Monitoring-2
	CH 2470935-1	2024-02-08	Field Test	Truck Dock	Bacteriological System Monitoring-2
	CH 2476338-1	2024-07-16	Field Test	Truck Dock	Bacteriological System Monitoring-2
	CH 2476338-1	2024-07-16	Coliform	Truck Dock	Bacteriological System Monitoring-2
	CH 2476479-1	2024-07-18	Coliform	Truck Dock	Bacteriological System Monitoring-2
	CH 2476479-1	2024-07-18	Field Test	Truck Dock	Bacteriological System Monitoring-2
Bacti-ss04	CH 2471329-1	2024-02-26	Coliform	Truck Shop	Drinking Water Monitoring
	CH 2471329-1	2024-02-26	Field Test	Truck Shop	Drinking Water Monitoring
	CH 2473257-1	2024-04-25	Coliform	Truck Shop	Bacteriological Monitoring 4
	CH 2473257-1	2024-04-25	Field Test	Truck Shop	Bacteriological Monitoring 4
	CH 2479048-1	2024-09-26	Coliform	Truck Shop	Bacteriological Monitoring 4
	CH 2479048-1	2024-09-26	Field Test	Truck Shop	Bacteriological Monitoring 4
WELL01	CH 1777513-1	2017-08-31	General Mineral	WELL 01 - RAW	Water Quality Monitoring
	CH 1777513-1	2017-08-31	Wet Chemistry	WELL 01 - RAW	Water Quality Monitoring
	CH 1874410-1	2018-06-14	Radio Chemistry	WELL 01 - RAW	Radio Monitoring
	CH 2270194-1	2022-01-11	General Mineral	WELL 01 - RAW	MORNING STAR PKG. CO.-WMS.
	CH 2275674-1	2022-07-14	Metals, Total	WELL 01 - RAW	Water Quality Monitoring
	CH 2376001-1	2023-07-27	Wet Chemistry	WELL 01 - RAW	Water Quality Monitoring
	CH 2476337-1	2024-07-25	Wet Chemistry	Well 01 - Raw	Water Quality Monitoring
	CH 2490050-1	2024-10-29	Wet Chemistry	WELL 01 - RAW	Chromium VI Monitoring
WELL02	CH 1777513-2	2017-08-31	Wet Chemistry	WELL 02	Water Quality Monitoring
	CH 1777513-2	2017-08-31	General Mineral	WELL 02	Water Quality Monitoring
	CH 1874410-2	2018-06-14	Radio Chemistry	WELL 02	Radio Monitoring
	CH 2270194-2	2022-01-11	General Mineral	WELL 02	MORNING STAR PKG. CO.-WMS.
	CH 2275674-2	2022-07-14	Metals, Total	WELL 02	Water Quality Monitoring
	CH 2376001-2	2023-07-27	Wet Chemistry	WELL 02	Water Quality Monitoring

	CH 2476337-2	2024-07-25	Wet Chemistry	Well 02	Water Quality Monitoring
	CH 2490050-2	2024-10-29	Wet Chemistry	WELL 02	Chromium VI Monitoring
0605002-005	CH 2270194-3	2022-01-11	General Mineral	WELL 03	MORNING STAR PKG. CO.-WMS.
	CH 2371580-1	2023-03-09	Wet Chemistry	WELL 03	Well 3 Water Quality Monitoring
	CH 2371580-1	2023-03-09	Metals, Total	WELL 03	Well 3 Water Quality Monitoring
	CH 2472017-1	2024-03-21	Wet Chemistry	WELL 03	Well 3 Water Quality Monitoring
	CH 2490050-3	2024-10-29	Wet Chemistry	WELL 03	Chromium VI Monitoring