

# EL DORADO IRRIGATION DISTRICT



[www.eid.org/main](http://www.eid.org/main)

## 2021 Water Quality Report

Water testing performed in 2021



## STRAWBERRY WATER SYSTEM

Este informe contiene información muy importante sobre su agua beber.  
Tradúzcalo o hable con alguien que lo entienda bien.

### About the Water Quality Report (Consumer Confidence Report)

The Water Quality Report is an annual summary of the results of ongoing tests for contaminants in drinking water. The report is designed to inform you of the quality of your drinking water. Each year, the State Water Resources Control Board and U.S. Environmental Protection Agency require EID to compile and distribute a report to all of our water customers. The report includes a comparison of the District's water quality to state and federal standards.

### Where Your Water Comes From

The Strawberry water system provides water to approximately 400 people in the Strawberry community, located approximately 40 miles east of Placerville along Highway 50. Water for the Strawberry system is diverted from the upper South Fork American River and treated at the District's Strawberry water treatment plant.



### About EID

EID is a multi-service public utility serving drinking water to approximately 130,000 people in El Dorado County. The District holds water rights in the Sierra Nevada foothills that date back to the Gold Rush. Today EID provides a unique combination of services—from drinking water and water for pastures, orchards, and vineyards to wastewater treatment, recycled water for irrigated landscapes and back and front yards, hydroelectric and solar power generation, water efficiency programs, and outstanding recreation in Sierra Nevada alpine and western slope environments.

## Your Drinking Water—What You Should Know

The sources of drinking water—both tap and bottled—include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, and farming.
- **Pesticides and herbicides** that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants** including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production and can also come from gas stations, urban stormwater runoff, agricultural applications, and septic systems.
- **Radioactive contaminants** that can be naturally-occurring or are the result of oil and gas production and mining activities.

Unregulated contaminant monitoring helps EPA and the State Water Resources Control Board determine where certain contaminants occur and whether the contaminants need to be regulated.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency and the State Water Resources Control Board, Division of Drinking Water prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection.

NOTE: Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Contact the EPA's Safe Drinking Water Hotline at 1-800-426-4791 for more about contaminants and potential health effects.

## Information about potential sources of pollution

The State Water Resources Control Board, Division of Drinking Water requires water providers to conduct a source water assessment to help protect the quality of water supplies. The assessment describes where a water system's drinking water comes from, the types of polluting activities that may threaten the quality of the source water, and an evaluation of the water's vulnerability to the threats.

The last updated assessments of EID's drinking water sources were completed in 2018. Our source water is considered most vulnerable to recreation, residential sewer, septic system, and urban runoff activities, which are associated with constituents detected in the water supply. Our source water is also considered most vulnerable to illegal activities, dumping, fertilizer, pesticide and herbicide application, forest activities, and wildfires, although constituents associated with these activities were not detected. Copies of the assessments are available online at [www.eid.org](http://www.eid.org) in our Document Library or at the State Water Resources Control Board, Division of Drinking Water, Sacramento District Office, 1001 I Street, 17th Floor, Sacramento, CA 95814. To view them, contact Ali Rezvani, Sacramento District Engineer, at 916-445-5285, or Radenko Odzakovic, EID Drinking Water Operations Division Manager, at 530-642-4060.

## Testing the water

To help ensure safe water is delivered to our customers, EID's water quality monitoring program includes taking samples of raw and treated water throughout the year from many locations in the District's service area. Analyses cover more than 100 different constituents. Analysis of the water is performed at state-certified commercial labs. The State of California may grant monitoring waivers for contaminants when historical monitoring results are less than the Maximum Contaminant Level. As a result, some of our data, although representative, may be more than a year old. The tables on page four and five list all constituents that were detected in 2021 under our monitoring and testing program.

The information shows EID meets or exceeds all state and federal drinking water standards. When available, the data reported reflects the treated water supply.

## A Note for Sensitive Populations

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. EID is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, test methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline, or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## Lead in Schools

In January 2017, the State Water Resources Control Board, Division of Drinking Water amended public water system domestic water supply permits to require for lead monitoring and lead sample result interpretation at K–12 schools served by the water system that have submitted a written request for lead sampling related assistance. In October 2017, the Governor approved AB 746 amending the Health and Safety Code (HSC) §116277. The new law requires Community Water Systems serving public school sites of a local education agency with buildings constructed before January 1, 2010 to test for lead in the potable water system of the school site before July 1, 2019. Please be advised there are no public schools served by EID in your service area.

## Questions?

For more information from EID about this report, contact Radenko Odzakovic, EID Drinking Water Operations Division Manager, at 530-642-4060.

For information from the State Water Resources Control Board, Division of Drinking Water, contact Ali Rezvani, Sacramento District Engineer, at 916-445-5285.

Safe Drinking Water Hotline: 1-800-426-4791

**The following definitions help explain information in the tables on the following pages.**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHG or MCLGs as is economically and technologically feasible. Secondary MCLs (SMCL) are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (EPA).

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for the control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standard (PDWS):** MCL, MRDLs and treatment techniques (TTs) for contaminants that affect health, along with their monitoring and reporting requirements.

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. The California Environmental Protection Agency sets PHGs.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Turbidity:** Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.

## Strawberry Water System - Source Water Quality

Primary Standards - Health Based (units)	Primary MCL	PHG (MCLG)	Highest Single Measurement	Lowest Monthly Percentage of Samples Meeting Limits	MCL Violation?	Most Recent Sampling Date	Typical Source of Constituent
Turbidity - Highest single measurement of the Treated Surface Water (NTU)	TT = 1.0	NA	0.07	NA	No	2021	Soil runoff
Turbidity - Lowest Monthly % of the Treated Surface Water Meeting NTU Requirements	TT = 95% of samples ≤ 0.1 NTU	NA	NA	100%	No	2021	Soil runoff
Primary Standards - Health Based (units)	Primary MCL	PHG (MCLG)	Range of Detection	Average Level	MCL Violation?	Most Recent Sampling Date	Typical Source of Constituent
Aluminum (mg/L)	1	0.6	0.12	0.12	No	2021	Erosion of natural deposits; residue from some surface water treatment processes
Secondary Standards - Aesthetic (units)	Secondary MCL	PHG (MCLG)	Range of Detection	Average Level	MCL Violation?	Most Recent Sampling Date	Typical Source of Constituent
Aluminum (µ/L)	200	NA	120	120	No	2021	Erosion of natural deposits; residue from some surface water treatment processes
Chloride (mg/L)	500	NA	3	3	No	2021	Runoff/leaching from natural deposits; seawater influence
Color (Units)	15	NA	5	5	No	2021	Naturally-occurring organic materials
Corrosivity (A.I.)	Non-corrosive	NA	10	10	No	2021	Natural or industrially-influenced balance of hydrogen, carbon and oxygen in the water; affected by temperature and other factors
Odor (Units)	3	NA	1	1	No	2021	Naturally-occurring organic materials
Specific Conductance (µmhos/cm)	1600	NA	31	31	No	2021	Substances that form ions when in water; seawater influence
Total Dissolved Solids (mg/L)	1000	NA	25	25	No	2021	Runoff/leaching from natural deposits
Other Parameters (units)	Notification Level	PHG (MCLG)	Range of Detection	Average Level	MCL Violation?	Most Recent Sampling Date	Typical Source of Constituent
Alkalinity (mg/L)	Unregulated	NA	9	9	NA	2021	No Known Typical Source of Constituent
Bicarbonate (mg/L)	Unregulated	NA	9	9	NA	2021	
Calcium (mg/L)	Unregulated	NA	1	1	NA	2021	
Hardness as CaCO <sub>3</sub> (mg/L)	Unregulated	NA	4	4	NA	2021	
Hardness as CaCO <sub>3</sub> (grains/gal)	Unregulated	NA	0.23	0.23	NA	2021	
Magnesium (mg/L)	Unregulated	NA	0.17	0.17	NA	2021	
pH (pH units)	Unregulated	NA	8.5	8.5	NA	2021	
Sodium (mg/L)	Unregulated	NA	5	5	NA	2021	

### KEY

**NA**=not applicable  
**ND**=not detected  
**NR**=not reportable  
**NTU**=nephelometric turbidity unit (measure of clarity)  
**mg/L**=milligrams/liter  
**µg/L**=micrograms/liter  
**µmho/cm**=micromhos per centimeter

Units		Equivalence
mg/L – milligrams per liter	ppm – parts per million	1 second in 11.5 days
µg/L – micrograms per liter	ppb – parts per billion	1 second in nearly 32 years
ng/L – nanograms per liter	ppt – parts per trillion	1 second in nearly 32,000 years
pg/L – picograms per liter	ppq – parts per quadrillion	1 second in nearly 32,000,000 years



## Strawberry Water System - Distribution System Water Quality

Disinfection Byproducts and Disinfectant Residuals (units)	Primary MCL (MRDL)	PHG (MRDLG)	Range of Detection	Highest Running Annual Average (RAA)	MCL Violation?	Most Recent Sampling Date	Typical Source of Constituent	
Chlorine [as Cl <sub>2</sub> ] (mg/L)	(4.0)	(4)	0.13-0.48	0.32	No	2021	Drinking water disinfectant added for treatment	
HAA5 [Total of five Haloacetic Acids] (µg/L)	60	NA	13-130	42 <sup>1</sup>	No	2021	Byproduct of drinking water disinfection	
TTHMs [Total of four Trihalomethanes] (µg/L)	80	NA	21-77	47 <sup>1</sup>	No	2021	Byproduct of drinking water disinfection	
Inorganic Constituents (units)	Action Level	PHG (MCLG)	Sample Data	90th % Level	MCL Violation?	Most Recent Sampling Date	Typical Source of Constituent	Number of Schools Requesting Lead Sampling
Copper (mg/L)[at the tap]	1.3	0.3	None of the 7 samples collected exceeded the action level	0.1	No	2020	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	NA
Lead (µg/L)[at the tap]	15	0.2	None of the 7 samples collected exceeded the action level	<5.0	No	2020	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	0

<sup>1</sup> Highest Locational Running Annual Average (LRAA).

## Get Involved

The El Dorado Irrigation District Board of Directors meetings are open to the public and are held on the second and fourth Mondays of each month. Meetings begin at 9:00 A.M. in the Placerville headquarters building at 2890 Mosquito Road. Go to the District website at [www.eid.org](http://www.eid.org) to learn more.

The information provided in this report is required by law to be issued to every water user. Property owners: please share this information with your tenants.



Water for the Strawberry service area is diverted from the upper South Fork American River



In accordance with the Americans with Disabilities Act and California law, it is the policy of the El Dorado Irrigation District to offer its public programs, services and meetings in a manner that is readily accessible to everyone, including individuals with disabilities. If you are a person with a disability and require information or materials in an appropriate alternative format; or if you require any other accommodation, please contact the ADA Coordinator at the number or address below at least 72 hours prior to the meeting or when you desire

to receive services. Advance notification within this guideline will enable the District to make reasonable arrangements to ensure accessibility. The District ADA Coordinator can be reached by phone at (530) 642-4045 or e-mail at [adacoordinator@eid.org](mailto:adacoordinator@eid.org).