

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certific/drinkingwater/CCR.shtml)

| | |
|----------------------|-----------------------------------------|
| Water System Name: | ONEILL VINTNERS & DISTILLERS |
| Water System Number: | 1000411 |

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 4-19-21 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

| | | | |
|---------------|---------------|------------------------|----------------------|
| Certified By: | Name: | <i>Joe A. Pichler</i> | |
| | Signature: | <i>Joe A. Pichler</i> | |
| | Title: | <i>System Operator</i> | |
| | Phone Number: | <i>(579) 638-3544</i> | Date: <i>4-19-21</i> |

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at <http://> _____
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places (attach a list of locations) *All Break areas*
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2020 Consumer Confidence Report

Water System Name: ONEILL VINTNERS & DISTILLERS

Report Date: April 2021

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 source(s): Well 01- Raw and Well 03 - Raw

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held. Information regarding public water system will posted by time clocks and break rooms.

For more information about this report, or any questions relating to your drinking water, please call (559) 638 - 3544 ext 210 and ask for Joe Pulido.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

| Microbiological Contaminants (complete if bacteria detected) | Highest No. of Detections | No. of Months in Violation | MCL | MCLG | Typical Sources of Contaminant |
|-----------------------------------------------------------------|---------------------------|----------------------------|----------------------------------------|------|---------------------------------------|
| Total Coliform Bacteria | 1/mo. (2020) | 0 | no more than 1 positive monthly sample | 0 | Naturally present in the environment. |

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

| Lead and Copper (complete if lead or copper detected in last sample set) | Sample Date | No. of Samples | 90th percentile level detected | No. Sites Exceeding AL | AL | PHG | Typical Sources of Contaminant |
|-----------------------------------------------------------------------------|-------------|----------------|--------------------------------|------------------------|-----|-----|-----------------------------------------------------------------------------------------------------------------|
| Copper (mg/L) | (2020) | 5 | 0.08 | 0 | 1.3 | .3 | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Sources of Contaminant |
|--------------------------------------------------|-------------|------------------------|---------------------|------|------------|----------------------------------------------------------------------------------------------------------------------|
| Sodium (mg/L) | (2014) | 26 | n/a | none | none | Salt present in the water and is generally naturally occurring |
| Hardness (mg/L) | (2014) | 121 | n/a | none | none | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

| Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD | | | | | | |
|-----------------------------------------------------------------------------------|--------------------|---------------------------------------|--------------------------------|-----------------------|-----------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Sources of Contaminant |
| Arsenic (ug/L) | (2018 - 2019) | 3 | 2 - 3 | 10 | 0.004 | Erosion of natural deposits; runoff from orchards, glass and electronics production wastes |
| Barium (mg/L) | (2018 - 2019) | 0.17 | 0.16 - 0.17 | 1 | 2 | Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits |
| Hexavalent Chromium (ug/L) | (2014) | 1.7 | 1.6 - 1.8 | | 0.02 | Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits. |
| Nitrate as N (mg/L) | (2020) | 3.1 | 2.9 - 3.5 | 10 | 10 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits |
| Nitrate + Nitrite as N (mg/L) | (2014) | 3.3 | n/a | 10 | 10 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits |
| Gross Alpha (pCi/L) | (2019 - 2020) | 4.59 | 4.04 - 5.14 | 15 | (0) | Erosion of natural deposits. |
| Uranium (pCi/L) | (2019 - 2020) | 3.9 | 3.89 - 3.90 | 20 | 0.43 | Erosion of natural deposits |
| 1,2,3-Trichloropropane (1,2,3-TCP) (ug/L) | (2020) | 0.01 | 0.005 - 0.014 | 0.005 | 0.0007 | Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides. |

| Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD | | | | | | |
|-------------------------------------------------------------------------------------|--------------------|---------------------------------------|--------------------------------|------------|-----------------------|-------------------------------------------------------------|
| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Sources of Contaminant |
| Chloride (mg/L) | (2014) | 13 | n/a | 500 | n/a | Runoff/leaching from natural deposits; seawater influence |
| Specific Conductance (umhos/cm) | (2014) | 378 | n/a | 1600 | n/a | Substances that form ions when in water; seawater influence |
| Sulfate (mg/L) | (2014) | 12 | n/a | 500 | n/a | Runoff/leaching from natural deposits; industrial wastes |
| Total Dissolved Solids (mg/L) | (2014) | 240 | n/a | 1000 | n/a | Runoff/leaching from natural deposits |
| Turbidity (NTU) | (2012 - 2014) | 0.5 | ND - 1.0 | 5 | n/a | Soil runoff |

| Table 6 - DETECTION OF UNREGULATED CONTAMINANTS | | | | | |
|--------------------------------------------------------------|--------------------|-----------------------------------|--------------------------------|-------------------------------|--------------------------------------------------------------------------------|
| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | Notification Level | Typical Sources of Contaminant |
| Vanadium (mg/L) | (2018 - 2019) | 0.021 | 0.020 - 0.022 | 0.05 | Vanadium exposures resulted in developmental and reproductive effects in rats. |

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL (MRDL) | PHG (MCLG) | Violation | Typical Sources of Contaminant |
|-----------------------------------------------|-------------|------------------------|---------------------|------------|------------|-----------|--------------------------------------------------|
| Total Trihalomethanes (THMs) (ug/L) | (2020) | 4 | 2 - 5 | 80 | n/a | No | By-product of drinking water disinfection |
| Chlorine (mg/L) | (2020) | 1.70 | 0.00 - 2.20 | 4.0 | 4.0 | No | Drinking water disinfectant added for treatment. |
| Haloacetic Acids (five) (ug/L) | (2020) | 0.67 | ND - 1 | 60 | n/a | No | By-product of drinking water disinfection |

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *O`Neill Beverages Co. LLC* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

| VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT | | | | |
|------------------------------------------------------------------------|-------------|----------|----------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Violation | Explanation | Duration | Actions Taken To Correct the Violation | Health Effects Language |
| Total Coliform Bacteria | | | | Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments. |
| 1,2,3-Trichloropropane (1,2,3-TCP) | | | | Some people who use water containing 1,2,3-trichloropropane in excess of the action level over many years may have an increased risk of getting cancer, based on studies in laboratory animals. |

2020 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 01 and WELL 03 of the O'NEILL VINTNERS & DISTILLERS water system in March, 2003.

Well 01- Raw - is considered most vulnerable to the following activities not associated with any detected contaminants:

Septic systems - low density [<1 /acre]
Wells - Agricultural/ Irrigation

Well 03 - Raw - is considered most vulnerable to the following activities not associated with any detected contaminants:

Septic systems - low density [<1 /acre]
Wells - Agricultural/ Irrigation

Discussion of Vulnerability

There have been no primary contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source. The primary source of potential contamination could come from septic systems in the area.

Acquiring Information

A copy of the complete assessment may be viewed at:

Fresno County Department of Community Health Environmental Health
1221 Fulton Mall
PO Box 11867
Fresno, Ca 93775

You may request a summary of the assessment be sent to you by contacting:

Jim Brunton
Supervising Environmental Health Analysts
(559) 445-3357
(559) 445-3379 (fax)

O'Neill Beverages Co. LLC
Analytical Results By FGL - 2020

| MICROBIOLOGICAL CONTAMINANTS | | | | | | | | | |
|-------------------------------------|--------------|-------|------|--------|-----|------------|--------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Total Coliform Bacteria | | | 0 | 5% | n/a | | | 0 | 1 - 1 |
| Boiler Room | VI 2049565-1 | | | | | 2020-12-04 | Absent | | |
| Boiler Room | VI 2048840-1 | | | | | 2020-11-09 | <1.0 | | |
| Boiler Room | VI 2048556-1 | | | | | 2020-10-29 | Absent | | |
| Boiler Room | VI 2047169-1 | | | | | 2020-09-15 | <1.0 | | |
| Boiler Room | VI 2045422-1 | | | | | 2020-07-15 | <1.0 | | |
| Boiler Room | VI 2044341-1 | | | | | 2020-06-09 | <1.0 | | |
| Boiler Room | VI 2043518-1 | | | | | 2020-05-14 | Absent | | |
| Boiler Room | VI 2042747-1 | | | | | 2020-04-22 | <1.0 | | |
| Boiler Room | VI 2041793-1 | | | | | 2020-03-10 | Absent | | |
| Boiler Room | VI 2041412-3 | | | | | 2020-02-27 | Absent | | |
| Boiler Room | VI 2040695-5 | | | | | 2020-01-31 | <1.0 | | |
| Boiler Room | VI 2040603-1 | | | | | 2020-01-29 | 1 | | |
| Lab Sink | VI 2041412-4 | | | | | 2020-02-27 | Absent | | |
| Lab Sink | VI 2040695-4 | | | | | 2020-01-31 | <1.0 | | |
| Main Office Breakroom | VI 2041412-5 | | | | | 2020-02-27 | Absent | | |
| Site # Boiler Room | VI 2046542-1 | | | | | 2020-08-24 | <1.0 | | |
| Site #2 - Upstairs Breakroom | VI 2041412-2 | | | | | 2020-02-27 | Absent | | |
| Spirits Lab | VI 2041412-1 | | | | | 2020-02-27 | Absent | | |
| Upstairs Breakroom | VI 2040695-3 | | | | | 2020-01-31 | <1.0 | | |

| LEAD AND COPPER RULE | | | | | | | | | |
|-----------------------------|--------------|-------|------|--------|-----|------------|--------|-----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | 90th Percentile | # Samples |
| Copper | | mg/L | | 1.3 | .3 | | | 0.075 | 5 |
| Boiler Room | VI 2045615-2 | mg/L | | | | 2020-07-23 | ND | | |
| Front Office Sink | VI 2045615-5 | mg/L | | | | 2020-07-23 | 0.15 | | |
| Lab Sink | VI 2045615-1 | mg/L | | | | 2020-07-23 | ND | | |
| Processing Room | VI 2045615-4 | mg/L | | | | 2020-07-23 | ND | | |
| Upstairs Breakroom | VI 2045615-3 | mg/L | | | | 2020-07-23 | ND | | |

| SAMPLING RESULTS FOR SODIUM AND HARDNESS | | | | | | | | | |
|-------------------------------------------------|--------------|-------|------|--------|------|------------|--------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Sodium | | mg/L | | none | none | | | 26 | 26 - 26 |
| Well 03 - Raw | VI 1440279-1 | mg/L | | | | 2014-01-29 | 26 | | |
| Hardness | | mg/L | | none | none | | | 121 | 121 - 121 |
| Well 03 - Raw | VI 1440279-1 | mg/L | | | | 2014-01-29 | 121 | | |

| PRIMARY DRINKING WATER STANDARDS (PDWS) | | | | | | | | | |
|------------------------------------------------|--------------|-------|------|--------|-------|------------|--------|----------------|-------------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Arsenic | | ug/L | | 10 | 0.004 | | | 3 | 2 - 3 |
| Well 01- Raw | VI 1941890-1 | ug/L | | | | 2019-04-29 | 2 | | |
| Well 03 - Raw | VI 1841422-1 | ug/L | | | | 2018-03-27 | 3 | | |
| Barium | | mg/L | 2 | 1 | 2 | | | 0.17 | 0.16 - 0.17 |
| Well 01- Raw | VI 1941890-1 | mg/L | | | | 2019-04-29 | 0.17 | | |
| Well 03 - Raw | VI 1841422-1 | mg/L | | | | 2018-03-27 | 0.16 | | |
| Hexavalent Chromium | | ug/L | | | 0.02 | | | 1.7 | 1.6 - 1.8 |
| Well 01- Raw | VI 1444595-1 | ug/L | | | | 2014-12-04 | 1.6 | | |
| Well 03 - Raw | VI 1444595-2 | ug/L | | | | 2014-12-04 | 1.8 | | |
| Nitrate as N | | mg/L | | 10 | 10 | | | 3.1 | 2.9 - 3.5 |
| Well 01- Raw | VI 2044341-2 | mg/L | | | | 2020-06-09 | 3.5 | | |

| | | | | | | | | | |
|-------------------------------------------|--------------|-------|--|-------|--------|------------|-------|-------|---------------|
| Well 01- Raw | VI 2042749-1 | mg/L | | | | 2020-04-22 | 2.9 | | |
| Well 03 - Raw | VI 2042748-1 | mg/L | | | | 2020-04-22 | 3.0 | | |
| Nitrate + Nitrite as N | | mg/L | | 10 | 10 | | | 3.3 | 3.3 - 3.3 |
| Well 03 - Raw | VI 1440279-1 | mg/L | | | | 2014-01-29 | 3.3 | | |
| Gross Alpha | | pCi/L | | 15 | (0) | | | 4.59 | 4.04 - 5.14 |
| Well 01- Raw | VI 1941890-1 | pCi/L | | | | 2019-04-29 | 4.04 | | |
| Well 03 - Raw | VI 2040658-1 | pCi/L | | | | 2020-01-29 | 5.14 | | |
| Uranium | | pCi/L | | 20 | 0.43 | | | 3.90 | 3.89 - 3.90 |
| Well 01- Raw | VI 1941890-1 | pCi/L | | | | 2019-04-29 | 3.90 | | |
| Well 03 - Raw | VI 2040658-1 | pCi/L | | | | 2020-01-29 | 3.89 | | |
| 1,2,3-Trichloropropane (1,2,3-TCP) | | ug/L | | 0.005 | 0.0007 | | | 0.010 | 0.005 - 0.014 |
| Well 01- Raw | VI 2048845-1 | ug/L | | | | 2020-11-09 | 0.012 | | |
| Well 01- Raw | VI 2046544-1 | ug/L | | | | 2020-08-24 | 0.014 | | |
| Well 01- Raw | VI 2043527-1 | ug/L | | | | 2020-05-14 | 0.01 | | |
| Well 01- Raw | VI 2041073-1 | ug/L | | | | 2020-02-14 | 0.008 | | |
| Well 03 - Raw | VI 2048845-2 | ug/L | | | | 2020-11-09 | 0.005 | | |
| Well 03 - Raw | VI 2046544-2 | ug/L | | | | 2020-08-24 | 0.012 | | |
| Well 03 - Raw | VI 2043527-2 | ug/L | | | | 2020-05-14 | 0.011 | | |
| Well 03 - Raw | VI 2041073-2 | ug/L | | | | 2020-02-14 | 0.009 | | |

SECONDARY DRINKING WATER STANDARDS (SDWS)

| | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
|-------------------------------|--------------|----------|--------|-----|------------|--------|----------------|-----------|
| Chloride | mg/L | | 500 | n/a | | | 13 | 13 - 13 |
| Well 03 - Raw | VI 1440279-1 | mg/L | | | 2014-01-29 | 13 | | |
| Specific Conductance | umhos/cm | | 1600 | n/a | | | 378 | 378 - 378 |
| Well 03 - Raw | VI 1440279-1 | umhos/cm | | | 2014-01-29 | 378 | | |
| Sulfate | mg/L | | 500 | n/a | | | 12 | 12 - 12 |
| Well 03 - Raw | VI 1440279-1 | mg/L | | | 2014-01-29 | 12 | | |
| Total Dissolved Solids | mg/L | | 1000 | n/a | | | 240 | 240 - 240 |
| Well 03 - Raw | VI 1440279-1 | mg/L | | | 2014-01-29 | 240 | | |
| Turbidity | NTU | | 5 | n/a | | | 0.5 | ND - 1.0 |
| Well 01- Raw | VI 1240282-1 | NTU | | | 2012-02-09 | 1.0 | | |
| Well 03 - Raw | VI 1440279-1 | NTU | | | 2014-01-29 | ND | | |

UNREGULATED CONTAMINANTS

| | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
|-----------------|--------------|------|--------|-----|------------|--------|----------------|---------------|
| Vanadium | mg/L | | NS | n/a | | | 0.021 | 0.020 - 0.022 |
| Well 01- Raw | VI 1941890-1 | mg/L | | | 2019-04-29 | 0.020 | | |
| Well 03 - Raw | VI 1841422-1 | mg/L | | | 2018-03-27 | 0.022 | | |

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

| | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
|----------------------------------------|--------------|------|--------|-----|------------|--------|----------------|-------------|
| Total Trihalomethanes (TTHMs) | ug/L | | 80 | n/a | | | 4 | 2 - 5 |
| DBP Smply Pt - W-2 East End Of | VI 2049566-2 | ug/L | | | 2020-12-04 | 4 | | |
| DBP Smply Pt - W-2 East End Of | VI 2044342-2 | ug/L | | | 2020-06-09 | 4 | | |
| DBP Smply Pt - W-2 East End Of | VI 2042164-2 | ug/L | | | 2020-03-25 | 5 | | |
| Average DBP Smply Pt - W-2 East End Of | | | | | | | 4.33 | |
| DBP Smply Pt -W-1-North Center | VI 2049566-1 | ug/L | | | 2020-12-04 | 2 | | |
| DBP Smply Pt -W-1-North Center | VI 2044342-1 | ug/L | | | 2020-06-09 | 3 | | |
| DBP Smply Pt -W-1-North Center | VI 2042164-1 | ug/L | | | 2020-03-25 | 3 | | |
| Average DBP Smply Pt -W-1-North Center | | | | | | | 2.67 | |
| Chlorine | mg/L | | 4.0 | 4.0 | | | 1.70 | 0.00 - 2.20 |
| Boiler Room | VI 2049565-1 | mg/L | | | 2020-12-04 | 0.40 | | |
| Boiler Room | VI 2048840-1 | mg/L | | | 2020-11-09 | 1.47 | | |
| Boiler Room | VI 2048556-1 | mg/L | | | 2020-10-29 | 0.28 | | |
| Boiler Room | VI 2047169-1 | mg/L | | | 2020-09-15 | .54 | | |

O'Neill Beverages Co. LLC CCR Login Linkage - 2020

| FGL Code | Lab ID | Date_Sampled | Method | Description | Property |
|-----------------|--------------|--------------|---------------|-------------------------------|-------------------------------|
| BOILER RM | VI 2040603-1 | 2020-01-29 | Coliform | Boiler Room | Monthly Water Monitoring |
| | VI 2040603-1 | 2020-01-29 | Field Test | Boiler Room | Monthly Water Monitoring |
| CuPb-ss02 | VI 2040695-5 | 2020-01-31 | Coliform | Boiler Room | O'NEILL VINTNERS & DISTILLERS |
| | VI 2040695-5 | 2020-01-31 | Field Test | Boiler Room | O'NEILL VINTNERS & DISTILLERS |
| BOILER RM | VI 2041412-3 | 2020-02-27 | Field Test | Boiler Room | Bacteriological Monitoring |
| | VI 2041412-3 | 2020-02-27 | Coliform | Boiler Room | Bacteriological Monitoring |
| | VI 2041793-1 | 2020-03-10 | Coliform | Boiler Room | Montly Water Monitoring |
| | VI 2041793-1 | 2020-03-10 | Field Test | Boiler Room | Montly Water Monitoring |
| | VI 2042747-1 | 2020-04-22 | Field Test | Boiler Room | Monthly Water Monitoring |
| | VI 2042747-1 | 2020-04-22 | Coliform | Boiler Room | Monthly Water Monitoring |
| | VI 2043518-1 | 2020-05-14 | Coliform | Boiler Room | Site # |
| | VI 2043518-1 | 2020-05-14 | Field Test | Boiler Room | Site # |
| CuPb-ss02 | VI 2044341-1 | 2020-06-09 | Coliform | Boiler Room | Site #Boiler Room |
| | VI 2044341-1 | 2020-06-09 | Field Test | Boiler Room | Site #Boiler Room |
| BOILER RM | VI 2045422-1 | 2020-07-15 | Field Test | Boiler Room | Monthly Water Monitoring |
| | VI 2045422-1 | 2020-07-15 | Coliform | Boiler Room | Monthly Water Monitoring |
| CuPb-ss02 | VI 2045615-2 | 2020-07-23 | Metals, Total | Boiler Room | Copper & Lead Monitoring |
| | VI 2047169-1 | 2020-09-15 | Coliform | Boiler Room | Site # |
| | VI 2047169-1 | 2020-09-15 | Field Test | Boiler Room | Site # |
| | VI 2048556-1 | 2020-10-29 | Field Test | Boiler Room | Monthly Water Monitoring |
| | VI 2048556-1 | 2020-10-29 | Coliform | Boiler Room | Monthly Water Monitoring |
| BOILER RM | VI 2048840-1 | 2020-11-09 | Coliform | Boiler Room | Monthly Water Monitoring |
| | VI 2048840-1 | 2020-11-09 | Field Test | Boiler Room | Monthly Water Monitoring |
| | VI 2049565-1 | 2020-12-04 | Coliform | Boiler Room | Site # Boiler Room |
| | VI 2049565-1 | 2020-12-04 | Field Test | Boiler Room | Site # Boiler Room |
| DBP-ss02 | VI 2042164-2 | 2020-03-25 | EPA 552.2 | DBP Smpg Pt - W-2 East End Of | DBP Monitoring |
| | VI 2042164-2 | 2020-03-25 | EPA 551.1 | DBP Smpg Pt - W-2 East End Of | DBP Monitoring |
| | VI 2044342-2 | 2020-06-09 | EPA 551.1 | DBP Smpg Pt - W-2 East End Of | DBP Monitoring |
| | VI 2044342-2 | 2020-06-09 | EPA 552.2 | DBP Smpg Pt - W-2 East End Of | DBP Monitoring |
| | VI 2049566-2 | 2020-12-04 | EPA 551.1 | DBP Smpg Pt - W-2 East End Of | DBP Monitoring |
| | VI 2049566-2 | 2020-12-04 | EPA 552.2 | DBP Smpg Pt - W-2 East End Of | DBP Monitoring |
| DBP-ss01 | VI 2042164-1 | 2020-03-25 | EPA 551.1 | DBP Smpg Pt -W-1-North Center | DBP Monitoring |
| | VI 2042164-1 | 2020-03-25 | EPA 552.2 | DBP Smpg Pt -W-1-North Center | DBP Monitoring |
| | VI 2044342-1 | 2020-06-09 | EPA 552.2 | DBP Smpg Pt -W-1-North Center | DBP Monitoring |
| | VI 2044342-1 | 2020-06-09 | EPA 551.1 | DBP Smpg Pt -W-1-North Center | DBP Monitoring |
| | VI 2049566-1 | 2020-12-04 | EPA 551.1 | DBP Smpg Pt -W-1-North Center | DBP Monitoring |
| | VI 2049566-1 | 2020-12-04 | EPA 552.2 | DBP Smpg Pt -W-1-North Center | DBP Monitoring |
| CuPb-ss05 | VI 2045615-5 | 2020-07-23 | Metals, Total | Front Office Sink | Copper & Lead Monitoring |
| CuPb-ss01 | VI 2040695-4 | 2020-01-31 | Coliform | Lab Sink | O'NEILL VINTNERS & DISTILLERS |
| | VI 2040695-4 | 2020-01-31 | Field Test | Lab Sink | O'NEILL VINTNERS & DISTILLERS |
| | VI 2041412-4 | 2020-02-27 | Coliform | Lab Sink | Bacteriological Monitoring |
| | VI 2041412-4 | 2020-02-27 | Field Test | Lab Sink | Bacteriological Monitoring |
| | VI 2045615-1 | 2020-07-23 | Metals, Total | Lab Sink | Copper & Lead Monitoring |
| OFFS BREAKROOM | VI 2041412-5 | 2020-02-27 | Coliform | Main Office Breakroom | Bacteriological Monitoring |
| | VI 2041412-5 | 2020-02-27 | Field Test | Main Office Breakroom | Bacteriological Monitoring |
| CuPb-ss04 | VI 2045615-4 | 2020-07-23 | Metals, Total | Processing Room | Copper & Lead Monitoring |
| Site # Boiler R | VI 2046542-1 | 2020-08-24 | Field Test | Site # Boiler Room | Monthly Water Monitoring |
| | VI 2046542-1 | 2020-08-24 | Coliform | Site # Boiler Room | Monthly Water Monitoring |
| Bacti-ss02 | VI 2041412-2 | 2020-02-27 | Coliform | Site #2 - Upstairs Breakroom | Bacteriological Monitoring |
| | VI 2041412-2 | 2020-02-27 | Field Test | Site #2 - Upstairs Breakroom | Bacteriological Monitoring |
| SPIRITS LABORAT | VI 2041412-1 | 2020-02-27 | Coliform | Spirits Lab | Bacteriological Monitoring |
| | VI 2041412-1 | 2020-02-27 | Field Test | Spirits Lab | Bacteriological Monitoring |
| CuPb-ss03 | VI 2040695-3 | 2020-01-31 | Coliform | Upstairs Breakroom | O'NEILL VINTNERS & DISTILLERS |
| | VI 2040695-3 | 2020-01-31 | Field Test | Upstairs Breakroom | O'NEILL VINTNERS & DISTILLERS |
| | VI 2045615-3 | 2020-07-23 | Metals, Total | Upstairs Breakroom | Copper & Lead Monitoring |

| | | | | | |
|---------|--------------|------------|-----------------|---------------|-------------------------------|
| | VI 1240282-1 | 2012-02-09 | Wet Chemistry | Well 01- Raw | |
| Well #1 | VI 1444595-1 | 2014-12-04 | Wet Chemistry | Well 01- Raw | Cr+6 Monitoring |
| WELL01 | VI 1941890-1 | 2019-04-29 | Radio Chemistry | Well 01- Raw | Well 01 - Water Quality |
| | VI 1941890-1 | 2019-04-29 | Metals, Total | Well 01- Raw | Well 01 - Water Quality |
| | VI 2041073-1 | 2020-02-14 | SRL 524M-TCP | Well 01- Raw | TCP Monitoring |
| | VI 2042749-1 | 2020-04-22 | Wet Chemistry | Well 01- Raw | Well 01 - Water Quality |
| | VI 2043527-1 | 2020-05-14 | SRL 524M-TCP | Well 01- Raw | TCP Monitoring |
| | VI 2044341-2 | 2020-06-09 | Wet Chemistry | Well 01- Raw | Annual Nitrate Monitoring |
| | VI 2046544-1 | 2020-08-24 | SRL 524M-TCP | Well 01- Raw | TCP Monitoring |
| | VI 2048845-1 | 2020-11-09 | SRL 524M-TCP | Well 01- Raw | TCP Monitoring |
| Well #3 | VI 1440279-1 | 2014-01-29 | General Mineral | Well 03 - Raw | Water Quality Monitoring |
| | VI 1440279-1 | 2014-01-29 | Wet Chemistry | Well 03 - Raw | Water Quality Monitoring |
| | VI 1444595-2 | 2014-12-04 | Wet Chemistry | Well 03 - Raw | Cr+6 Monitoring |
| WELL03 | VI 1841422-1 | 2018-03-27 | Metals, Total | Well 03 - Raw | Well 03 - Water Quality |
| | VI 2040658-1 | 2020-01-29 | Radio Chemistry | Well 03 - Raw | O'NEILL VINTNERS & DISTILLERS |
| | VI 2040658-1 | 2020-01-29 | Metals, Total | Well 03 - Raw | O'NEILL VINTNERS & DISTILLERS |
| | VI 2041073-2 | 2020-02-14 | SRL 524M-TCP | Well 03 - Raw | TCP Monitoring |
| | VI 2042748-1 | 2020-04-22 | Wet Chemistry | Well 03 - Raw | Well 03 - Water Quality |
| | VI 2043527-2 | 2020-05-14 | SRL 524M-TCP | Well 03 - Raw | TCP Monitoring |
| | VI 2046544-2 | 2020-08-24 | SRL 524M-TCP | Well 03 - Raw | TCP Monitoring |
| | VI 2048845-2 | 2020-11-09 | SRL 524M-TCP | Well 03 - Raw | TCP Monitoring |