

APPENDIX B: eCCR Certification Form (Suggested Format)

Consumer Confidence Report Certification Form

(To be submitted with a copy of the CCR)

Water System Name:	ONEILL Vintners & Distillers
Water System Number:	CA1000411

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 5/31/2023 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by:

Name: <u>Angel Contreras</u>	Title: <u>Manager of EHS</u>
Signature: <u>Angel Contreras</u>	Date: <u>5/31/2023</u>
Phone number: <u>(559) 638-3544</u>	blank

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- ☐ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- ☐ CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- ☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - ☐ Posting the CCR at the following URL: www._____
 - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - ☒ Posted the CCR in public places (attach a list of locations)
Time clocks + Break areas

- ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
- ☐ Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
- ☐ Other (attach a list of other methods used)
- ☐ *For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following URL: www._____
- ☐ *For privately-owned utilities:* Delivered the CCR to the California Public Utilities Commission

Consumer Confidence Report Electronic Delivery Certification

Water systems utilizing electronic distribution methods for CCR delivery must complete this page by checking all items that apply and fill-in where appropriate.

- ☐ Water system mailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available website where it can be viewed (attach a copy of the mailed CCR notification). URL: www._____
- ☐ Water system emailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed (attach a copy of the emailed CCR notification). URL: www._____
- ☐ Water system emailed the CCR as an electronic file email attachment.
- ☐ Water system emailed the CCR text and tables inserted or embedded into the body of an email, not as an attachment (attach a copy of the emailed CCR).
- ☐ *Requires prior DDW review and approval.* Water system utilized other electronic delivery method that meets the direct delivery requirement.

Provide a brief description of the water system's electronic delivery procedures and include how the water system ensures delivery to customers unable to receive electronic delivery.

N/A

*This form is provided as a convenience and may be used to meet the certification
requirement of
section 64483(c) of the California Code of Regulations.*

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	ONEILL VINTNERS & DISTILLERS
Water System Number:	CA1000411

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 5/31/2023 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Angel Contreras	
	Signature:	<i>Angel Contreras</i>	
	Title:	Manager of EHS	
	Phone Number:	(559) 638-3544	Date: 5/31/2023

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

☒ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> _____
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☒ Other (attach a list of other methods used) *Time clocks + Break Areas*

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2022 Consumer Confidence Report

Water System Name: ONEILL VINTNERS & DISTILLERS

Report Date: May 2023

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2022.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 source(s): WELL 01- Raw and WELL 03 - Raw
and from 1 treated location(s): Brandy Lab

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held. Information regarding public water system will posted by time clocks and break rooms.

For more information about this report, or any questions relating to your drinking water, please call (559) 638 - 3544 ext 210 and ask for Joe Pulido.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2022)	5	0.34	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2014)	26	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2014)	121	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2021 - 2022)	ND	ND - 3	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2021 - 2022)	0.23	0.17 - 0.29	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits

Chromium (ug/L)	(2022)	10	n/a	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Hexavalent Chromium (ug/L)	(2014)	1.7	1.6 - 1.8		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate as N (mg/L)	(2022)	3.5	2.7 - 4.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2014)	3.3	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2019 - 2021)	2.02	ND - 4.04	15	(0)	Erosion of natural deposits.
1,2,3-Trichloropropane (1,2,3-TCP) (ug/L)	(2022)	0.013	ND - 0.023	0.005	0.0007	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.
Uranium (pCi/L)	(2019 - 2020)	3.9	3.89 - 3.90	20	0.43	Erosion of natural deposits

Table 4 - TREATED DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
1,2,3-Trichloropropane (1,2,3-TCP) (ug/L)	(2021)	ND	ND - 0.016	0.005	0.0007	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2014)	13	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2014)	378	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2014)	12	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2014)	240	n/a	1000	n/a	Runoff/leaching from natural deposits

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Vanadium (ug/L)	(2021 - 2022)	14	7 - 21	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2022)	60	ND - 120	80	n/a	No	By-product of drinking water disinfection
Chlorine (mg/L)	(2021)	0.49	.36 - 0.61	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ug/L)	(2022)	1.5	ND - 3	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *O'Neill Beverages Co. LLC* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
1,2,3-Trichloropropane (1,2,3-TCP)				Some people who use water containing 1,2,3-trichloropropane in excess of the action level over many years may have an increased risk of getting cancer, based on studies in laboratory animals.

Total Trihalomethanes (TTHMs)				Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience liver, kidney, or central nervous system problems, and may have an increased risk of getting cancer.
-------------------------------	--	--	--	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

2022 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 01 and WELL 03 of the O'NEILL VINTNERS & DISTILLERS water system in March, 2003.

Discussion of Vulnerability

There have been no primary contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source. The primary source of potential contamination could come from septic systems in the area.

Acquiring Information

A copy of the complete assessment may be viewed at:
Fresno County Department of Community Health Environmental Health
1221 Fulton Mall
PO Box 11867
Fresno, Ca 93775

You may request a summary of the assessment be sent to you by contacting:

Jim Brunton
Supervising Environmental Health Analysts
(559) 445-3357
(559) 445-3379 (fax)

O'Neill Beverages Co. LLC
Analytical Results By FGL - 2022

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		mg/L		1.3	.3			0.34	5
Boiler Room	VI 2245313-2	mg/L				2022-06-28	ND		
Front Office Sink	VI 2245313-5	mg/L				2022-06-28	0.25		
Lab Sink	VI 2245313-1	mg/L				2022-06-28	ND		
Processing Room	VI 2245313-4	mg/L				2022-06-28	ND		
Upstairs Breakroom	VI 2245313-3	mg/L				2022-06-28	0.43		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			26	26 - 26
WELL 03 - Raw	VI 1440279-1	mg/L				2014-01-29	26		
Hardness		mg/L		none	none			121	121 - 121
WELL 03 - Raw	VI 1440279-1	mg/L				2014-01-29	121		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			ND	ND - 3
WELL 01- Raw	VI 2243021-1	ug/L				2022-04-25	ND		
WELL 03 - Raw	VI 2143262-1	ug/L				2021-04-30	3		
Barium		mg/L	2	1	2			0.23	0.17 - 0.29
WELL 01- Raw	VI 2243021-1	mg/L				2022-04-25	0.29		
WELL 03 - Raw	VI 2143262-1	mg/L				2021-04-30	0.17		
Chromium		ug/L	100	50.0	n/a			10	10 - 10
WELL 01- Raw	VI 2243021-1	ug/L				2022-04-25	10		
Hexavalent Chromium		ug/L			0.02			1.7	1.6 - 1.8
WELL 01- Raw	VI 1444595-1	ug/L				2014-12-04	1.6		
WELL 03 - Raw	VI 1444595-2	ug/L				2014-12-04	1.8		
Nitrate as N		mg/L		10	10			3.5	2.7 - 4.7
WELL 01- Raw	VI 2244214-2	mg/L				2022-06-13	2.7		
WELL 01- Raw	VI 2243021-1	mg/L				2022-04-25	4.7		
WELL 03 - Raw	VI 2243020-1	mg/L				2022-04-25	3.1		
Nitrate + Nitrite as N		mg/L		10	10			3.3	3.3 - 3.3
WELL 03 - Raw	VI 1440279-1	mg/L				2014-01-29	3.3		
Gross Alpha		pCi/L		15	(0)			2.020	ND - 4.04
WELL 01- Raw	VI 1941890-1	pCi/L				2019-04-29	4.04		
WELL 03 - Raw	VI 2143262-1	pCi/L				2021-04-30	ND		
1,2,3-Trichloropropane (1,2,3-TCP)		ug/L		0.005	0.0007			0.013	ND - 0.023
WELL 01- Raw	VI 2248526-1	ug/L				2022-10-28	0.011		
WELL 01- Raw	VI 2246507-1	ug/L				2022-08-22	ND		
WELL 01- Raw	VI 2243825-1	ug/L				2022-05-26	0.007		
WELL 01- Raw	VI 2240856-1	ug/L				2022-02-10	0.018		
WELL 03 - Raw	VI 2248526-2	ug/L				2022-10-28	0.012		
WELL 03 - Raw	VI 2246507-2	ug/L				2022-08-22	0.015		
WELL 03 - Raw	VI 2243825-2	ug/L				2022-05-26	0.023		
WELL 03 - Raw	VI 2240856-2	ug/L				2022-02-10	0.014		
Uranium		pCi/L		20	0.43			3.90	3.89 - 3.90
WELL 01- Raw	VI 1941890-1	pCi/L				2019-04-29	3.90		
WELL 03 - Raw	VI 2040658-1	pCi/L				2020-01-29	3.89		

TREATED PRIMARY DRINKING WATER STANDARDS (PDWS)	
-------------------------------------------------	--

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
1,2,3-Trichloropropane (1,2,3-TCP)		ug/L		0.005	0.0007			ND	ND - 0.016
Brandy Lab	VI 2147920-1	ug/L				2021-10-06	ND		
Brandy Lab	VI 2147729-1	ug/L				2021-09-29	ND		
Brandy Lab	VI 2147610-1	ug/L				2021-09-24	ND		
Brandy Lab	VI 2147135-1	ug/L				2021-09-08	ND		
Brandy Lab	VI 2146756-1	ug/L				2021-08-25	0.016		
Brandy Lab	VI 2146564-1	ug/L				2021-08-18	0.013		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			13	13 - 13
WELL 03 - Raw	VI 1440279-1	mg/L				2014-01-29	13		
Specific Conductance		umhos/cm		1600	n/a			378	378 - 378
WELL 03 - Raw	VI 1440279-1	umhos/cm				2014-01-29	378		
Sulfate		mg/L		500	n/a			12	12 - 12
WELL 03 - Raw	VI 1440279-1	mg/L				2014-01-29	12		
Total Dissolved Solids		mg/L		1000	n/a			240	240 - 240
WELL 03 - Raw	VI 1440279-1	mg/L				2014-01-29	240		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Vanadium		ug/L		NS	n/a			14	7 - 21
WELL 01- Raw	VI 2243021-1	ug/L				2022-04-25	7		
WELL 03 - Raw	VI 2143262-1	ug/L				2021-04-30	21		

[illegible]

O'Neill Beverages Co. LLC

CCR Login Linkage - 2022

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
BOILER RM	VI 2140637-1	2021-01-27	Field Test	Boiler Room	Monthly Water Monitoring
	VI 2240125-1	2022-01-07	Coliform	Boiler Room	Site #
	VI 2240857-1	2022-02-10	Coliform	Boiler Room	Site #
	VI 2241866-1	2022-04-25	Coliform	Boiler Room	Monthly Water Monitoring
	VI 2243824-1	2022-05-26	Coliform	Boiler Room	Monthly Water Monitoring
	VI 2244214-1	2022-06-13	Coliform	Boiler Room	Site #
CuPb-ss02	VI 2245313-2	2022-06-28	Metals, Total	Boiler Room	Copper & Lead Monitoring
BOILER RM	VI 2248927-1	2022-11-14	Coliform	Boiler Room	Site #
	VI 2249921-1	2022-12-20	Coliform	Boiler Room	Site #
Brandy Lab	VI 2146564-1	2021-08-18	SRL 524M-TCP	Brandy Lab	Bacteriological Monitoring
	VI 2146756-1	2021-08-25	SRL 524M-TCP	Brandy Lab	Bacteriological Monitoring
	VI 2147135-1	2021-09-08	SRL 524M-TCP	Brandy Lab	Bacteriological Monitoring
	VI 2147610-1	2021-09-24	SRL 524M-TCP	Brandy Lab	Bacteriological Monitoring
	VI 2147729-1	2021-09-29	SRL 524M-TCP	Brandy Lab	Bacteriological Monitoring
	VI 2147920-1	2021-10-06	SRL 524M-TCP	Brandy Lab	Bacteriological Monitoring
DBP-ss02	VI 2241838-2	2022-03-17	EPA 552.2	DBP Smpg Pt - W-2 East End Of	DBP Monitoring
	VI 2241838-2	2022-03-17	EPA 551.1	DBP Smpg Pt - W-2 East End Of	DBP Monitoring
	VI 2244604-2	2022-06-23	EPA 552.2	DBP Smpg Pt - W-2 East End Of	DBP Monitoring
	VI 2244604-2	2022-06-23	EPA 551.1	DBP Smpg Pt - W-2 East End Of	DBP Monitoring
DBP-ss01	VI 2241838-1	2022-03-17	EPA 552.2	DBP Smpg Pt -W-1-North Center	DBP Monitoring
	VI 2241838-1	2022-03-17	EPA 551.1	DBP Smpg Pt -W-1-North Center	DBP Monitoring
	VI 2244604-1	2022-06-23	EPA 551.1	DBP Smpg Pt -W-1-North Center	DBP Monitoring
	VI 2244604-1	2022-06-23	EPA 552.2	DBP Smpg Pt -W-1-North Center	DBP Monitoring
CuPb-ss05	VI 2245313-5	2022-06-28	Metals, Total	Front Office Sink	Copper & Lead Monitoring
CuPb-ss01	VI 2245313-1	2022-06-28	Metals, Total	Lab Sink	Copper & Lead Monitoring
CuPb-ss04	VI 2245313-4	2022-06-28	Metals, Total	Processing Room	Copper & Lead Monitoring
Bacti-ss02	VI 2141401-1	2021-02-24	Field Test	Site #2 - Upstairs Breakroom	Monthly Water Monitoring
	VI 2142289-1	2021-03-24	Field Test	Site #2 - Upstairs Breakroom	Site #2 - Upstairs Breakroom
	VI 2143452-1	2021-04-30	Field Test	Site #2 - Upstairs Breakroom	Monthly Water Monitoring
	VI 2241837-1	2022-03-17	Coliform	Site #2 - Upstairs Breakroom	Monthly Water Monitoring
	VI 2245543-1	2022-07-21	Coliform	Site #2 - Upstairs Breakroom	Site #
	VI 2246505-1	2022-08-22	Coliform	Site #2 - Upstairs Breakroom	Site #
	VI 2247583-1	2022-09-26	Coliform	Site #2 - Upstairs Breakroom	Site #
	VI 2248292-1	2022-10-20	Coliform	Site #2 - Upstairs Breakroom	Site #
CuPb-ss03	VI 2245313-3	2022-06-28	Metals, Total	Upstairs Breakroom	Copper & Lead Monitoring
Well #1	VI 1444595-1	2014-12-04	Wet Chemistry	WELL 01- Raw	Cr+6 Monitoring
WELL01	VI 1941890-1	2019-04-29	Radio Chemistry	WELL 01- Raw	Well 01 - Water Quality
	VI 1941890-1	2019-04-29	Metals, Total	WELL 01- Raw	Well 01 - Water Quality
	VI 2240856-1	2022-02-10	SRL 524M-TCP	WELL 01- Raw	TCP Monitoring
	VI 2243021-1	2022-04-25	Metals, Total	WELL 01- Raw	Well 01 - Water Quality
	VI 2243021-1	2022-04-25	EPA 504.1	Well 01- Raw	Well 01 - Water Quality
	VI 2243021-1	2022-04-25	Wet Chemistry	WELL 01- Raw	Well 01 - Water Quality
	VI 2243825-1	2022-05-26	SRL 524M-TCP	WELL 01- Raw	TCP Monitoring
	VI 2244214-2	2022-06-13	Wet Chemistry	WELL 01- Raw	Annual Nitrate Monitoring
	VI 2246507-1	2022-08-22	SRL 524M-TCP	WELL 01- Raw	TCP Monitoring
	VI 2248526-1	2022-10-28	SRL 524M-TCP	WELL 01- Raw	O'NEILL VINTNERS & DISTILLERS
Well #3	VI 1440279-1	2014-01-29	General Mineral	WELL 03 - Raw	Water Quality Monitoring
	VI 1444595-2	2014-12-04	Wet Chemistry	WELL 03 - Raw	Cr+6 Monitoring
WELL03	VI 2040658-1	2020-01-29	Metals, Total	WELL 03 - Raw	O'NEILL VINTNERS & DISTILLERS
	VI 2143262-1	2021-04-30	Metals, Total	WELL 03 - Raw	Well 03 - Water Quality
	VI 2143262-1	2021-04-30	Radio Chemistry	WELL 03 - Raw	Well 03 - Water Quality
	VI 2240856-2	2022-02-10	SRL 524M-TCP	WELL 03 - Raw	TCP Monitoring
	VI 2243020-1	2022-04-25	Wet Chemistry	WELL 03 - Raw	Well 03 - Water Quality
	VI 2243825-2	2022-05-26	SRL 524M-TCP	WELL 03 - Raw	TCP Monitoring
	VI 2246507-2	2022-08-22	SRL 524M-TCP	WELL 03 - Raw	TCP Monitoring

	VI 2248526-2	2022-10-28	SRL 524M-TCP	WELL 03 - Raw	O'NEILL VINTNERS & DISTILLERS
--	--------------	------------	--------------	---------------	-------------------------------