

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	ONEILL VINTNERS & DISTILLERS
Water System Number:	CA1000411

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/19/2024 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Angel Contreras	
	Signature:	Angel Contreras	
	Title:	Manager of EHS	
	Phone Number:	(559) 638-3544	Date: 6/19/2024

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☐ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

☐ Posted the CCR on the internet at <http://> _____

☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)

☐ Advertised the availability of the CCR in news media (attach a copy of press release)

☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

☐ Posted the CCR in public places (attach a list of locations)

☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools

☐ Delivery to community organizations (attach a list of organizations)

☒ Other (attach a list of other methods used) Time Clocks + Break Areas

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> _____

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2023 Consumer Confidence Report

Water System Name: ONEILL VINTNERS & DISTILLERS

Report Date: April 2024

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2023.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 source(s): WELL 01 - RAW and WELL 03 - RAW
and from 1 treated location(s): Brandy Lab

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held. Information regarding public water system will be posted by time clocks and break rooms.

For more information about this report, or any questions relating to your drinking water, please call ext 8446 and ask for Angel Contreras.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	3/year (2023)	1	no more than 1 positive monthly sample	0	Naturally present in the environment.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2023)	5	0.19	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2021 - 2022)	ND	ND - 3	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2021 - 2022)	0.23	0.17 - 0.29	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium (ug/L)	(2021 - 2022)	ND	ND - 10	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits

Nitrate as N (mg/L)	(2023)	3.5	3.0 - 3.8	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2019 - 2021)	2.02	ND - 4.04	15	(0)	Erosion of natural deposits.
1,2,3-Trichloropropane (1,2,3-TCP) (ng/L)	(2023)	11	6 - 14	5	0.7	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.
Uranium (pCi/L)	(2019 - 2020)	3.9	3.89 - 3.90	20	0.43	Erosion of natural deposits

Table 4 - TREATED DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
1,2,3-Trichloropropane (1,2,3-TCP) (ug/L)	(2021)	ND	ND - 0.016	5	0.7	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Vanadium (ug/L)	(2021 - 2022)	14	7 - 21	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 6 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2022)	60	ND - 120	80	n/a	No	By-product of drinking water disinfection
Chlorine (mg/L)	(2021)	0.49	.36 - 0.61	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ug/L)	(2022)	1.5	ND - 3	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at

risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *O'Neill Beverages Co. LLC* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Total Coliform Bacteria				Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.
1,2,3-Trichloropropane (1,2,3-TCP)				Some people who use water containing 1,2,3-trichloropropane in excess of the action level over many years may have an increased risk of getting cancer, based on studies in laboratory animals.
Total Trihalomethanes (TTHMs)				Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience liver, kidney, or central nervous system problems, and may have an increased risk of getting cancer.

2023 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 01 and WELL 03 of the O'NEILL VINTNERS & DISTILLERS water system in March, 2003.

Discussion of Vulnerability

There have been no primary contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source. The primary source of potential contamination could come from septic systems in the area.

Acquiring Information

A copy of the complete assessment may be viewed at:
Fresno County Department of Community Health Environmental Health
1221 Fulton Mall
PO Box 11867
Fresno, Ca 93775

You may request a summary of the assessment be sent to you by contacting:

Jim Brunton
Supervising Environmental Health Analysts
(559) 445-3357
(559) 445-3379 (fax)

O'Neill Beverages Co. LLC

Analytical Results By FGL - 2023

MICROBIOLOGICAL CONTAMINANTS								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
Total Coliform Bacteria			0	5%	n/a			1 11.1 - 19.2
Boiler Room	VI 2348332-1					2023-12-07	<1.0	
Boiler Room	VI 2347650-1					2023-11-13	<1.0	
Boiler Room	VI 2347276-1					2023-10-26	19.2	
Boiler Room	VI 2346973-1					2023-10-16	11.1	
Boiler Room	VI 2346554-1					2023-09-28	19.2	
Boiler Room	VI 2345490-1					2023-08-17	<1.0	
Boiler Room	VI 2344747-1					2023-07-20	<1.0	
Boiler Room	VI 2344012-1					2023-06-29	<1.0	
Boiler Room	VI 2343394-1					2023-05-31	<1.0	
Boiler Room	VI 2342087-1					2023-04-06	<1.0	
Boiler Room	VI 2341319-1					2023-03-03	<1.0	
Boiler Room	VI 2341152-1					2023-02-23	<1.0	
Boiler Room	VI 2340405-1					2023-01-23	<1.0	

LEAD AND COPPER RULE								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile # Samples
Copper		mg/L		1.3	.3			0.19 5
Boiler Room	VI 2343468-2	mg/L				2023-05-30	ND	
Front Office Sink	VI 2343468-5	mg/L				2023-05-30	0.14	
Lab Sink	VI 2343468-1	mg/L				2023-05-30	ND	
Processing Room	VI 2343468-4	mg/L				2023-05-30	0.24	
Upstairs Breakroom	VI 2343468-3	mg/L				2023-05-30	0.12	

PRIMARY DRINKING WATER STANDARDS (PDWS)								
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a) Range (b)
Arsenic		ug/L		10	0.004			ND ND - 3
WELL 01 - RAW	VI 2243021-1	ug/L				2022-04-25	ND	
WELL 03 - RAW	VI 2143262-1	ug/L				2021-04-30	3	
Barium		mg/L	2	1	2			0.23 0.17 - 0.29
WELL 01 - RAW	VI 2243021-1	mg/L				2022-04-25	0.29	
WELL 03 - RAW	VI 2143262-1	mg/L				2021-04-30	0.17	
Chromium		ug/L	100	50.0	n/a			ND ND - 10
WELL 01 - RAW	VI 2243021-1	ug/L				2022-04-25	10	
WELL 03 - RAW	VI 2143262-1	ug/L				2021-04-30	ND	
Nitrate as N		mg/L		10	10			3.5 3.0 - 3.8
WELL 01 - RAW	VI 2344012-2	mg/L				2023-06-29	3.8	
WELL 01 - RAW	VI 2342586-1	mg/L				2023-04-28	3.6	
WELL 03 - RAW	VI 2343215-1	mg/L				2023-05-24	3.0	
Gross Alpha		pCi/L		15	(0)			2.020 ND - 4.04
WELL 01 - RAW	VI 1941890-1	pCi/L				2019-04-29	4.04	
WELL 03 - RAW	VI 2143262-1	pCi/L				2021-04-30	ND	
1,2,3-Trichloropropane (1,2,3-TCP)		ng/L		5	0.7			11 6 - 14
WELL 01 - RAW	VI 2347653-1	ng/L				2023-11-13	14	
WELL 01 - RAW	VI 2345491-1	ng/L				2023-08-17	6	
WELL 01 - RAW	VI 2341153-1	ng/L				2023-02-23	12	
WELL 03 - RAW	VI 2345491-2	ng/L				2023-08-17	7	
WELL 03 - RAW	VI 2343208-2	ng/L				2023-05-24	12	
WELL 03 - RAW	VI 2341153-2	ng/L				2023-02-23	14	
Uranium		pCi/L		20	0.43			3.90 3.89 - 3.90
WELL 01 - RAW	VI 1941890-1	pCi/L				2019-04-29	3.90	

WELL 03 - RAW	VI 2040658-1	pCi/L				2020-01-29	3.89		
---------------	--------------	-------	--	--	--	------------	------	--	--

TREATED PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
1,2,3-Trichloropropane (1,2,3-TCP)		ug/L		5	0.7			ND	ND - 0.016
Brandy Lab	VI 2147920-1	ug/L				2021-10-06	ND		
Brandy Lab	VI 2147729-1	ug/L				2021-09-29	ND		
Brandy Lab	VI 2147610-1	ug/L				2021-09-24	ND		
Brandy Lab	VI 2147135-1	ug/L				2021-09-08	ND		
Brandy Lab	VI 2146756-1	ug/L				2021-08-25	0.016		
Brandy Lab	VI 2146564-1	ug/L				2021-08-18	0.013		

UNREGULATED CONTAMINANTS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Vanadium		ug/L		NS	n/a			14	7 - 21
WELL 01 - RAW	VI 2243021-1	ug/L				2022-04-25	7		
WELL 03 - RAW	VI 2143262-1	ug/L				2021-04-30	21		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

[illegible]

O'Neill Beverages Co. LLC

CCR Login Linkage - 2023

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
BOILER RM	VI 2140637-1	2021-01-27	Field Test	Boiler Room	Monthly Water Monitoring
	VI 2340405-1	2023-01-23	Coliform	Boiler Room	Site #
	VI 2341152-1	2023-02-23	Coliform	Boiler Room	Monthly Water Monitoring
	VI 2341319-1	2023-03-03	Coliform	Boiler Room	Monthly Water Monitoring
	VI 2342087-1	2023-04-06	Coliform	Boiler Room	Monthly Water Monitoring
DST_LCR	VI 2343468-2	2023-05-30	Metals, Total	Boiler Room	Copper & Lead Monitoring
BOILER RM	VI 2343394-1	2023-05-31	Coliform	Boiler Room	Monthly Water Monitoring
	VI 2344012-1	2023-06-29	Coliform	Boiler Room	Site #
	VI 2344747-1	2023-07-20	Coliform	Boiler Room	Site #
	VI 2345490-1	2023-08-17	Coliform	Boiler Room	Monthly Water Monitoring
	VI 2346554-1	2023-09-28	Coliform	Boiler Room	Site #
	VI 2346973-1	2023-10-16	Coliform	Boiler Room	O'Neill Beverages - Repeats
	VI 2347276-1	2023-10-26	Coliform	Boiler Room	Site #
	VI 2347650-1	2023-11-13	Coliform	Boiler Room	Monthly Water Monitoring
	VI 2348332-1	2023-12-07	Coliform	Boiler Room	Monthly Water Monitoring
	VI 2146564-1	2021-08-18	SRL 524M-TCP	Brandy Lab	Bacteriological Monitoring
Brandy Lab	VI 2146756-1	2021-08-25	SRL 524M-TCP	Brandy Lab	Bacteriological Monitoring
	VI 2147135-1	2021-09-08	SRL 524M-TCP	Brandy Lab	Bacteriological Monitoring
	VI 2147610-1	2021-09-24	SRL 524M-TCP	Brandy Lab	Bacteriological Monitoring
	VI 2147729-1	2021-09-29	SRL 524M-TCP	Brandy Lab	Bacteriological Monitoring
	VI 2147920-1	2021-10-06	SRL 524M-TCP	Brandy Lab	Bacteriological Monitoring
DBP-ss02	VI 2241838-2	2022-03-17	EPA 552.2	DBP Smpg Pt - W-2 East End Of	DBP Monitoring
	VI 2241838-2	2022-03-17	EPA 551.1	DBP Smpg Pt - W-2 East End Of	DBP Monitoring
	VI 2244604-2	2022-06-23	EPA 551.1	DBP Smpg Pt - W-2 East End Of	DBP Monitoring
	VI 2244604-2	2022-06-23	EPA 552.2	DBP Smpg Pt - W-2 East End Of	DBP Monitoring
DBP-ss01	VI 2241838-1	2022-03-17	EPA 551.1	DBP Smpg Pt -W-1-North Center	DBP Monitoring
	VI 2241838-1	2022-03-17	EPA 552.2	DBP Smpg Pt -W-1-North Center	DBP Monitoring
	VI 2244604-1	2022-06-23	EPA 551.1	DBP Smpg Pt -W-1-North Center	DBP Monitoring
	VI 2244604-1	2022-06-23	EPA 552.2	DBP Smpg Pt -W-1-North Center	DBP Monitoring
DST_LCR	VI 2343468-5	2023-05-30	Metals, Total	Front Office Sink	Copper & Lead Monitoring
	VI 2343468-1	2023-05-30	Metals, Total	Lab Sink	Copper & Lead Monitoring
	VI 2343468-4	2023-05-30	Metals, Total	Processing Room	Copper & Lead Monitoring
Bacti-ss02	VI 2141401-1	2021-02-24	Field Test	Site #2 - Upstairs Breakroom	Monthly Water Monitoring
	VI 2142289-1	2021-03-24	Field Test	Site #2 - Upstairs Breakroom	Site #2 - Upstairs Breakroom
	VI 2143452-1	2021-04-30	Field Test	Site #2 - Upstairs Breakroom	Monthly Water Monitoring
DST_LCR	VI 2343468-3	2023-05-30	Metals, Total	Upstairs Breakroom	Copper & Lead Monitoring
WELL01	VI 1941890-1	2019-04-29	Metals, Total	WELL 01 - RAW	Well 01 - Water Quality
	VI 1941890-1	2019-04-29	Radio Chemistry	WELL 01 - RAW	Well 01 - Water Quality
	VI 2243021-1	2022-04-25	Metals, Total	WELL 01 - RAW	Well 01 - Water Quality
	VI 2243021-1	2022-04-25	EPA 504.1	WELL 01 - RAW	Well 01 - Water Quality
	VI 2341153-1	2023-02-23	SRL 524M-TCP	WELL 01 - RAW	TCP Monitoring - 1
	VI 2342586-1	2023-04-28	Wet Chemistry	WELL 01 - RAW	Well 01 - Water Quality
	VI 2344012-2	2023-06-29	Wet Chemistry	WELL 01 - RAW	Annual Nitrate Monitoring
	VI 2345491-1	2023-08-17	SRL 524M-TCP	WELL 01 - RAW	TCP Monitoring - 1
	VI 2347653-1	2023-11-13	SRL 524M-TCP	WELL 01 - RAW	TCP Monitoring - 1
WELL03	VI 2040658-1	2020-01-29	Metals, Total	WELL 03 - RAW	O'NEILL VINTNERS & DISTILLERS
	VI 2143262-1	2021-04-30	Metals, Total	WELL 03 - RAW	Well 03 - Water Quality
	VI 2143262-1	2021-04-30	Radio Chemistry	WELL 03 - RAW	Well 03 - Water Quality
	VI 2341153-2	2023-02-23	SRL 524M-TCP	WELL 03 - RAW	TCP Monitoring - 1
	VI 2343215-1	2023-05-24	Wet Chemistry	WELL 03 - RAW	Well 03 - Water Quality
	VI 2343208-2	2023-05-24	SRL 524M-TCP	WELL 03 - RAW	TCP Monitoring - 1
	VI 2345491-2	2023-08-17	SRL 524M-TCP	WELL 03 - RAW	TCP Monitoring - 1