

2020 Consumer Confidence Report

Water System Name: **Batth Dehydrator**

Report Date: 2020

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2021 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse BATTH DEHYDRATOR a 4624 W NEBRASKA CARUTHERS 93609 559-864-3501 para asistirlo en español.

Type of water source(s) in use: Groundwater

Name & general location of source(s): Well is located on the Westside of the facility

Drinking Water Source Assessment information: Possible potential contamination from septic systems in the area

Time and place of regularly scheduled board meetings for public participation: NA

For more information, contact: Rani Batth

Phone: (559)864-3501

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	0	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	9/24/2019	5	0	0	15	0.2	0	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	9/24/2019	5	0	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits;

							leaching from wood preservatives
--	--	--	--	--	--	--	----------------------------------

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm) Well 03	12/18/2020	25 mg/l	N/A	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm) Well 03	12/18/2020	23 mg/l	N/A	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Inorganic Contaminants						
Arsenic ug/l Well 03	12/18/2020	14	N/A	10 ug/l	1.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Arsenic (ug/L) Well 01	1/4/2019	2.9	NA	10 ug/l	1.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Fluoride (MG/L) Well 03	12/18/2020	0.19	NA	2.0	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (N) ppm * Well 1	2020	3.83	1.7-6.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
*Nitrate (N) ppm post treatment at drinking fountain	2020	0.65	0-1.3	10	10	Same as above
*Nitrate (N) ppm post treatment at kitchen sink	2020	0.145	0.58	10	10	Same as above
*Nitrate (N) ppm post treatment at fill station	2020	0.43	0.41-0.47	10	10	Same as above
Uranium (pCi/L) well 01	10/7/2019	7.2	NA	20	0.13	Erosion of natural deposits
Gross Alpha (PCI/L) Well 01	1/6//2020	1.27	NA	15	1	Erosion of natural deposits

Synthetic Organic Contaminants including Pesticides and Herbicides

Dibromochloropropane* (DBCP) (ppt) Well 01	2020	0.242	0.045-0.48	200	1.7	Banned nematocide that may still be present in soils due to runoff/leaching from former use on soybeans; cotton; vineyards, tomatoes and tree fruits
1,2,3 Trichloropropane* (1,2,3-TCP) Well 1	2020	0.039	.038-0.072			
1,2,3 Trichloropropane* (1,2,3-TCP) Well 3	12/18/2020	0.039	0.006-.038	0.005	0.0007	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.
*1,2,3 Trichloropropane (1,2,3 TCP) post treatment	2020	0	0	5	0.7	Same as above

Disinfection Byproducts, Disinfectant Residuals, and Disinfection Byproduct Precursors						
TTHM(Total Trihalomethanes) (ppb)	7/25/2017	0.74	N/A	80	N/A	Byproduct of drinking water disinfection
TABLE 5 – DETECTION OF CONTAMINANTS WITH A <u>SECONDARY</u> DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Chloride(ppm) Well 03	12/18/2020	3.5 ppm	N/A	500 ppm	N/A	Runoff/leaching from natural deposits; seawater influence
Iron(ug/L) Well 03	12/18/2020	120	NA	1000	300	Leaching from natural deposits; industrial wastes
Iron (ppb)* well 01	4/19/2016	340 ppb	N/A	300 ppb	N/A	Leaching from natural deposits; industrial wastes
MBAS(ppb) Well 01	2016	0.5 ppb	N/A	500 ppb	N/A	Municipal and industrial waste discharges
Specific Conductance (umhos) Well 03	12/18/2020	140	N/A	1600 umhos	N/A	Substances that form ions when in water; seawater influence
Total Dissolved Solids (ppm) Well 03	12/18/2020	120	N/A	1000 ppm	N/A	Runoff/leaching from natural deposits
Sulfate (ppm) Well 03	12/18/2020	4.0	N/A	500 ppm	N/A	Runoff/leaching from natural deposits; industrial waters
Copper (ppm) Well 01	4/19/2016	0.019	N/A	1.0 ppm	N/A	Internal corrosion of household plumbing systems; erosion f natural deposits; leaching from wood preservatives
Color Units Well 01	4/19/2016	<5.0	N/A	15	N/A	Naturally-occurring organic materials
Zinc(ppm) well 03	12/18/2021	60	N/A	5.0	N/A	Runoff/leaching from natural deposits; industrial wastes
Turbidity (NTU) well 03	12/18/2021	.04	N/A	5	N/A	Soil runoff

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Bath Dehydrator is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4701) or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
Arsenic Well 03	Erosion of natural deposits	1 month	POU's are in place to remove contaminant prior to being served to consumer	Some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems, and may have an increased risk of getting cancer.

For Water Systems Providing Groundwater as a Source of Drinking Water

TABLE 7 – SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLES					
Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0	2020	0	(0)	Human and animal fecal waste
Enterococci	0	2020	TT	n/a	Human and animal fecal waste
Coliphage	0	2020	TT	n/a	Human and animal fecal waste

SUMMARY STATEMENT ABOUT WATER SYSTEM IN 2020

Last year, your drinking water AFTER TREATMENT met all U.S. EPA and State drinking water health standards. Batth Dehydrator vigilantly safeguards its water supplies and did not violate water quality standards. This Consumer Confidence Report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards. We are committed to providing you with information because informed customers are our best allies.