

2025 Consumer Confidence Report

Water System Information

Water System Name: CITY OF REEDLEY

Report Date: 4/17/26

Type of Water Source(s) in Use: GROUND WATER

Name and General Location of Source(s): WELL 5, 6, 10, 11, 12, 13, 14

Drinking Water Source Assessment Information: N/A

Time and Place of Regularly Scheduled Board Meetings for Public Participation: N/A

For More Information, Contact: JASON TEETER (559)637-4200 EXT 267

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2025, and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse [CITY OF REEDLEY] a [845 G ST. REEDLEY CA 93654] para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 [CITY OF REEDLEY] 以获得中文的帮助: [845 G ST. REEDLEY CA 93654].

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa [CITY OF REEDLEY 845 G ST. REEDLEY CA 93654] o tumawag sa [(559)528-5177] para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ [CITY OF REEDLEY] tại [845 G ST. REEDLEY CA 93654] để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau [CITY OF REEDLEY] ntawm [845 G ST. REEDLEY CA 93654] rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	Range of Results	AL	PHG	Typical Source of Contaminant
Lead (ppb)	9/30/24	32	ND	0	ND	15	0.2	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	9/30/24	32	0.154	0	ND – 0.21	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	4/11/25 8/4/25	14.8	3.6 - 26	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	4/11/25 8/4/25	93	26 - 160	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Nitrate (mg/L) Well 05A ,Well 06A, Well 10, Well 11, Well 12, Well 13, & Well 14	Monthly Jan – Dec 2025	4.64	0.24 – 8.4	10 (as N)	10 (as N)	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
1,2,3-Trichloropropane [TCP] (ng/L) Well 06A, Well 10, Well 11, Well 12, Well 13, & Well 14	Monthly Jan – Dec 2025	24.5	ND – 56	5	0.7	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.
Monochlorobenzene (µg/L) – Well 12	10/7/25	ND	N/A	70	70	Discharge from industrial and agricultural chemical factories and dry cleaning facilities
Methyl-tert-butyl ether (µg/L) – Well 12	10/7/25	ND	N/A	13	13	Leaking underground storage tanks; discharge from petroleum and chemical factories
1,1,2-Trichloro-1,2,2-trifluoroethane (mg/L) - Well 12	10/7/25	ND	N/A	1.2	4	Discharge from metal degreasing sites and other factories; dry-cleaning solvent; refrigerant
Alachlor (µg/L) – Well 10 , Well 12	4/11/25 8/4/25	ND	ND	2	4	Runoff from herbicide used on row crops
Atrazine (µg/L) – Well 10, Well 12	4/11/25 8/4/25	ND	ND	1	0.15	Runoff from herbicide used on row crops and along railroad and

						highway right-of-ways
Simazine (µg/L) – Well 10, Well 12	4/11/25 8/4/25	ND	ND	4	4	Herbicide runoff
Perchlorate (µg/L) – Well 10, Well 11, Well 12	3/5/25 5/5/25 10/7/25	0.60	ND – 1.8	6	1	Perchlorate is an inorganic chemical used in solid rocket propellant, fireworks, explosives, flares, matches, and a variety of industries. It usually gets into drinking water as a result of environmental contamination from historic aerospace or other industrial operations that used or use, store, or dispose of perchlorate and its salts.
Arsenic (µg/L) – Well 10 & Well 12	4/11/25 8/4/25	1.3	ND – 2.6	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Aluminum (mg/L) – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes
Barium (mg/L) – Well 10 & Well 12	4/11/25	0.04	ND - 0.075	1	2	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Antimony (µg/L) - Well 10 & Well 12	4/11/25 8/4/25	ND	ND	6	1	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Beryllium (µg/L) – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	4	1	Discharge from metal refineries, coal-burning factories, and electrical, aerospace, and defense industries

Cadmium (µg/L) – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	5	0.04	Internal corrosion of galvanized pipes; erosion of natural deposits; discharge from electroplating and industrial chemical factories, and metal refineries; runoff from waste batteries and paints
Chromium [total] (µg/L)- Well 10 & Well 12	4/11/25 8/4/25	ND	ND	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Copper (mg/L) – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	AL = 1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride (mg/L) – Well 10 & Well 12	4/11/25 8/4/25	0.08	ND – 0.16	2.0	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Lead (µg/L) – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	AL = 15	0.2	Corrosion of household plumbing systems; Erosion of natural deposits
Mercury [Inorganic] (µg/L) – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	2	1.2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills and cropland
Nickel (µg/L) – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	100	12	Erosion of natural deposits; discharge from metal factories
Nitrite (mg/L) – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	1 (as N)	1 (as N)	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (µg/L) – Well 10 & Well 12	4/11/25	ND	ND	50	30	Discharge from petroleum, glass,

	8/4/25					and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
Thallium (µg/L) – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	2	0.1	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
Trichlorofluoromethane (µg/L) – Well 12	10/7/25	ND	N/A	150	1300	Discharge from industrial factories; degreasing solvent; propellant and refrigerant
1,2,4-Trichlorobenzene (µg/L) – Well 12	10/7/25	ND	N/A	5	5	Discharge from textile-finishing factories
cis-1,2-Dichloroethylene (µg/L) – Well 12	10/7/25	ND	N/A	6	13	Discharge from industrial chemical factories; major biodegradation byproduct of TCE and PCE groundwater contamination
1,3-Dichloropropene (ng/L) – Well 12	10/7/25	ND	N/A	500	200	Runoff/leaching from nematocide used on croplands
Xylenes (mg/L) – Well 12	10/7/25	ND	N/A	1.750	1.8	Discharge from petroleum and chemical factories; fuel solvent
Dichloromethane (µg/L) – Well 12	10/7/25	ND	N/A	5	4	Discharge from pharmaceutical and chemical factories; insecticide
Vinyl Chloride (ng/L) – Well 12	10/7/25	ND	N/A	500	50	Leaching from PVC piping; discharge from plastics factories; biodegradation byproduct of TCE and PCE groundwater contamination
1,1-Dichloroethylene (µg/L) – Well 12	10/7/25	ND	N/A	6	10	Discharge from industrial chemical factories

1,1-Dichloroethane (µg/L) – Well 12	10/7/25	ND	N/A	5	3	Extraction and degreasing solvent; used in manufacture of pharmaceuticals, stone, clay and glass products; fumigant
trans-1,2-Dichloroethylene (µg/L) – Well 12	10/7/25	ND	N/A	10	50	Discharge from industrial chemical factories; minor biodegradation byproduct of TCE and PCE groundwater contamination
1,2-Dichloroethane (ng/L) – Well 12	10/7/25	ND	N/A	500	400	Discharge from industrial chemical factories
1,1,1-Trichloroethane (µg/L) – Well 12	10/7/25	ND	N/A	200	1000	Discharge from metal degreasing sites and other factories; manufacture of food wrappings
Carbon Tetrachloride (ng/L) – Well 12	10/7/25	ND	N/A	500	100	Discharge from chemical plants and other industrial activities
1,2-Dichloropropane (µg/L) – Well 12	10/7/25	ND	N/A	5	0.5	Discharge from industrial chemical factories; primary component of some fumigants
Dibromochloropropane [DBCP] (ng/L) – Well 05A, Well 12, Well 13, & Well 14	Monthly Jan – Dec 2025	137.8	3 - 300	200	3	Banned nematocide that may still be present in soils due to runoff/leaching from former use on soybeans, cotton, vineyards, tomatoes, and tree fruit
Trichloroethylene [TCE] (µg/L) – Well 12	10/7/25	ND	N/A	5	1.7	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (µg/L) – Well 12	10/7/25	ND	N/A	5	0.3	Discharge from industrial chemical factories
Tetrachloroethylene (PCE) (µg/L) – Well 12	10/7/25	2.1	N/A	5	0.06	Discharge from factories, dry cleaners, and auto

						shops (metal degreaser)
1,1,2,2-Tetrachloroethane (µg/L) – Well 12	10/7/25	ND	N/A	1	0.1	Discharge from industrial and agricultural chemical factories; solvent used in production of TCE, pesticides, varnish and lacquers
Benzene (µg/L) – Well 12	10/7/25	ND	N/A	1	0.15	Discharge from plastics, dyes and nylon factories; leaching from gas storage tanks and landfills
Toluene (µg/L) – Well 12	10/7/25	ND	N/A	150	150	Discharge from petroleum and chemical factories; underground gas tank leaks
Ethylbenzene (µg/L) – Well 12	10/7/25	ND	N/A	300	300	Discharge from petroleum refineries; industrial chemical factories
Styrene (µg/L) – Well 12	10/7/25	ND	N/A	100	0.5	Discharge from rubber and plastic factories; leaching from landfills
Ethylene Dibromide [EDB] (ng/L) – Well 12, Well 13, Well 14	6/2/25 11/5/25 12/3/25	ND	ND	50	10	Discharge from petroleum refineries; underground gas tank leaks; banned nematocide that may still be present in soils due to runoff and leaching from grain and fruit crops

Nitrate (mg/L) AFTER TREATMENT	Weekly Jan – Dec 2025	5.65	2.7 – 6.9	10 (as N)	10 (as N)	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Dibromochloropropane [DBCP] (ng/L) – AFTER TREATMENT	Monthly Jan – Dec 2025	ND	ND	200	3	Banned nematocide that may still be present in soils due to runoff/leaching from former use on soybeans, cotton, vineyards, tomatoes, and tree fruit
1,2,3-Trichloropropane [TCP] (ng/L) AFTER TREATMENT	Monthly Jan – Dec 2025	0.214	ND – 0.9	5	0.7	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.
Ethylene Dibromide [EDB] (ng/L) – AFTER TREATMENT	6/2/25 11/5/25 12/3/25	ND	ND	50	10	Discharge from petroleum refineries; underground gas tank leaks; banned nematocide that may still be present in soils due to runoff and leaching from grain and fruit crops
TTHMs [Total Trihalomethanes] (µg/L) – Dist Site	9/10/25	1.2	N/A	80	N/A	Byproduct of drinking water disinfection
HAA5 [Sum of 5 Haloacetic Acids] (µg/L)- Dist Site	9/10/25	ND	N/A	60	N/A	Byproduct of drinking water disinfection

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Foaming Agents [MBAS] – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	0.5 mg/L	500 µg/L	Municipal and industrial waste discharges
Total Dissolved Solids [TDS] – Well 10 & Well 12	4/11/25 8/4/25	188.5	67 - 310	1,000 mg/L	1,000 mg/L	Runoff/leaching from natural deposits
Aluminum – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	0.2 mg/L	200 µg/L	Erosion of natural deposits; residual from some surface water treatment processes
Odor---Threshold – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	3 Units	3 Units	Naturally-occurring organic materials
Color – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	15 Units	15 Units	Naturally-occurring organic materials
Zinc – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	5.0 mg/L	5.0 mg/L	Runoff/leaching from natural deposits; industrial wastes
Turbidity – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	5 Units	5 Units	Soil runoff
Methyl- <i>tert</i> -butyl ether [MTBE] – Well 12	10/7/25	ND	N/A	0.005 mg/L	5 µg/L	Leaking underground storage tanks; discharge from petroleum and chemical factories
Chloride – Well 10 & Well 12	4/11/25 8/4/25	14.1	1.2 - 27	500 mg/L	500 mg/L	Runoff/leaching from natural deposits; seawater influence
Iron – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	0.3 mg/L	300 µg/L	Leaching from natural deposits; industrial wastes
Manganese – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	0.05 mg/L	50 µg/L	Leaching from natural deposits
Silver – Well 10 & Well 12	4/11/25 8/4/25	ND	ND	0.1 mg/L	100 µg/L	Industrial discharges
Specific Conductance – Wells 05A,06A,10,11, 12,13, & 14	Jan – Dec 2025 Monthly	336	63 - 530	1,600 µS/cm	1,600 µS/cm	Substances that form ions when in water; seawater influence
Sulfate – Well 10 & Well 12	4/11/25 8/4/25	10.15	2.3 - 18	500 mg/L	500 mg/L	Runoff/leaching from natural deposits; industrial wastes

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [UTILITY NAME] is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact [UTILITY NAME and CONTACT]. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*: [Enter Additional Information Described in Instructions for SWS CCR Document]

State Revised Total Coliform Rule (RTCR): [Enter Additional Information Described in Instructions for SWS CCR Document]

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
1,2,3-TCP MCL Violation	Source water had results of 1,2,3-TCP over the MCL.	All months of 2025	Treatment has been installed and sampling is conducted monthly to ensure water quality is under the MCL.	Some people who drink water containing 1,2,3-trichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.