

APPENDIX B: eCCR Certification Form (Suggested Format)


Consumer Confidence Report Certification Form

(To be submitted with a copy of the CCR)

Water System Name:	City of Fresno Wastewater Management Division - 1 Water System
Water System Number:	CA-1010057

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/30/2025 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by:

Name: Cory Asher	Title: Assistant Director
Signature: 	Date: 8/1/2025
Phone number: (559) 621-5110	blank

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- ☐ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- ☒ CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- ☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - ☐ Posting the CCR at the following URL: www._____
 - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - ☒ Posted the CCR in public places (attach a list of locations)

- ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
- ☐ Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
- ☒ Other (attach a list of other methods used)
- ☐ *For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following URL: www._____
- ☐ *For privately-owned utilities:* Delivered the CCR to the California Public Utilities Commission

Consumer Confidence Report Electronic Delivery Certification

Water systems utilizing electronic distribution methods for CCR delivery must complete this page by checking all items that apply and fill-in where appropriate.

- ☐ Water system mailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available website where it can be viewed (attach a copy of the mailed CCR notification). URL: www._____
- ☐ Water system emailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed (attach a copy of the emailed CCR notification). URL: www._____
- ☒ Water system emailed the CCR as an electronic file email attachment.
- ☐ Water system emailed the CCR text and tables inserted or embedded into the body of an email, not as an attachment (attach a copy of the emailed CCR).
- ☐ *Requires prior DDW review and approval.* Water system utilized other electronic delivery method that meets the direct delivery requirement.

Provide a brief description of the water system's electronic delivery procedures and include how the water system ensures delivery to customers unable to receive electronic delivery.

The Consumer Confidence Report (CCR) was distributed to all employees through an email that included the attachment. Each employee has a company email account and computer access to retrieve their emails. Furthermore, the CCR was uploaded to the

facility's Intranet page, specifically in the reports folder, allowing easy access for all facility personnel. Additionally, a printed copy of the CCR was posted on the main notification board located in the main break room.

This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c) of the California Code of Regulations.

Picture of 2023 CCR posted in Break Room.

Consumer Confidence Report Page 1 of 10

2024 Consumer Confidence Report

Water System Information

Water System Name: City of Fresno Wastewater Management Division - 1 Water System

Report Date: June 24, 2025

Type of Water Source(s) in Use: Groundwater

Name and General Location of Source(s):

- Well #3A and Well #7 located at the Fresno-Clovis Regional Wastewater Reclamation Facility (RWRF) 5607 W. Jensen Ave. Fresno, CA. 93706

Drinking Water Source Assessment Information:

- A source assessment was conducted for the active water supply wells for the Fresno City Wastewater Plant 1W System in April 2002. Another source water assessment was conducted in February 2008 in connection with the permitting of Well #7. Two additional source water assessments were performed in August 2013 and May 2015.
- The sources are considered most vulnerable to the following activities not associated with any contaminates.
 - Automobile-Gas Stations
 - Historic Gas Stations
 - Wastewater Treatment Plants
- A copy of the assessment may be viewed at:
 - Fresno-Clovis Regional Wastewater Reclamation Facility
5607 W. Jensen Ave. Fresno, CA. 93706
- Discussion of vulnerability:
 - The Wells are vulnerable to contamination associated with wastewater treatment plant and the sanitary sewer pipelines and reclamation sites surrounding the wastewater treatment plant. The most common contamination associated with wastewater treatment plants are elevated nitrate levels or bacteriological contamination. The wastewater treatment plant monitors the nitrate level in both wells annually. The wastewater levels of nitrate. In addition, the sources are monitored monthly to identify any elevated fecal coliform (bacteriological contamination). As a precaution, the wastewater treatment plant disinfects the water produced from both wells with Sodium Hypochlorite feed systems.
- You may request a summary of the assessment be sent to you by contacting:
 - Cory Asher, Wastewater Manager, (559) 621-5110.

SWS CCR Revised January 2025