

## 2025 Consumer Confidence Report

### Water System Information

Water System Name: City of Fresno Wastewater Management Division - 1 Water System

Report Date: June 25, 2026

Type of Water Source(s) in Use: Groundwater

- Name and General Location of Source(s): Well #3A and Well #7 located at the Fresno-Clovis Regional Wastewater Reclamation Facility (RWRF) 5607 W. Jensen Ave. Fresno, CA 93706

Drinking Water Source Assessment Information:

- A source assessment was conducted for the active water supply wells for the Fresno City Wastewater Plant 1W System in April 2002. Another source water assessment was conducted in February 2008 in connection with the permitting of Well #7. Two additional source water assessments were performed in August 2013 and May 2015.
- The sources are considered most vulnerable to the following activities not associated with any contaminants.
  - Automobile-Gas Stations
  - Historic Gas Stations
  - Wastewater Treatment Plants
- A copy of the assessment may be viewed at:
  - Fresno-Clovis Regional Wastewater Reclamation Facility  
5607 W. Jensen Ave. Fresno, CA 93706
- Discussion of vulnerability:
  - The wells are vulnerable to contamination associated with wastewater treatment plant and the sanitary sewer pipelines and reclamation sites surrounding the wastewater treatment plant. The most common contamination associated with wastewater treatment plants are elevated nitrate levels or bacteriological contamination. The wastewater treatment plant monitors the nitrate level in both wells annually to identify any elevated levels of nitrate. In addition, the sources are monitored monthly for total coliform and fecal coliform (bacteriological contamination). As a precaution, the wastewater treatment plant disinfects the water produced from both wells with sodium hypochlorite feed systems.
- You may request a summary of the assessment be sent to you by contacting:
  - Andrew Heckman, Wastewater Manager, (559) 621-5170.

### Time and Place of Regularly Scheduled Board Meetings for Public Participation:

- There are no board meetings. However, plant personnel can bring up issues regarding the water system at any time, including but not limited to staff meetings or bi-weekly management staff meetings.

For More Information, Contact: Andrew Heckman at (559) 621-5170

## About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2025, and may include earlier monitoring data.

## Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse City of Fresno Wastewater Management Division - 1 Water System a 5607 W. Jensen Ave. Fresno, CA 93706 (559) 621-5110 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 City of Fresno Wastewater Management Division - 1 Water System 以获得中文的帮助: 5607 W. Jensen Ave. Fresno, CA 93706 (559) 621-5110.

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa City of Fresno Wastewater Management Division - 1 Water System o tumawag sa 5607 W. Jensen Ave. Fresno, CA 93706 (559) 621-5110 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ City of Fresno Wastewater Management Division - 1 Water System tại 5607 W. Jensen Ave. Fresno, CA 93706 (559) 621-5110 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau City of Fresno Wastewater Management Division - 1 Water System ntawm 5607 W. Jensen Ave. Fresno, CA 93706 (559) 621-5110 rau kev pab hauv lus Askiv.

## Terms Used in This Report

| Term               | Definition                                                                                                                                                                                                                                                                  |
|--------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Level 1 Assessment | A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.                                                                                             |
| Level 2 Assessment | A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions. |

| <b>Term</b>                                      | <b>Definition</b>                                                                                                                                                                                                                                                |
|--------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Maximum Contaminant Level (MCL)                  | The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water. |
| Maximum Contaminant Level Goal (MCLG)            | The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).                                                                                     |
| Maximum Residual Disinfectant Level (MRDL)       | The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.                                                                                  |
| Maximum Residual Disinfectant Level Goal (MRDLG) | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.                                                           |
| Primary Drinking Water Standards (PDWS)          | MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.                                                                                                                     |
| Public Health Goal (PHG)                         | The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.                                                                                           |
| Regulatory Action Level (AL)                     | The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.                                                                                                                                 |
| Secondary Drinking Water Standards (SDWS)        | MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.                                                                                                          |
| Treatment Technique (TT)                         | A required process intended to reduce the level of a contaminant in drinking water.                                                                                                                                                                              |
| Variances and Exemptions                         | Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.                                                                                                       |
| ND                                               | Not detectable at testing limit.                                                                                                                                                                                                                                 |
| ppm                                              | parts per million or milligrams per liter (mg/L)                                                                                                                                                                                                                 |
| ppb                                              | parts per billion or micrograms per liter (µg/L)                                                                                                                                                                                                                 |
| ppt                                              | parts per trillion or nanograms per liter (ng/L)                                                                                                                                                                                                                 |
| ppq                                              | parts per quadrillion or picograms per liter (pg/L)                                                                                                                                                                                                              |
| pCi/L                                            | picocuries per liter (a measure of radiation)                                                                                                                                                                                                                    |

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

| Microbiological Contaminants | Highest No. of Detections | No. of Months in Violation | MCL | MCLG | Typical Source of Bacteria   |
|------------------------------|---------------------------|----------------------------|-----|------|------------------------------|
| <i>E. coli</i>               | (2025)<br>0               | 0                          | (a) | 0    | Human and animal fecal waste |

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Complete if lead or copper is detected in the last sample set.

| Lead and Copper | Sample Date | No. of Samples | 90 <sup>th</sup> Percentile Level Detected | No. Sites Exceeding AL | Range of Results | AL  | PHG | Typical Source of Contaminant                                                                                   |
|-----------------|-------------|----------------|--------------------------------------------|------------------------|------------------|-----|-----|-----------------------------------------------------------------------------------------------------------------|
| Lead (ppb)      | 6/16/2023   | 5              | 0.0134                                     | 1                      | NA               | 15  | 0.2 | Corrosion of household plumbing systems; Erosion of natural deposits                                            |
| Copper (ppm)    | 6/16/2023   | 5              | 0.286                                      | 0                      | NA               | 1.3 | 0.3 | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

**Table 3. Sampling Results for Sodium and Hardness**

| Chemical or Constituent (and reporting units) | Sample Date            | Level Detected | Range of Detections | MCL  | PHG (MCLG) | Typical Source of Contaminant                                                                                        |
|-----------------------------------------------|------------------------|----------------|---------------------|------|------------|----------------------------------------------------------------------------------------------------------------------|
| Sodium (ppm)<br>Well 3A & Well 7              | 9/10/2014<br>4/29/2005 | 37<br>24       | 24-37               | None | None       | Salt present in the water and is generally naturally occurring                                                       |
| Hardness (ppm)<br>Well 3A & Well 7            | 9/10/2014<br>4/29/2005 | 199<br>100     | 100 - 199           | None | None       | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard**

| <b>Chemical or Constituent<br/>(and reporting units)</b> | <b>Sample Date</b>                                | <b>Level Detected</b>        | <b>Range of Detections</b> | <b>MCL [MRDL]</b>                | <b>PHG (MCLG) [MRDLG]</b>         | <b>Typical Source of Contaminant</b>                                                        |
|----------------------------------------------------------|---------------------------------------------------|------------------------------|----------------------------|----------------------------------|-----------------------------------|---------------------------------------------------------------------------------------------|
| Arsenic (µg/L)<br><i>Well 3A &amp; Well 7</i>            | 10/24/2023<br>10/24/2023                          | 1.5<br>1.3                   | 1.3 - 1.5                  | 10<br>10                         | 0.004<br>0.004                    | Erosion of natural deposits: runoff from orchards: glass and electronics production wastes. |
| Barium (µg/L)<br><i>Well 3A &amp; Well 7</i>             | 10/24/2023<br>10/24/2023                          | 160<br>25                    | 25 - 160                   | 1,000<br>1,000                   | 200<br>200                        | Discharge of oil drilling wastes and from metal refineries: erosion of natural deposits.    |
| Chlorine (mg/L)                                          | 2025                                              | 1.14                         | NA                         | MRDL = 4.0 (as Cl <sub>2</sub> ) | MRDLG = 4.0 (as Cl <sub>2</sub> ) | Drinking water disinfection added for treatment.                                            |
| Chromium [Total] (µg/L)<br><i>Well 3A &amp; Well 7</i>   | 10/24/2023<br>10/24/2023                          | 2.4<br>9.5                   | 2.4 - 9.5                  | 50<br>50                         | 100<br>100                        | Discharge of steel and pulp mills and chrome plating: erosion of natural deposits.          |
| Gross Alpha Particle Activity (pCi/L)<br><i>Well 3A</i>  | 10/21/2025<br>7/22/2025<br>4/15/2025<br>1/23/2025 | 16.4<br>14.2<br>4.41<br>11.8 | 4.41 - 16.4                | 15<br>15                         | 0<br>0                            | Erosion of natural deposits.                                                                |
| Gross Alpha Particle Activity (pCi/L)<br><i>Well 7</i>   | 01/23/2025                                        | 7.33                         | NA                         | 15                               | 0                                 | Erosion of natural deposits.                                                                |
| Nickel (µg/L)<br><i>Well 3A</i>                          | 10/24/2023                                        | 5.8                          | NA                         | 100                              | 12                                | Erosion of natural deposits; discharge from metal factories                                 |

|                                                         |                                                   |                         |             |                              |                              |                                                                                                                                                                                 |
|---------------------------------------------------------|---------------------------------------------------|-------------------------|-------------|------------------------------|------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Nitrate (as N)<br>(mg/L)<br><i>Well 3A &amp; Well 7</i> | 10/21/2025<br>10/21/2025                          | 3.30<br>3.35            | 3.30 - 3.35 | 10<br>(as N)<br>10<br>(as N) | 10<br>(as N)<br>10<br>(as N) | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits                                                                     |
| Selenium (µg/L)<br><i>Well 3A</i>                       | 10/24/2023                                        | 2.2                     | NA          | 50                           | 30                           | Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive) |
| Uranium (pCi/L)<br><i>Well 3A</i>                       | 10/21/2025<br>7/22/2025<br>4/15/2025<br>1/23/2025 | 13<br>5.8<br>6.8<br>7.4 | 5.8 - 13    | 20                           | 0.43                         | Erosion of natural deposits                                                                                                                                                     |
| Uranium (pCi/L)<br><i>Well 7</i>                        | 1/23/2025                                         | 6                       | NA          | 20                           | 0.43                         | Erosion of natural deposits                                                                                                                                                     |

**Table 5. Detection of Contaminants with a Secondary Drinking Water Standard**

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | SMCL    | PHG (MCLG) | Typical Source of Contaminant         |
|-----------------------------------------------|-------------|----------------|---------------------|---------|------------|---------------------------------------|
| Odor - Threshold                              | 9/20/2017   | 1              | NA                  | 3 Units |            | Naturally-occurring organic materials |
| Total Dissolved Solids [TDS]                  | 5/9/2018    | 250            | NA                  | 1,000   |            | Runoff/leaching from natural deposits |

**Table 6. Detection of Unregulated Contaminants**

| <b>Chemical or Constituent (and reporting units)</b> | <b>Sample Date</b>                                             | <b>Level Detected</b>                                         | <b>Range of Detections</b> | <b>Notification Level</b> | <b>Health Effects</b>                                                                                   |
|------------------------------------------------------|----------------------------------------------------------------|---------------------------------------------------------------|----------------------------|---------------------------|---------------------------------------------------------------------------------------------------------|
| Perfluorohexanesulfonic acid (PFHxS)<br>Well 3A      | 11/5/2025<br>10/21/2025<br>7/22/2025<br>4/23/2025<br>2/19/2025 | 4.1 ng/L<br>11.0 ng/L<br>2.8 ng/L<br>3.4 ng/L<br>3.1 ng/L     | 2.8–11 ng/L                | 3.0 ng/L                  | Perfluorohexanesulfonic acid exposures resulted in decreased total thyroid hormone in male rats.        |
| Perfluorononanoic acid (PFNA)<br>Well 3A             | 11/5/2025<br>10/21/2025<br>7/22/2025<br>4/23/2025<br>2/19/2025 | 2.7 ng/L<br>6.8 ng/L<br>1.8 ng/L<br>2.1 ng/L<br>1.9 ng/L      | 1.8-6.8 ng/L               | None                      | None                                                                                                    |
| Perfluorooctanesulfonic acid (PFOS)<br>Well 3A       | 11/5/2025<br>10/21/2025<br>7/22/2025<br>4/23/2025<br>2/19/2025 | 21.0 ng/L<br>48.0 ng/L<br>11.0 ng/L<br>15.0 ng/L<br>14.0 ng/L | 14-48 ng/L                 | 4.0 ng/L                  | Perfluorooctanesulfonic acid exposures resulted in immune suppression and cancer in laboratory animals. |
| Perfluorooctanoic acid (PFOA)<br>Well 3A             | 11/5/2025<br>10/21/2025<br>7/22/2025<br>4/23/2025<br>2/19/2025 | 7.4 ng/L<br>15.0 ng/L<br>6.0 ng/L<br>7.0 ng/L<br>7.1 ng/L     | 6-15 ng/L                  | 4.0 ng/L                  | Perfluorooctanoic acid exposures resulted in increased liver weight and cancer in laboratory animals.   |
| Perfluorobutanoic acid (PFBA)<br>Well 3A             | 11/5/2025<br>10/21/2025<br>7/22/2025<br>4/23/2025<br>2/19/2025 | 3.3 ng/L<br>7.2 ng/L<br>2.1 ng/L<br>2.8 ng/L<br>2.3 ng/L      | 2.1-7.2 ng/L               | None                      | None                                                                                                    |
| Perfluorobutanesulfonic acid (PFBS)<br>Well 3A       | 10/21/2025                                                     | 3.0 ng/L                                                      | NA                         | 500 ng/L                  | Perfluorobutanesulfonic acid exposures resulted in decreased thyroid hormone in pregnant female mice.   |
| Perfluorohexanoic acid (PFHxA)<br>Well 3A            | 10/21/2025                                                     | 2.3 ng/L                                                      | NA                         | 1,000 ng/L                | None                                                                                                    |

|                                                       |                                                                |                                                          |              |          |                                                                                                         |
|-------------------------------------------------------|----------------------------------------------------------------|----------------------------------------------------------|--------------|----------|---------------------------------------------------------------------------------------------------------|
| Perfluorooctanesulfonic acid (PFOS)<br><i>Well 7</i>  | 11/5/2025<br>10/21/2025<br>7/22/2025<br>4/23/2025<br>2/19/2025 | 3.7 ng/L<br>4.8 ng/L<br>3.5 ng/L<br>4.9 ng/L<br>7.6 ng/L | 3.5-7.6 ng/L | 4.0 ng/L | Perfluorooctanesulfonic acid exposures resulted in immune suppression and cancer in laboratory animals. |
| Perfluorooctanoic acid (PFOA)<br><i>Well 7</i>        | 11/5/2025<br>10/21/2025<br>7/22/2025<br>4/23/2025<br>2/19/2025 | 2.8 ng/L<br>3.5 ng/L<br>2.8 ng/L<br>3.6 ng/L<br>5.9 ng/L | 2.8-5.9 ng/L | 4.0 ng/L | Perfluorooctanoic acid exposures resulted in increased liver weight and cancer in laboratory animals.   |
| Perfluorohexanesulfonic acid (PFHxS)<br><i>Well 7</i> | 7/22/2025<br>4/23/2025<br>2/19/2025                            | 1.8 ng/L<br>2.1 ng/L<br>2.8 ng/L                         | 1.8-2.8 ng/L | 3.0 ng/L | Perfluorohexanesulfonic acid exposures resulted in decreased total thyroid hormone in male rats.        |
| Perfluorobutanoic acid (PFBA)<br><i>Well 7</i>        | 2/19/2025                                                      | 1.9 ng/L                                                 | NA           | None     | None                                                                                                    |

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Fresno Wastewater Management Division - 1 Water System is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

State Revised Total Coliform Rule (RTCR): This Consumer Confidence Report (CCR) reflects changes in drinking water regulatory requirements during 2025. These revisions add the requirements of the federal Revised Total Coliform Rule, effective since April 1, 2016, to the existing state Total Coliform Rule. The revised rule maintains the purpose to protect public health by ensuring the integrity of the drinking water distribution system and monitoring for the presence of microbials (i.e., total coliform and *E. coli* bacteria). The U.S. EPA anticipates greater public health protection as the rule requires water systems that are vulnerable to microbial contamination to identify and fix problems. Water systems that exceed a specified frequency of total coliform occurrences are required to conduct an assessment to determine if any sanitary defects exist. If found, these must be corrected by the water system. The state Revised Total Coliform Rule became effective July 1, 2021.

### Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

**Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement**

| Violation   | Explanation | Duration | Actions Taken to Correct Violation | Health Effects Language |
|-------------|-------------|----------|------------------------------------|-------------------------|
| <i>None</i> |             |          |                                    |                         |

### For Water Systems Providing Groundwater as a Source of Drinking Water

**Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples**

| Microbiological Contaminants (complete if fecal-indicator detected) | Total No. of Detections | Sample Dates | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant |
|---------------------------------------------------------------------|-------------------------|--------------|------------|--------------------|-------------------------------|
| <i>None</i>                                                         |                         |              |            |                    |                               |

**Table 9. Violation of Groundwater TT**

| Violation   | Explanation | Duration | Actions Taken to Correct Violation | Health Effects Language |
|-------------|-------------|----------|------------------------------------|-------------------------|
| <i>None</i> |             |          |                                    |                         |

### Summary Information for Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

If a water system is required to comply with a Level 1 or Level 2 assessment requirement that is not due to an *E. coli* MCL violation, include the following information below [22 CCR section 64481(n)(1)].

**Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation**

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.