



## 2022 Consumer Confidence Report

Attached is Carriere Family Farms 2022 consumer Confidence Report in regard to our well water. We have only one well that supplies our amenities and it is tested monthly throughout the year. The water is tested for a wide range of contaminants and has been found safe to drink by USEPA and the California Department of Health.

This report is posted on each break room and the main office building for our employees and visitors' convenience. If additional information is needed, please follow up the reports instructions or contact Blanca Palomino for assistance.

Best regards,

Blanca Palomino-Carter  
QA & Logistics Manager  
530-934-8200

# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)  
(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at  
[http://www.swrcb.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name:	<b>CARRIERE FAMILY FARMS</b>
Water System Number:	<b>CA1100101</b>

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 4/5/2022 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Blanca Palomino-Carter	
	Signature:		
	Title:	QA & Logistics Manager	
	Phone Number:	( 530 ) 934-8200	Date: 4/5/2022

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:  
Posted in the break room areas of Carriere Family Farms and Main office buildings.

☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> \_\_\_\_\_
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> \_\_\_\_\_

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)



# 2021 Consumer Confidence Report

Water System Name: CARRIERE FAMILY FARMS

Report Date: April 2022

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2021.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 1 source(s):** Well 01

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings currently are not held as the water provided is to employees only. There is an open door policy if any employee has an questions.

For more information about this report, or any questions relating to your drinking water, please call (530)343-5105 and ask for Greg Lowe.

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**pCi/L:** picocuries per liter (a measure of radiation)

**NTU:** Nephelometric Turbidity Units

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.



### Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

**Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2019)	5	0.16	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2014)	22	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2014)	208	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2020)	2	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2020)	0.12	n/a	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits



Hexavalent Chromium (ug/L)	(2020)	6	n/a		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Fluoride (mg/L)	(2020)	0.1	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2021)	1.2	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2014)	1.04	n/a	15	(0)	Erosion of natural deposits.

**Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2014)	49	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2014)	512	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2014)	5.6	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2014)	290	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2014)	0.2	n/a	5	n/a	Soil runoff

**Table 5 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2014)	0.1	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

**Table 6 - ADDITIONAL DETECTIONS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2014)	42	n/a	n/a	n/a
Magnesium (mg/L)	(2014)	25	n/a	n/a	n/a
pH (units)	(2014)	7.5	n/a	n/a	n/a
Alkalinity (mg/L)	(2014)	200	n/a	n/a	n/a
Aggressiveness Index	(2014)	11.8	n/a	n/a	n/a
Langelier Index	(2014)	-0.02	n/a	n/a	n/a

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead Specific Language for Community Water Systems:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Carriere Family Farms* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## **2021 Consumer Confidence Report**

### **Drinking Water Assessment Information**

#### **Assessment Information**

A source water assessment was conducted for the WELL 01 of the CARRIERE FAMILY FARMS water system in September, 2015.

Well 01 - - is considered most vulnerable to the following activities not associated with any detected contaminants:

- Irrigated Crops
- Fertilizer/Pesticide/Herbicide Application
- Transportation Corridors (State Highway)
- Wells (Agriculture/Irrigation)

#### **Discussion of Vulnerability**

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

#### **Acquiring Information**

A copy of the complete assessment may be viewed at:

State Water Resources Control Board  
Division of Drinking Water  
364 Knollcrest Dr., Suite 101  
Redding, CA 96002

You may request a summary of the assessment be sent to you by contacting:

Daniel L. Cikuth, P.E.

Associate Sanitary Engineer

Phone: (530) 224-3271

Fax: (530) 224-4844

Email: [dan.cikuth@waterboards.ca.gov](mailto:dan.cikuth@waterboards.ca.gov)



## Carriere Family Farms

### Analytical Results By FGL - 2021

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
<b>Copper</b>		mg/L		1.3	.3			0.155	5
Bleacher Mens RR	CH 1977935-4	mg/L				2019-09-13	ND		
Borges Bleacher Break Room	CH 1977935-5	mg/L				2019-09-13	0.20		
Kernel Ladies RR	CH 1977935-1	mg/L				2019-09-13	ND		
Kernel Mens RR	CH 1977935-3	mg/L				2019-09-13	ND		
Main Office	CH 1977935-2	mg/L				2019-09-13	0.11		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Sodium</b>		mg/L		none	none			22	22 - 22
Well 01	CH 1475031-1	mg/L				2014-09-03	22		
<b>Hardness</b>		mg/L		none	none			208	208 - 208
Well 01	CH 1475031-1	mg/L				2014-09-03	208		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Arsenic</b>		ug/L		10	0.004			2	2 - 2
Well 01	CH 2072173-1	ug/L				2020-04-06	2		
<b>Barium</b>		mg/L	2	1	2			0.12	0.12 - 0.12
Well 01	CH 2072173-1	mg/L				2020-04-06	0.12		
<b>Hexavalent Chromium</b>		ug/L			0.02			6.0	6.0 - 6.0
Well 01	CH 2072173-1	ug/L				2020-04-06	6.0		
<b>Fluoride</b>		mg/L		2	1			0.1	0.1 - 0.1
Well 01	CH 2072173-1	mg/L				2020-04-06	0.1		
<b>Nitrate as N</b>		mg/L		10	10			1.2	1.2 - 1.2
Well 01	CH 2172089-1	mg/L				2021-04-05	1.2		
<b>Gross Alpha</b>		pCi/L		15	(0)			1.04	1.04 - 1.04
Well 01	CH 1475031-1	pCi/L				2014-09-03	1.04		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Chloride</b>		mg/L		500	n/a			49	49 - 49
Well 01	CH 1475031-1	mg/L				2014-09-03	49		
<b>Specific Conductance</b>		umhos/cm		1600	n/a			512	512 - 512
Well 01	CH 1475031-1	umhos/cm				2014-09-03	512		
<b>Sulfate</b>		mg/L		500	n/a			5.6	5.6 - 5.6
Well 01	CH 1475031-1	mg/L				2014-09-03	5.6		
<b>Total Dissolved Solids</b>		mg/L		1000	n/a			290	290 - 290
Well 01	CH 1475031-1	mg/L				2014-09-03	290		
<b>Turbidity</b>		NTU		5	n/a			0.2	0.2 - 0.2
Well 01	CH 1475031-1	NTU				2014-09-03	0.2		

UNREGULATED CONTAMINANTS										
			Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron			mg/L		NS	n/a			0.1	0.1 - 0.1
Well 01	CH 1475031-1		mg/L				2014-09-03	0.1		

## ADDITIONAL DETECTIONS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Calcium</b>		mg/L			n/a			42	42 - 42
Well 01	CH 1475031-1	mg/L				2014-09-03	42		
<b>Magnesium</b>		mg/L			n/a			25	25 - 25
Well 01	CH 1475031-1	mg/L				2014-09-03	25		
<b>pH</b>		units			n/a			7.5	7.5 - 7.5
Well 01	CH 1475031-1	units				2014-09-03	7.5		
<b>Alkalinity</b>		mg/L			n/a			200	200 - 200
Well 01	CH 1475031-1	mg/L				2014-09-03	200		
<b>Aggressiveness Index</b>					n/a			11.8	11.8 - 11.8
Well 01	CH 1475031-1					2014-09-03	11.8		
<b>Langelier Index</b>					n/a			-0.02	-0.02 - -0.02
Well 01	CH 1475031-1					2014-09-03	-0.02		



# Carriere Family Farms

## CCR Login Linkage - 2021

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Bidwell Water	CH 2175717-2	2021-07-19	Coliform	Bidwell Water	Carriere Family Farms
Bleacher Mens R	CH 1977935-4	2019-09-13	Metals, Total	Bleacher Mens RR	Lead & Copper Monitoring
Borges Bleacher	CH 1977935-5	2019-09-13	Metals, Total	Borges Bleacher Break Room	Lead & Copper Monitoring
Bacti-Rout-ss03	CH 2171393-1	2021-03-01	Coliform	Borges Plant-HB W.Side of Bldg	Routine Bacteriological -3
	CH 2173789-1	2021-06-08	Coliform	Borges Plant-HB W.Side of Bldg	Routine Bacteriological -3
	CH 2177558-1	2021-09-15	Coliform	Borges Plant-HB W.Side of Bldg	Routine Bacteriological -3
	CH 2179706-1	2021-12-06	Coliform	Borges Plant-HB W.Side of Bldg	Routine Bacteriological -3
Bacti-Rout-ss02	CH 2170564-1	2021-02-02	Coliform	Carriere Office-HBPatio/W.Side	Routine Bacteriological -2
	CH 2172658-1	2021-05-04	Coliform	Carriere Office-HBPatio/W.Side	Routine Bacteriological -2
	CH 2176412-1	2021-08-10	Coliform	Carriere Office-HBPatio/W.Side	Routine Bacteriological -2
	CH 2178891-1	2021-11-01	Coliform	Carriere Office-HBPatio/W.Side	Routine Bacteriological -2
Bacti-Rout-ss01	CH 2170050-1	2021-01-11	Coliform	Carriere Plant-HB SE Corner	Routine Bacteriological -1
	CH 2172090-1	2021-04-05	Coliform	Carriere Plant-HB SE Corner	Routine Bacteriological -1
	CH 2174917-1	2021-07-06	Coliform	Carriere Plant-HB SE Corner	Routine Bacteriological -1
	CH 2178765-1	2021-10-21	Coliform	Carriere Plant-HB SE Corner	Routine Bacteriological -1
Ice Machine	CH 2175717-3	2021-07-19	Coliform	Ice Machine	Carriere Family Farms
Kernel Ladies R	CH 1977935-1	2019-09-13	Metals, Total	Kernel Ladies RR	Lead & Copper Monitoring
Kernel Mens RR	CH 1977935-3	2019-09-13	Metals, Total	Kernel Mens RR	Lead & Copper Monitoring
Main Office	CH 1977935-2	2019-09-13	Metals, Total	Main Office	Lead & Copper Monitoring
WELL 01	CH 1475031-1	2014-09-03	Wet Chemistry	Well 01	Title 22 Monitoring
	CH 1475031-1	2014-09-03	Radio Chemistry	Well 01	Title 22 Monitoring
	CH 1475031-1	2014-09-03	General Mineral	Well 01	Title 22 Monitoring
	CH 2072173-1	2020-04-06	Wet Chemistry	Well 01	Water Quality Monitoring
	CH 2072173-1	2020-04-06	Metals, Total	Well 01	Water Quality Monitoring
	CH 2172089-1	2021-04-05	Wet Chemistry	Well 01	Water Quality Monitoring