#### THE PALISADES RV PARK

# 2024 Water Quality Consumer Confidence Report Public Water System Number 1100452

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

For additional information concerning your drinking water, contact **Dale Perryman** at (530) 691-2998

Water for the Palisades RV Park originates from one groundwater source known as new Well 01

## DEFINITIONS OF SOME OF THE TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is technologically, and economically feasible.

**Primary Drinking Water Standards (PDWS):** MCLs for Contaminants that affect health along with their monitoring and reporting requirements, and surface water treatment requirements.

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the Federal Environmental Protection Agency (USEPA).

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

pCi/L: picocuries per liter (a measure of radiation)

**ppb:** parts per billion or micrograms per liter **ppm:** parts per million or milligrams per liter

nd: non detectable at testing limitTDS: Total Dissolved Solids

## MICROBIOLOGICAL WATER QUALITY:

Testing for bacteriological Contaminants in the distribution system is required by State regulations. This testing is done regularly to verify that the water system is free from coliform bacteria. The minimum number of tests required per month is one. In our distribution system, we test the water once per month for coliform bacteria. The highest number of samples found to contain coliform bacteria during any one month was zero.

#### **DETECTED CONTAMINANTS IN OUR WATER:**

Table1. Samplir	ng Result	s Showing tl	ne Detection	of Lead a	nd Cop	per		
Lead and Copper	Sample Date	No. of Samples Collected	90th Percentile Level Detected	No. Sites Exceedi ng AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	2022	5	0	0	15	0.2	None	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	2022	5	0	0	1.3	0.3	N/A	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2. Sampling	Results 1	for Sodium an	d Hardness							
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	MCL	PHG	Typical Source of Contaminant					
Sodium (ppm)	2020	19	None	None	Salt present in the water and is generally naturally occurring					
Hardness (ppm)	2020	125	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring					
Table 3. Detection	of Conta	minants with a	Primary Dri	nking Wate	er Standard					
Chemical or Constituent (and Reporting Units)	Sample Date	Level Detected	MCL	PHG	Typical Source of Contaminant					
Gross Alpha Particle Activity (pCi/L)	2016	0.67	15	0	Erosion of natural deposits					
Nitrate (mg/L as N	2024	0.6	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits					
Table 4. Detection	of Conta	minants with a	Secondary	Drinking W	later Standar	d				
Chemical or Constituent (and	Sample Date	Level Detected	SMCL	Typical Source of Contaminant						
reporting units)										
Chloride (mg/L)	2020	17	500		unoff/leaching from natural deposits; awater influence					
Specific Conductance (µS/cm)	2020	370	1,600	Substances that form ions when in water; seawater influence						

#### GENERAL INFORMATION ON DRINKING WATER:

220

1 000

2020

2016

Total Dissolved

Solids [TDS] (mg/L)

Turbidity (units)

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at 1-800-426-4791.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems.

Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the State Water Resources Control Board (Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly individuals, and infants can be particularly at

risk from infections. These people should seek advice about drinking water from their health care providers. The USEPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

### Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Shady Oaks Trailer Park is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <a href="http://www.epa.gov/lead">http://www.epa.gov/lead</a>.

## **SOURCE WATER ASSESSMENT:**

A source water assessment has been completed for the well serving Shady Oaks Trailer Park. The source is considered most vulnerable to the following activities not associated with any detected contaminants:

High Density - Septic Systems

VIOLATION INCORMATIONS

A copy of the complete assessment may be viewed at the State Water Board, Division of Drinking Water Office 364 Knollcrest Drive, Suite 101 Redding, CA 96002 (530) 224-4800

VIOLATION IN CHINATION.		
Additional Information:		