

## 2023 Consumer Confidence Report

### Water System Information

Water System Name: **Gateway of Americas CSA CA1300018**

Report Date: **June 29, 2024**

Type of Water Source(s) in Use: **Colorado River surface water purchased from the Imperial Irrigation District.**

Name and General Location of Source(s): **Gateway of Americas receives all their source water from the Imperial Irrigation District via the Alamo Canal.**

Drinking Water Source Assessment Information: **A Watershed Sanitary Survey that included the IID's Alamo Canal, and its tributary, was completed in February 2021. A copy of the complete assessment is available at the Imperial County Division of Environmental Health – Local Primacy Agency at 797 Main Street, Suite B, El Centro, CA 92243. Phone: (442) 265-1888.**

Time and Place of Regularly Scheduled Board Meetings for Public Participation: **N/A**

For More Information, Contact: **Joseph G. Lechuga at (760)996-6775**

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2023 and may include earlier monitoring data.

### Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Gateway of Americas CSA a 1499 Gateway Rd. HWY 98 Calexico, Ca. (442)265-1818 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Gateway of Americas CSA 以获得中文的帮助: 1499 Gateway Rd. HWY 98 Calexico, Ca. (442)265-1818.

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Gateway of Americas CSA o tumawag sa 1499 Gateway Rd. HWY 98 Calexico, Ca. (442)265-1818 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Gateway of Americas CSA tại 1499 Gateway Rd. HWY 98 Calexico, Ca. (442)265-1818 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Gateway of Americas CSA ntawm 1499 Gateway Rd. HWY 98 Calexico, Ca. (442)265-1818 rau kev pab hauv lus Askiv.

## Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of disinfectant is allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
Ppm	parts per million or milligrams per liter (mg/L)
Ppb	parts per billion or micrograms per liter (µg/L)

Term	Definition
Ppt	parts per trillion or nanograms per liter (ng/L)
Ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

To ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the number of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## About Your Drinking Water Quality

### Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do

not change frequently. Some of the data, though representative of the water quality, is more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**Table 1. Sampling Results Showing the Detection of Coliform Bacteria**

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<b>Total Coliform Bacteria</b> (State Total Coliform Rule)	(In a month) <b>0</b>	<b>0</b>	<b>1 positive monthly sample <sup>(a)</sup></b>	<b>0</b>	Naturally present in the environment
<b>Fecal Coliform or <i>E. coli</i></b> (State Total Coliform Rule)	(In the year) <b>0</b>	<b>0</b>	<b>A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive</b>	<b>None</b>	Human and animal fecal waste
<b><i>E. coli</i></b> (Federal Revised Total Coliform Rule)	(In the year) <b>0</b>	<b>0</b>	<b>(b)</b>	<b>0</b>	Human and animal fecal waste

(a) Two or more positive monthly samples is a violation of the MCL

(b) Routine and repeat samples are total coliform-positive, and either is *E. coli*-positive, or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 <sup>th</sup> Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
<b>Lead (ppb)</b>	<b>7/20/22</b>	<b>20</b>	<b>ND</b>	<b>0</b>	<b>15</b>	<b>0.2</b>	<b>0</b>	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
<b>Copper (ppm)</b>	<b>7/20/22</b>	<b>20</b>	<b>0.21</b>	<b>0</b>	<b>1.3</b>	<b>0.3</b>	<b>Not applicable</b>	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 3. Sampling Results for Sodium and Hardness**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
<b>Sodium (ppm)</b>	<b>07/27/23</b>	<b>120</b>	<b>N/A</b>	<b>None</b>	<b>None</b>	Salt present in the water and is generally naturally occurring
<b>Hardness (ppm)</b>	<b>07/27/23</b>	<b>340</b>	<b>N/A</b>	<b>None</b>	<b>None</b>	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<b>Arsenic (As) in (ug/l)</b> <b>South Alamo Canal:</b>	<b>07/27/23</b>	<b>2.4</b>	<b>N/A</b>	<b>10</b>	<b>0.004</b>	Erosion of natural deposits; runoff from orchards; runoff from glass & electronics production wastes.
<b>Fluoride (F) in (mg/l)</b> <b>AAC Drop 4:</b> <b>South Alamo Canal:</b>	<b>07/27/23</b>	<b>0.40</b> <b>0.38</b>	<b>N/A</b>	<b>2.0</b>	<b>1</b>	Erosion of natural deposits; water additives that promotes strong teeth; discharge from fertilizer and aluminum factories.
<b>Barium (Ba) in (ug/l)</b> <b>AAC Drop 4:</b> <b>South Alamo Canal:</b>	<b>07/27/23</b>	<b>130</b> <b>130</b>	<b>N/A</b>	<b>1000</b>	<b>2000</b>	Discharge of oil drilling wastes and metal refineries; erosion from natural deposits.
<b>Gross Alpha Particles in (pCi/L)</b> <b>Gross Alpha Counting Error:</b> <b>Gross Alpha Min Det Activity:</b>	<b>07/27/23</b>	<b>ND</b> <b>0.61</b> <b>0.47</b>	<b>N/A</b>	<b>15</b>	<b>0</b>	Erosion of natural deposits of certain minerals that are radioactive and may emit a form of radiation known as alpha radiation.
<b>Uranium (U) in (pCi/L)</b>	<b>07/27/23</b>	<b>2.3</b>	<b>N/A</b>	<b>20</b>	<b>0.43</b>	Erosion of natural deposits; naturally occurring uranium has very low levels of radioactivity.
<b>Chromium (Total Cr) (µg/L)</b> <b>ACC Drop 4:</b> <b>South Alamo Canal:</b>	<b>7/27/23</b> <b>10/25/23*</b>	<b>170</b> <b>140</b> <b>Not Detected*</b>	<b>N/A</b>	<b>50</b>	<b>100</b>	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits. Some people who use water containing chromium in excess of the MCL over many years may experience allergic dermatitis.

<b>Total Trihalomethanes (ug/l)</b>	<b>2023 Quarterly</b>	<b>54.11</b>	<b>30–88.3</b>	<b>80</b>	<b>NA</b>	Byproducts of disinfection
<b>Halo acetic acids (ug/l)</b>	<b>2023 Quarterly</b>	<b>36.05</b>	<b>30.9–53.9</b>	<b>60</b>	<b>NA</b>	Byproducts of disinfection

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

<b>Chemical or Constituent (and reporting units)</b>	<b>Sample Date</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>SMCL</b>	<b>PHG (MCLG)</b>	<b>Typical Source of Contaminant</b>
<b>Color</b> (Color Units)	<b>07/27/23</b>	<b>10.0</b>	<b>N/A</b>	<b>15</b>	<b>N/A</b>	Naturally occurring organic material; deposits from leaching, minerals, ect.
<b>Odor Threshold</b> in (units)	<b>07/27/23</b>	<b>1</b>	<b>N/A</b>	<b>3</b>	<b>N/A</b>	Naturally – occurring organic material.
<b>Turbidity</b> in (NTU)	<b>07/27/23</b>	<b>5.9</b>	<b>N/A</b>	<b>5.0</b>	<b>N/A</b>	Soil Runoff / measures the cloudiness in water.
<b>Chloride</b> (Cl) in (mg/l)	<b>07/27/23</b>	<b>120</b>	<b>N/A</b>	<b>500</b>	<b>N/A</b>	Runoff / leaching from natural deposits; seawater influence.
<b>Specific Conductance</b> in (umhos/cm)	<b>07/27/23</b>	<b>1200</b>	<b>N/A</b>	<b>1600</b>	<b>N/A</b>	A measure of the ability of water to conduct an electrical current; varies with temperature.
<b>Sulfate</b> (SO4) in (mg/l)	<b>07/27/23</b>	<b>270</b>	<b>N/A</b>	<b>500</b>	<b>N/A</b>	Runoff / leaching from natural deposits; industrial wastes.
<b>Total Dissolved Solids</b> in (mg/l)	<b>07/27/23</b>	<b>720</b>	<b>N/A</b>	<b>1000</b>	<b>N/A</b>	Runoff / leaching from natural deposits.
<b>Aluminum</b> (Al) in (ug/l) <b>ACC Drop 4:</b>  <b>South Alamo Canal:</b>	<b>02/02/23</b> <b>07/27/23</b> <b>11/06/23</b>  <b>7/27/23</b> <b>10/25/23</b>	<b>50</b> <b>210</b> <b>76</b>  <b>100</b> <b>72</b>	<b>N/A</b>	<b>200</b>	<b>N/A</b>	Erosion of natural deposits; residual from some surface water treatment processes.
<b>Iron</b> (Fe) in (ug/l)	<b>01/27/22</b>	<b>200</b>	<b>N/A</b>	<b>300</b>	<b>N/A</b>	Leaching from natural deposits; industrial wastes.

**Table 6. Detection of Unregulated Contaminants**

<b>Chemical or Constituent (and reporting units)</b>	<b>Sample Date</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>Notification Level</b>	<b>Health Effects Language</b>
<b>Alkalinity</b> (CaCo <sub>3</sub> ) in (mg/l)	<b>07/27/23</b>	<b>160</b>	<b>N/A</b>	<b>N/A</b>	Alkalinity is a measure of the capacity of unfiltered water to neutralize acid.
<b>Bicarbonate</b> (HCO <sub>3</sub> ) in (mg/l)	<b>07/27/23</b>	<b>190</b>	<b>N/A</b>	<b>N/A</b>	Bicarbonate in combination with calcium and magnesium forms carbonate hardness.
<b>pH</b> (lab) in (pH units)	<b>07/27/23</b>	<b>8.1</b>	<b>N/A</b>	<b>N/A</b>	pH is a measure of the hydrogen ion concentration.
<b>Boron</b> (B) in (ug/l)	<b>07/27/23</b>	<b>180</b>	<b>N/A</b>	<b>1000</b>	The babies of some pregnant women who drink water containing boron more than the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.
<b>Calcium</b> (Ca) in (mg/l)	<b>07/27/23</b>	<b>86</b>	<b>N/A</b>	<b>N/A</b>	Calcium is naturally present in water. It may dissolve from rocks such as limestone, marble, calcite, dolomite, gypsum, fluorite, and apatite.
<b>Magnesium</b> (Mg) in (mg/l)	<b>07/27/23</b>	<b>30</b>	<b>N/A</b>	<b>N/A</b>	Magnesium is naturally present in water. It may dissolve from rocks such as limestone, marble, calcite, dolomite, gypsum, fluorite, and apatite.
<b>Potassium</b> (K) in (mg/l)	<b>07/27/23</b>	<b>5.7</b>	<b>N/A</b>	<b>N/A</b>	Potassium is normally found in drinking-water are generally low and do not pose health concerns.
<b>Vanadium</b> (V) in (Ug/l) <b>ACC Drop 4:</b>  <b>South Alamo Canal:</b>	<b>07/27/23</b>	<b>50</b>  <b>45</b>	<b>N/A</b>	<b>N/A</b>	Vanadium is a naturally occurring element that is widely distributed in the environment. It is found in many foods, typically in small amounts. You cannot avoid exposure to vanadium. Exposure to the levels of vanadium that are naturally present in food and water are not considered to be harmful.

**Additional General Information on Drinking Water**

Drinking water, including bottled water, may be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Gateway of Americas CSA is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*:

Federal Revised Total Coliform Rule (RTCR):

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language

For Water Systems Providing Groundwater as a Source of Drinking Water

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples



Microbiological Contaminants (complete if fecal indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>			0	(0)	Human and animal fecal waste
Enterococci			TT	N/A	Human and animal fecal waste
Coliphage			TT	N/A	Human and animal fecal waste

**Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT**

**Special Notice of Fecal Indicator-Positive Groundwater Source Sample: N/A**

**Special Notice for Uncorrected Significant Deficiencies: N/A**

**Table 9. Violation of Groundwater TT**

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language

**For Systems Providing Surface Water as a Source of Drinking Water**

**Table 10. Sampling Results Showing Treatment of Surface Water Sources**

Treatment Technique <sup>(a)</sup> (Type of approved filtration technology used)	<b>ALTERNATIVE FILTRATION TECHNOLOGY PV-150 &amp; PV-105</b>
Turbidity Performance Standards <sup>(b)</sup> (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to <b>0.30</b> NTU in 95% of measurements in a month. 2 – Not exceed <b>1.0</b> NTU for more than eight consecutive hours. 3 – Not exceed <b>1.0</b> NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	<b>100%</b>
Highest single turbidity measurement during the year	<b>0.17</b>

Number of violations of any surface water treatment requirements	0
--	---

- (a) A required process intended to reduce the level of a contaminant in drinking water.
- (b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a Surface Water TT

Table 11. Violation of Surface Water TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language

Summary Information for Operating Under a Variance or Exemption

Summary Information for Federal Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct 0 Level 1 assessment(s). 0 Level 1 assessment(s) were completed. In addition, we were required to take zero corrective actions and we completed none of these actions.

During the past year 0 Level 2 assessments were required to be completed for our water system. 0 Level 2 assessments were completed. In addition, we were required to take zero corrective actions and we completed zero of these actions.

**Level 2 Assessment Requirement Due to an *E. coli* MCL Violation**

*E. coli* are bacteria whose presence indicates that the water may be contaminated with human or animal waste. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

We were required to complete a Level 2 assessment because we found *E. coli* in our water system. In addition, we were required to take zero corrective actions and we completed zero of these actions.

## ATTACHMENT 7

### Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)


(to certify electronic delivery of the CCR, use the certification form on the State Board's website at [http://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name: Gateway of Americas CSA

Water System Number: 1300018

The water system named above hereby certifies that its Consumer Confidence Report was distributed on July 19, 2022 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: Joseph G. Lechuga

Signature: 

Title: Area Operation Manager

Phone Number: (760) 996-6775

Date: 10-01-2024

*To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:*

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: \_\_\_\_\_

☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

☒ Posting the CCR on the Internet at [www.co.imperial.ca.us](http://www.co.imperial.ca.us)

☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)

☐ Advertising the availability of the CCR in news media (attach copy of press release)

☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)

☐ Posted the CCR in public places (attach a list of locations)

☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools

☐ Delivery to community organizations (attach a list of organizations)

☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.

☐ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

*This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.*