2023 Consumer Confidence Report

Water System Information

Water System Name: Desert Research & Extension Center, University of California

Report Date: July 1, 2024

Type of Water Source(s) in Use: Surface Water

Name and General Location of Source(s): *Imperial Irrigation District – All American Canal (IID-AAC)*

Drinking Water Source Assessment Information: The Imperial Irrigation District (IID) annually coordinates with a state certified laboratory for the collection and analysis of Title 22 (of the California Code of Regulations) source water samples as a service to local public water treatment systems to facilitate the annual production of Consumer Confidence Reports. The All-American Canal and three main supply canals (East Highline, Central Main, and Westside Main) are sampled each year for numerous constituents as required by law and in coordination with the State Water Resources Control Board. The Desert Research & Extension Center domestic water system is supplied by the All-American Canal Drop 4.

A watershed sanitary survey of IID's canal system was updated in December 2020. A copy of the assessment is available at the State Water Resources Control Board, Division of Drinking Water (DDW), 1350 Front St., Rm 2050, San Diego, CA 92101. You may request a summary of the assessment by calling the DDW at (619) 525-4159 or by Fax number (619) 525-4383. The Survey indicated source water is most vulnerable to uncontrolled disposal of waste products, irrigation seepage and flow, aerial pesticide application, and accidental chemical spills.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Not Applicable.

For More Information, Contact: David Preciado, (760) 356-3060.

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2023 and may include earlier monitoring data.

Importance of This Report Statement in Spanish (Español)

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse *Desert Research & Extension Center a (760) 356-3060* para asistirlo en español.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (μg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
E. coli	(In the year) 0	0	(a)	0	Human and animal fecal waste.

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	рнс	Typical Source of Contaminant
Lead (ppb)	08/05/23	6	ND	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.
Copper (ppm)	08/05/23	6	0.0374	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

Table 3.	Sampling	Results	for Sodium	and Hardness
----------	----------	---------	------------	--------------

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	07/27/23	120	N/A	None	None	Salt present in the water and is generally naturally occurring. (No drinking water standards for this constituent, reported for consumer information.)

Hardness, Total (as CaCO3) (ppm)	07/27/23	340	N/A	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring. (No drinking water standards for this
						constituent, reported for consumer information.)

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Aluminum (ppm)	01/25/23 04/26/23 07/27/23 10/25/23	50 ND 210 76	ND-210	200	N/A	Erosion of natural deposits; residue from some surface water treatment processes.
Barium (ppm)	07/27/23	130	N/A	1000	2000	Discharge of drilling waste; discharge from metal refineries; erosions of natural deposits.
Chromium (total) (ppb)	07/27/23 10/25/23	170 ND	ND-170	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits.
Fluoride (ppm)	07/27/23	0.40	N/A	2.0	1	Water additive which promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories.
Total Trihalomethanes (TTHM) (ppb)	03/13/23 06/13/23 07/27/23 09/11/23 12/04/23	16.2 (Locational Running Annual Average)	ND-30	80	N/A	Byproducts of disinfection.

Haloacetic Acids (HAA5) (ppb)	03/13/23 06/13/23 07/27/23 09/11/23 12/04/23	37.8 (Locational Running Annual Average)	ND-62	60	N/A	Byproducts of disinfection.
Turbidity (NTU)	07/27/23	5.9	N/A	5	N/A	Soil runoff.

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Apparent Color (color units)	07/27/23	10	N/A	15	N/A	Naturally occurring organic materials.
Chloride (ppm)	07/27/23	120	N/A	500	N/A	Leaching from PVC piping; discharge from plastics factories; biodegradation byproduct of TCE and PCE groundwater contamination.
Iron (ppb)	01/25/23 04/26/23 07/27/23 10/25/23	ND ND 200 ND	ND-200	300	N/A	Leaching from natural deposits; industrial wastes.
Manganese (Mn) (ppm)	07/27/23	ND		50		Leaching from natural deposits.
Odor Threshold (TON)	07/27/23	1	N/A	3	N/A	Naturally-occurring organic materials.
Specific Conductance (umhos/cm)	07/27/23	1200	N/A	1600	N/A	Substances that form ions when in water; seawater influence.
Sulfate (SO4) (ppm)	07/27/23	270	N/A	500	N/A	Runoff/leaching from natural deposits; industrial wastes.
Total Filterable Residue/TDS (ppm)	07/27/23	720	N/A	1000	N/A	Runoff/leaching from natural deposits; industrial wastes.

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Boron (ppb)	07/27/23	180	N/A	1000	The babies of some pregnant women who drink water containing Boron in excess of notification level may have increased risk of development effects, based on studies of laboratory animals

Table 6. Detection of Unregulated Contaminants

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. <u>UC Desert REC</u> is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <u>http://www.epa.gov/lead</u>.

This Consumer Confidence Report (CCR) reflects changes in drinking water regulatory requirements during 2021. These revisions add the requirements of the federal Revised Total Coliform Rule, effective since April 1, 2016, to the existing state Total Coliform Rule. The revised rule maintains the purpose to protect public health by ensuring the integrity of the drinking water distribution system and monitoring for the presence of microbials (i.e., total coliform and E. coli bacteria). The U.S. EPA anticipates greater public health protection as the rule requires water systems that are vulnerable to microbial contamination to identify and fix problems. Water systems that exceed a specified frequency of total coliform occurrences are required to conduct an assessment to determine if any

sanitary defects exist. If found, these must be corrected by the water system. The state Revised Total Coliform Rule became effective July 1, 2021.

Sampling Results Showing Treatment of Surface Water Sources

Treatment Technique ^(a) (Type of approved filtration technology used)	Alternative Filtration Technology
Turbidity Performance Standards ^(b)	Turbidity of the filtered water must:
(that must be met through the water treatment process)	1 – Be less than or equal to 0.1 NTU in 95% of measurements in a month.
	2 – Not exceed 0.5 NTU for more than eight consecutive hours.
	3 – Not exceed 1 NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	100%
Highest single turbidity measurement during the year	0.0778
Number of violations of any surface water treatment requirements	0

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

For Additional Information on the UC Desert Research and Extension Center Water System, Contact: *David Preciado, (760) 356-3060.*

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse *Desert Research & Extension Center a (760) 356-3060* para asistirlo en español.