

**Consumer Confidence Report
Certification Form**
(to be submitted with a copy of the CCR)

(To certify electronic delivery of the CCR, use the certification form on the State Board's website at
http://www.swrcb.ca.gov/drinking_water/certific/drinkingwater/CCR.shtml)

Water System Name: Earthrise Nutritionals, LLC Water System

Water System Number: 1300676

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/24/2020 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: Manuel M. Sanchez

Signature: _____

Title: Chief Plant Operator

Phone Number: (760) 259-3834

Date: 6/24/2020

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: Posted at Main Office and Lunch Room

☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

- ☐ Posting the CCR on the Internet at www.
- ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertising the availability of the CCR in news media (attach copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
- ☒ Posted the CCR in public places (**Main Office and Employee Lunch Room**)
- ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience for use to meet the certification requirement of the California Code of Regulations, section 64483(c).

2019 Consumer Confidence Report

Water System Name: Earthrise Nutritionals, LLC #1300676 Report Date: 6/24/2020

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2019 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Surface water, Colorado River

Name & general location of source(s): Raw water originates from the Colorado River which diverted through the All American Canal and then delivered through the East Highland Canal to the I lateral to the site of the water treatment plant, Canal #1 Gate 001A, field #6964.

Drinking Water Source Assessment information: Information acquired from Imperial Valley Joint Watershed IID Title 22 analytical testing 2019. Also, assessment conducted by ICPHD on May 2003.

Time and place of regularly scheduled board meetings for public participation: Earthrise Nutritionals, LLC performs Bi-weekly Management meetings on Fridays at 8:00 am at the main office.

For more information, contact: Manuel M. Sanchez Phone: (760) 259-3834

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a mo.)	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year)	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive	0	Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(from 1/1/19-12/31/19)	0	(a)	0	Human and animal fecal waste
(a) Routine and repeat samples are total coliform-positive and either is <i>E. coli</i> -positive or system fails to take repeat samples following <i>E. coli</i> -positive routine sample or system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> .					

** Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.*

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of samples collected	90th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	8/28/18	5	1.3	None	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppb)	8/28/18	5	590	None	1300	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Location	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	East Highline Canal	10/24/19	150	2.0	none	none	Salt present in the water and is generally naturally occurring
	Vail Lat 4 Gate 416A	07/25/19	100				
Hardness (ppm)	East Highline Canal	10/24/19	370	N/A	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring
	Vail Lat 4 Gate 416A	07/25/19	300				

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Inorganic Contaminants							
Chemical or Constituent (and reporting units)	Sample Location	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Aluminum (ug/L)	East Highline Canal	4 quarterly samples in 2019	340*	230-1700	200	600	Erosion of natural deposits; residue from some surface water treatment process.
	Vail Lat 4 Gate 416A	07/25/19	310*	320-1200			
Arsenic (ug/L)	East Highline Canal	10/24/19	2.0	N/A	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes.
	Vail Lat 4 Gate 416A	07/25/19	3.2				
Barium (ug/L)	East Highline Canal	10/24/19	110	N/A	1000	2000	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits.
	Vail Lat 4 Gate 416A	07/25/19	120				
Fluoride (mg/L)	East Highline Canal	10/24/19	0.48	N/A	2	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
	Vail Lat 4 Gate 416A	07/25/19	0.37				

Gross Alpha (pCi/L)	10/29/'19	3.2 ± 0.83	3.0	15	0	Erosion of natural deposits.
Uranium (pCi/L)	10/29/'19	2.7 ± 0.89	n/a	20	0.43	Erosion of natural deposits.

Volatile Organic Contaminants

Dichloro-methane (ug/L)	East Highline Canal	10/24/19	ND	N/A	5	4	Discharge from pharmaceutical and chemical factories; insecticides.
	Vail Lat 4 Gate 416A	4 quarterly samples in 2019	ND	0.50 – 0.97			

Disinfection Byproducts, Disinfectant Residuals, and Disinfection Byproduct Precursors

TTHM's (ug/L)	9/17/19	45	47-52	80	N/A	By-product of drinking water disinfection
HAA5's (ug/L)	9/17/19	19	7.5-9.0	60	N/A	By-product of drinking water disinfection

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Location	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Color (Units)	East Highline Canal	10/24/19	10	N/A	15	N/A	Naturally occurring organic materials
	Vail Lat 4 Gate 416A	07/25/19	15*	N/A			
Iron	East Highline Canal	4 quarterly samples in 2018	420*	330-2300	300	N/A	Leaching from natural deposits; industrial wastes
	Vail Lat 4 Gate 416A	07/25/19	440*	280-1200			
Odor-Threshold (TON)	East Highline Canal	10/24/19	2	N/A	3	N/A	Naturally occurring organic materials
	Vail Lat 4 Gate 416A	07/25/19	2				
Turbidity (Units)	East Highline Canal	10/24/19	4.3	N/A	5	N/A	Soil runoff
	Vail Lat 4 Gate 416A	07/25/19	31*				
Total Dissolved Solids (TDS)(mg/L)	East Highline Canal	10/24/19	770	N/A	1000	N/A	Runoff/leaching from natural deposits
	Vail Lat 4 Gate 416A	07/25/19	650				
Specific Conductance (uS/cm)	East Highline Canal	10/24/19	1200	N/A	1600	N/A	Substances that form ions when in water; seawater influence
	Vail Lat 4 Gate 416A	07/25/19	1000				

* Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

Chloride (mg/L)	East Highline Canal	10/24/19	130	N/A	500	N/A	Runoff/leaching from natural deposits; seawater influence
	Vail Lat 4 Gate 416A	07/25/19	100				
Manganese (mg/L)	East Highline Canal	10/24/19	25	N/A	50	N/A	Leaching from natural deposits
	Vail Lat 4 Gate 416A	07/25/19	28				
Sulfate (mg/L)	East Highline Canal	10/24/19	290	N/A	500	N/A	Runoff/leaching from natural deposits; industrial wastes
	Vail Lat 4 Gate 416A	07/25/19	250				

* Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Location	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Vanadium (ug/L)	East Highline Canal	10/24/19	3.1	N/A	50	Vanadium exposures resulted in developmental and reproductive effects in rats.
	Vail Lat 4 Gate 416A	07/25/19	5.9			
Boron (ug/L)	East Highline Canal	10/24/19	230	N/A	1000	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
	Vail Lat 4 Gate 416A	07/25/19	180			

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Earthrise Nutritionals, LLC (#1300676) is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can

take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4701) or at <http://www.epa.gov/lead>.

Raw (source) water from IID exceeded Secondary Maximum Contaminant Level (MCL) for Aluminum, Color, Iron, Turbidity and Manganese. The primary MCL was exceeded for Aluminum and Turbidity.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
None				
None				

For Systems Providing Surface Water as a Source of Drinking Water

TABLE 8 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES	
Treatment Technique ^(a) (Type of approved filtration technology used)	PV50 (2) Approved alternative filtration technology.
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to 0.15 NTU in 95% of measurements in a month. 2 – Not exceed 0.25 NTU for more than eight consecutive hours. 3 – Not exceed 0.5 NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	January 2019
Highest single turbidity measurement during the year	December 6, 2019; NTU 0.18
Number of violations of any surface water treatment requirements	0

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a Surface Water TT

VIOLATION OF A SURFACE WATER TT				
TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
None				
None				
None				

Summary Information for Operating Under a Variance or Exemption

Summary Information for Federal Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year Zero Level 1 and Level 2 assessments were required to be completed for our water system.

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

During the past year Zero Level 2 assessments required due to *E. coli* were required to be completed for our water system.
