

APPENDIX B: eCCR Certification Form (Suggested Format)

Consumer Confidence Report Certification Form

(To be submitted with a copy of the CCR)

Water System Name:	CALIPATRIA STATE PRISON
Water System Number:	CA1310800

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6-22-2022 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by:

Name: Rodney S. Gaddis	Title: Chief Operator
Signature:	Date: 6-23-2022
Phone number: (760) 348-7000 ext. 7125	blank

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- ☐ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- ☐ CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- ☐ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - ☐ Posting the CCR at the following URL: www._____
 - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - ☒ Posted the CCR in public places (see attached list)

- ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
- ☐ Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
- ☐ Other (attach a list of other methods used)
- ☐ *For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following URL: www._____
- ☐ *For privately-owned utilities:* Delivered the CCR to the California Public Utilities Commission

Consumer Confidence Report Electronic Delivery Certification

Water systems utilizing electronic distribution methods for CCR delivery must complete this page by checking all items that apply and fill-in where appropriate.

- ☐ Water system mailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available website where it can be viewed (attach a copy of the mailed CCR notification). URL: www._____
- ☐ Water system emailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed (attach a copy of the emailed CCR notification). URL: www._____
- ☐ Water system emailed the CCR as an electronic file email attachment.
- ☐ Water system emailed the CCR text and tables inserted or embedded into the body of an email, not as an attachment (attach a copy of the emailed CCR).
- ☐ *Requires prior DDW review and approval.* Water system utilized other electronic delivery method that meets the direct delivery requirement.

Provide a brief description of the water system's electronic delivery procedures and include how the water system ensures delivery to customers unable to receive electronic delivery.

*This form is provided as a convenience and may be used to meet the certification
requirement of
section 64483(c) of the California Code of Regulations.*

CALIPATRIA STATE PRISON
2022 POSTING LOCATIONS
For 2021 CCR

<u>POSTING LOCATIONS</u>		<u>DATE POSTED</u>	<u>CCR POSTED BY</u>
1. Water Treatment Plant / Bldg # 210	Office Bulletin Board	6/22/22	C. Alfaro ✓
2. Water Treatment Plant / Bldg # 212	Chemical Room Bulletin Board	6/22/22	C. Alfaro ✓
3. Warehouse / Bldg. # 700 NORTH	Bulletin Board	6/22/22	C. Alfaro ✓
4. Mail Room / Bldg. # 700 SOUTH	Bulletin Board	6/22/22	C. Alfaro ✓
5. State Garage Bldg. # 553	Bulletin Board	6/22/22	C. Alfaro ✓
6. Fire Station Bldg. # 701	Bulletin Board	6/22/22	C. Alfaro ✓
7. Administration Building / Bldg. # 800	Bulletin Board	6/22/22	C. Alfaro ✓
8. Administration Building / Bldg. # 800	Staff Lunch Area	6/22/22	C. Alfaro ✓
9. Main Staff & Visitor Entrance / Bldg. # 805	Bulletin Board	6/22/22	C. Alfaro ✓
10. Sallyport (Vehicle Entrance) / Bldg. # 806	Bulletin Board	6/22/22	C. Alfaro ✓
11. Infirmary / Bldg. # 461	Bulletin Board	6/22/22	C. Alfaro ✓
12. Level One / Bldg. # 903	Programming Office Bulletin Board	6/22/22	C. Alfaro ✓
13. Level One / Bldg. # 905	Visiting Area Bulletin Board	6/22/22	C. Alfaro ✓
14. Level One / Bldg. # 901	Dorm 1 Bulletin Board	6/22/22	C. Alfaro ✓
15. Level One / Bldg. # 902	Dorm 2 Bulletin Board	6/22/22	C. Alfaro ✓
16. Facility "A" / Bldg. # 421	Programming Office Bulletin Board	6/22/22	C. Alfaro ✓
17. Facility "A" / Bldg. # 430	Visiting Area Bulletin Board	6/22/22	C. Alfaro ✓
18. Facility "A" / Bldg. # 325	Housing Unit 1 Bulletin Board	6/22/22	C. Alfaro ✓
19. Facility "A" / Bldg. # 324	Housing Unit 2 Bulletin Board	6/22/22	C. Alfaro ✓
20. Facility "A" / Bldg. # 323	Housing Unit 3 Bulletin Board	6/22/22	C. Alfaro ✓
21. Facility "A" / Bldg. # 322	Housing Unit 4 Bulletin Board	6/22/22	C. Alfaro ✓
22. Facility "A" / Bldg. # 321	Housing Unit 5 Bulletin Board	6/22/22	C. Alfaro ✓
23. Facility "B" / Bldg. # 431	Programming Office Bulletin Board	6/22/22	C. Alfaro ✓
24. Facility "B" / Bldg. # 430	Visiting Area Bulletin Board	6/22/22	C. Alfaro ✓
25. Facility "B" / Bldg. # 335	Housing Unit 1 Bulletin Board	6/22/22	C. Alfaro ✓
26. Facility "B" / Bldg. # 334	Housing Unit 2 Bulletin Board	6/22/22	C. Alfaro ✓
27. Facility "B" / Bldg. # 333	Housing Unit 3 Bulletin Board	6/22/22	C. Alfaro ✓
28. Facility "B" / Bldg. # 332	Housing Unit 4 Bulletin Board	6/22/22	C. Alfaro ✓
29. Facility "B" / Bldg. # 331	Housing Unit 5 Bulletin Board	6/22/22	C. Alfaro ✓
30. Plant Operation Office "B" / Bldg. # 551	Office Bulletin Board	6/22/22	C. Alfaro ✓
31. Facility "C" / Bldg. # 441	Programming Office Bulletin Board	6/22/22	C. Alfaro ✓
32. Facility "C" / Bldg. # 440	Visiting Area Bulletin Board	6/22/22	C. Alfaro ✓
33. Facility "C" / Bldg. # 345	Housing Unit 1 Bulletin Board	6/22/22	C. Alfaro ✓
34. Facility "C" / Bldg. # 344	Housing Unit 2 Bulletin Board	6/22/22	C. Alfaro ✓
35. Facility "C" / Bldg. # 343	Housing Unit 3 Bulletin Board	6/22/22	C. Alfaro ✓
36. Facility "C" / Bldg. # 342	Housing Unit 4 Bulletin Board	6/22/22	C. Alfaro ✓
37. Facility "C" / Bldg. # 341	Housing Unit 5 Bulletin Board	6/22/22	C. Alfaro ✓
38. Facility "D" / Bldg. # 451	Programming Office Bulletin Board	6/22/22	C. Alfaro ✓
39. Facility "D" / Bldg. # 440	Visiting Area Bulletin Board	6/22/22	C. Alfaro ✓
40. Facility "D" / Bldg. # 355	Housing Unit 1 Bulletin Board	6/22/22	C. Alfaro ✓
41. Facility "D" / Bldg. # 354	Housing Unit 2 Bulletin Board	6/22/22	C. Alfaro ✓
42. Facility "D" / Bldg. # 353	Housing Unit 3 Bulletin Board	6/22/22	C. Alfaro ✓
43. Facility "D" / Bldg. # 352	Housing Unit 4 Bulletin Board	6/22/22	C. Alfaro ✓
44. Facility "D" / Bldg. # 351	Housing Unit 5 Bulletin Board	6/22/22	C. Alfaro ✓
45. ASU / Bldg. # 360	Programming Office Bulletin Board	6/22/22	C. Alfaro ✓
46. Accounting Office / Bldg. 512	Office Bulletin Board	6/22/22	C. Alfaro ✓

By 

2021 Consumer Confidence Report

Water System Information

Water System Name: Calipatria State Prison System # 1310800

Report Date: 06/06/22

Type of Water Source(s) in Use: Treated Potable Water

Name and General Location of Source(s): Golden State Water Company Located in Calipatria, Ca.

Drinking Water Source Assessment Information: The drinking water assessment information can be obtained from Golden State Water Company

Time and Place of Regularly Scheduled Board Meetings for Public Participation: N/A (State Prison)

For More Information, Contact: David Chase, CPM II (760) 348-7000 Ext. 5905

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2021 and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Calipatria State Prison a (760) 348-7000 Ext. 5905 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Calipatria State Prison 以获得中文的帮助: (760) 348-7000 Ext. 5905

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Calipatria State Prison o tumawag sa (760) 348-7000 Ext. 5905 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Calipatria State Prison tại (760) 348-7000 Ext. 5905 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Calipatria State Prison ntawm (760) 348-7000 Ext. 5905 rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)

Term	Definition
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

APPENDIX B: eCCR Certification Form (Suggested Format)


Consumer Confidence Report Certification Form

(To be submitted with a copy of the CCR)

Water System Name:	CALIPATRIA STATE PRISON
Water System Number:	CA1310800

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6-22-2022 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by:

Name: Rodney S. Gaddis	Title: Chief Operator
Signature: 	Date: 6-23-2022
Phone number: (760) 348-7000 ext. 7125	blank

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- ☐ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- ☐ CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- ☐ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - ☐ Posting the CCR at the following URL: www._____
 - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - ☒ Posted the CCR in public places (see attached list)

- ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
- ☐ Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
- ☐ Other (attach a list of other methods used)
- ☐ *For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following URL: www._____
- ☐ *For privately-owned utilities:* Delivered the CCR to the California Public Utilities Commission

Consumer Confidence Report Electronic Delivery Certification

Water systems utilizing electronic distribution methods for CCR delivery must complete this page by checking all items that apply and fill-in where appropriate.

- ☐ Water system mailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available website where it can be viewed (attach a copy of the mailed CCR notification). URL: www._____
- ☐ Water system emailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed (attach a copy of the emailed CCR notification). URL: www._____
- ☐ Water system emailed the CCR as an electronic file email attachment.
- ☐ Water system emailed the CCR text and tables inserted or embedded into the body of an email, not as an attachment (attach a copy of the emailed CCR).
- ☐ *Requires prior DDW review and approval.* Water system utilized other electronic delivery method that meets the direct delivery requirement.

Provide a brief description of the water system's electronic delivery procedures and include how the water system ensures delivery to customers unable to receive electronic delivery.

CALIPATRIA STATE PRISON
2022 POSTING LOCATIONS
For 2021 CCR

<u>POSTING LOCATIONS</u>		<u>DATE POSTED</u>	<u>CCR POSTED BY</u>
1. Water Treatment Plant / Bldg # 210	Office Bulletin Board	6/22/22	C. Alfaro ✓
2. Water Treatment Plant / Bldg # 212	Chemical Room Bulletin Board	6/22/22	C. Alfaro ✓
3. Warehouse / Bldg. # 700 NORTH	Bulletin Board	6/22/22	C. Alfaro ✓
4. Mail Room / Bldg. # 700 SOUTH	Bulletin Board	6/22/22	C. Alfaro ✓
5. State Garage Bldg. # 553	Bulletin Board	6/22/22	C. Alfaro ✓
6. Fire Station Bldg. # 701	Bulletin Board	6/22/22	C. Alfaro ✓
7. Administration Building / Bldg. # 800	Bulletin Board	6/22/22	C. Alfaro ✓
8. Administration Building / Bldg. # 800	Staff Lunch Area	6/22/22	C. Alfaro ✓
9. Main Staff & Visitor Entrance / Bldg. # 805	Bulletin Board	6/22/22	C. Alfaro ✓
10. Sallyport (Vehicle Entrance) / Bldg. # 806	Bulletin Board	6/22/22	C. Alfaro ✓
11. Infirmary / Bldg. # 461	Bulletin Board	6/22/22	C. Alfaro ✓
12. Level One / Bldg. # 903	Programming Office Bulletin Board	6/22/22	C. Alfaro ✓
13. Level One / Bldg. # 905	Visiting Area Bulletin Board	6/22/22	C. Alfaro ✓
14. Level One / Bldg. # 901	Dorm 1 Bulletin Board	6/22/22	C. Alfaro ✓
15. Level One / Bldg. # 902	Dorm 2 Bulletin Board	6/22/22	C. Alfaro ✓
16. Facility "A" / Bldg. # 421	Programming Office Bulletin Board	6/22/22	C. Alfaro ✓
17. Facility "A" / Bldg. # 430	Visiting Area Bulletin Board	6/22/22	C. Alfaro ✓
18. Facility "A" / Bldg. # 325	Housing Unit 1 Bulletin Board	6/22/22	C. Alfaro ✓
19. Facility "A" / Bldg. # 324	Housing Unit 2 Bulletin Board	6/22/22	C. Alfaro ✓
20. Facility "A" / Bldg. # 323	Housing Unit 3 Bulletin Board	6/22/22	C. Alfaro ✓
21. Facility "A" / Bldg. # 322	Housing Unit 4 Bulletin Board	6/22/22	C. Alfaro ✓
22. Facility "A" / Bldg. # 321	Housing Unit 5 Bulletin Board	6/22/22	C. Alfaro ✓
23. Facility "B" / Bldg. # 431	Programming Office Bulletin Board	6/22/22	C. Alfaro ✓
24. Facility "B" / Bldg. # 430	Visiting Area Bulletin Board	6/22/22	C. Alfaro ✓
25. Facility "B" / Bldg. # 335	Housing Unit 1 Bulletin Board	6/22/22	C. Alfaro ✓
26. Facility "B" / Bldg. # 334	Housing Unit 2 Bulletin Board	6/22/22	C. Alfaro ✓
27. Facility "B" / Bldg. # 333	Housing Unit 3 Bulletin Board	6/22/22	C. Alfaro ✓
28. Facility "B" / Bldg. # 332	Housing Unit 4 Bulletin Board	6/22/22	C. Alfaro ✓
29. Facility "B" / Bldg. # 331	Housing Unit 5 Bulletin Board	6/22/22	C. Alfaro ✓
30. Plant Operation Office "B" / Bldg. # 551	Office Bulletin Board	6/22/22	C. Alfaro ✓
31. Facility "C" / Bldg. # 441	Programming Office Bulletin Board	6/22/22	C. Alfaro ✓
32. Facility "C" / Bldg. # 440	Visiting Area Bulletin Board	6/22/22	C. Alfaro ✓
33. Facility "C" / Bldg. # 345	Housing Unit 1 Bulletin Board	6/22/22	C. Alfaro ✓
34. Facility "C" / Bldg. # 344	Housing Unit 2 Bulletin Board	6/22/22	C. Alfaro ✓
35. Facility "C" / Bldg. # 343	Housing Unit 3 Bulletin Board	6/22/22	C. Alfaro ✓
36. Facility "C" / Bldg. # 342	Housing Unit 4 Bulletin Board	6/22/22	C. Alfaro ✓
37. Facility "C" / Bldg. # 341	Housing Unit 5 Bulletin Board	6/22/22	C. Alfaro ✓
38. Facility "D" / Bldg. # 451	Programming Office Bulletin Board	6/22/22	C. Alfaro ✓
39. Facility "D" / Bldg. # 440	Visiting Area Bulletin Board	6/22/22	C. Alfaro ✓
40. Facility "D" / Bldg. # 355	Housing Unit 1 Bulletin Board	6/22/22	C. Alfaro ✓
41. Facility "D" / Bldg. # 354	Housing Unit 2 Bulletin Board	6/22/22	C. Alfaro ✓
42. Facility "D" / Bldg. # 353	Housing Unit 3 Bulletin Board	6/22/22	C. Alfaro ✓
43. Facility "D" / Bldg. # 352	Housing Unit 4 Bulletin Board	6/22/22	C. Alfaro ✓
44. Facility "D" / Bldg. # 351	Housing Unit 5 Bulletin Board	6/22/22	C. Alfaro ✓
45. ASU / Bldg. # 360	Programming Office Bulletin Board	6/22/22	C. Alfaro ✓
46. Accounting Office / Bldg. 512	Office Bulletin Board	6/22/22	C. Alfaro ✓

By 

2021 Consumer Confidence Report

Water System Information

Water System Name: Calipatria State Prison System # 1310800

Report Date: 06/06/22

Type of Water Source(s) in Use: Treated Potable Water

Name and General Location of Source(s): Golden State Water Company Located in Calipatria, Ca.

Drinking Water Source Assessment Information: The drinking water assessment information can be obtained from Golden State Water Company

Time and Place of Regularly Scheduled Board Meetings for Public Participation: N/A (State Prison)

For More Information, Contact: David Chase, CPM II (760) 348-7000 Ext. 5905

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2021 and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Calipatria State Prison a (760) 348-7000 Ext. 5905 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Calipatria State Prison 以获得中文的帮助: (760) 348-7000 Ext. 5905

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Calipatria State Prison o tumawag sa (760) 348-7000 Ext. 5905 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Calipatria State Prison tại (760) 348-7000 Ext. 5905 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Calipatria State Prison ntawm (760) 348-7000 Ext. 5905 rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)

Term	Definition
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (State Total Coliform Rule)	0	0	1 positive monthly sample (a)	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (State Total Coliform Rule)	0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive	0	Human and animal fecal waste
<i>E. coli</i> (Federal Revised Total Coliform Rule)	0	0	(b)	0	Human and animal fecal waste

(a) Two or more positive monthly samples is a violation of the MCL

(b) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	8/20/20	22	ND	0	15	0.2	Not applicable	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	8/20/20	22	.310	0	15	0.2	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2021	120	120-130	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2021	350	330-360	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected 2021 Avg.	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
TTHM (ug/L) Total Trihaloamethanes	2021	43	20-57	80	NA	Byproduct of drinking water disinfection
HAA5 (ug/L) Sum of 5 Halocetic Acids	2021	13	3.1-19	60	NA	Byproduct of drinking water disinfection
Chlorine as CL2 (mg/L)	2021	1.0	ND -3.2	4.0	4	Drinking water disinfectant

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Aluminum (ug/L)	2021	93	ND-200	200	NA	Erosion of natural deposits
Sulfate (mg/L)	2021	260	250-280	500	NA	Run off leaching from natural deposits
Total dissolved solids (mg/L)	2021	720	680-770	1000	NA	Runoff/leaching from natural deposits

Table 6. Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
N/A					

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Enter Water System's Name] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Federal Revised Total Coliform Rule (RTCR): This Consumer Confidence Report (CCR) reflects changes in drinking water regulatory requirements during 2021. These revisions add the requirements of the federal Revised Total Coliform Rule, effective since April 1, 2016, to the existing state Total Coliform Rule. The revised rule maintains the purpose to protect public health by ensuring the integrity of the drinking water distribution system and monitoring for the presence of microbials (i.e., total coliform and *E. coli* bacteria). The U.S. EPA anticipates greater public health protection as the rule requires water systems that are vulnerable to microbial contamination to identify and fix problems. Water systems that exceed a specified frequency of total coliform occurrences are required to conduct an assessment to determine if any sanitary defects exist. If found, these must be corrected by the water system. The state Revised Total Coliform Rule became effective July 1, 2021

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

N/A				
-----	--	--	--	--

For Water Systems Providing Groundwater as a Source of Drinking Water**Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples**

N/A					
-----	--	--	--	--	--

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

Special Notice of Fecal Indicator-Positive Groundwater Source Sample: N/A
--

Special Notice for Uncorrected Significant Deficiencies: N/A

For Systems Providing Surface Water as a Source of Drinking Water**Table 10. Sampling Results Showing Treatment of Surface Water Sources**

Treatment Technique ^(a) (Type of approved filtration technology used)	GAC filtration
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to [0.3] NTU in 95% of measurements in a month. 2 – Not exceed 1.0 NTU for more than eight consecutive hours. 3 – Not exceed 5.0 NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	100%
Highest single turbidity measurement during the year	0.09
Number of violations of any surface water treatment requirements	0

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a Surface Water TT**Summary Information for Federal Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements****Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation**

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct 0 Level 1 assessment(s).

During the past year 0 Level 2 assessments were required to be completed for our water system.

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

We were required to complete 0 Level 2 assessment because we found *E. coli* in our water system.