

2022 Consumer Confidence Report

Water System Information

Water System Name: Wilson Circle Mutual Water Company

Report Date: June 2023

Type of Water Source(s) in Use: Ground Water Wells

Name and General Location of Source(s): Well 01 NW, Well 02 SE, and Well 03 E are located within the subdivision.

Drinking Water Source Assessment Information: The source assessments were conducted in June 2011. The water sources are considered vulnerable to the following activity associated with detected nitrated contaminates; the sewer collection system located within the subdivision. Copies of the complete assessment are available for review at the Division of Drinking Water Mojave District – 464 W. 4th St, Suite 437, San Bernardino, CA 92401 or by phone at 909-383-4328 or can be requested by contacting Wilson Circle MWC.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Annually in November at a place that will be determined and published to the customers.

For More Information, Contact: Caleb Kile, Kile's H2Operations at (760) 258-7220

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2022 and may include earlier monitoring data.

Importance of This Report Statement in Spanish

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse con Wilson Circle Mutual Water Company a 760-937-2677 para asistirlo en español.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Term	Definition
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
NTU	The unit used to measure the turbidity of a fluid or the presence of suspended particles in water
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)
µS/cm	microsiemens per centimeter is a decimal fraction of the SI unit of the electrical conductivity siemens per meter

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	0	[0]	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 1.A. Compliance with Total Coliform MCL between January 1, 2021 and June 30, 2021 (inclusive)

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	0	0	1 positive monthly sample (a)	0	Naturally present in the environment
Fecal Coliform and <i>E. coli</i>	0	0	0	None	Human and animal fecal waste

(a) For systems collecting fewer than 40 samples per month: two or more positively monthly samples is a violation of the total coliform MCL

For violation of the total coliform MCL, include potential adverse health effects, and actions taken by water system to address the violation: [Enter information]

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	9/30/22	5	0	0	15	0.2	0	Internal corrosion of household water plumbing systems; discharges from

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
								industrial manufacturers; erosion of natural deposits
Copper (ppb)	9/30/22	5	0	0	1300	300	N/A	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	9/1/21	8.5	7.7 - 10	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	9/1/21	55	46 - 66	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Arsenic (ppm)	10/24/22 9/1/21	4	3.3 - 5.0	10	.0004	Erosion of mineral deposits
Fluoride (ppm)	10/24/22 9/1/21	0.13	ND - 0.28	2.0	1	Erosion of natural deposits; water additive which

						promotes strong teeth; discharge from fertilizer and aluminum factories
Gross Alpha (pCi/L)	3/25/21	6.27	3.8 - 8.0	15	0	Emissions of natural deposits
Nitrate(As Nitrogen, N) (ppm)	10/24/22	0.42	0.32 - 0.51	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Uranium (pCi/L)	3/25/21 12/18/14	5.2	4.1 - 6.1	20	0.43	Erosion of Natural deposits

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
*Iron (mg/L)	3/27/22 9/1/21	0.54	ND - 1	0.3 mg/l	None	Leaching from natural deposits, industrial wastes
Manganese (mg/L)	9/1/21	0.05	ND - 0.12	0.05	None	Leaching from natural deposits.
Zinc (ug/L)	9/1/21	103	ND - 260	5000	None	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (TDS) (mg/l)	9/1/21	110	N/A	1000	None	Runoff/leaching from natural deposits
Aluminum (ppm)	10/24/22 9/1/21	0.08	ND to 0.24	1	None	Erosion of natural deposits
Chloride (mg/l)	9/1/21	1.5	1.1 - 2.2	500	None	Erosion of natural deposits
Color (units)	10/24/22 9/1/21	13	ND - 25	15	None	Naturally occurring organic materials

Copper (mg/l)	9/2/21	19	ND - 56	1000	None	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Cyanide (ug/l)	10/24/22 12/27/21	2.5	ND - 7.5	150	None	Discharge from steel/metal, plastic and fertilizer factories
Turbidity (NTU's)	10/24/22 9/1/21	4.38	0.24 - 6.80	5	None	Runoff; leaching from natural deposits
Specific Conductance (µS/cm)	9/1/21	153	140 - 170	1600	None	Substances that form ions when in water
Sulfate (mg/l)	9/1/21	5.2	4.7 - 6	500	None	Runoff; leaching from natural deposits; industrial waste

Table 6. Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Vanadium (ug/L)	9/19/18 1/26/16	5.5	4.6 - 6.5	50	The babies of some pregnant women who drink water containing vanadium in excess of the notification level may have increased risk of development effects, based on study of laboratory animals.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water

poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Wilson Circle MWC is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Our water contains an average of fluoride levels of 0.13 parts per million. You may want to contact your child's pediatrician and/or dentist with this information to help them determine if fluoride supplements or treatments are needed.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
Iron Secondary MCL Violation	Wilson Well 01 exceeded the secondary MCL Standard.	Ongoing	Wilson Well 01 has been offline (not providing water to the system) for several years and continues to be offline) The well has been re-established and brushed which has significantly reduced the iron content however the content continues above	Iron was found at levels that exceed the MCL. The iron MCL was set to protect you against unpleasant aesthetic effects (e.g., color, taste, and odor) and the staining of plumbing fixtures and clothing while washing. The high iron levels are due to leaching of natural deposits.

			the MCL. The company will work with the state to see if the well can be brought back online.	
Exceedance of Manganese Maximum Contaminant Level	Well 01 had elevated levels of manganese	Ongoing	Wilson Well 01 has been offline (not providing water to the system) for several years and continues to be offline). The well has been re-established and brushed. The company will work with the state to see if the well can be brought back online.	Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system
Exceedance of Color Maximum Contaminant Level	Well 01 had levels at the MCL and Well 02 had elevated levels of color	Third quarter of 2022	Routine flushing of wells and hydrants	Color was found at levels that exceed the MCL. The color MCL was set to protect you against unpleasant aesthetic effects. It is from naturally-occurring organic materials.
Exceedance of Turbidity Maximum Contaminant Level	Well 01 and Well 02 had elevated levels of turbidity	Third quarter of 2022	Routine flushing of wells and hydrants	Turbidity has no health effects. However, high levels of turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

For Water Systems Providing Groundwater as a Source of Drinking Water

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year) 0	N/A	0	(0)	Human and animal fecal waste
Enterococci	(In the year) 0	N/A	TT	N/A	Human and animal fecal waste
Coliphage	(In the year) 0	N/A	TT	N/A	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

Special Notice of Fecal Indicator-Positive Groundwater Source Sample: There were no positive fecal-indicator ground water source samples during 2022

Special Notice for Uncorrected Significant Deficiencies: There were no uncorrected significant deficiencies during 2022

Summary Information for Operating Under a Variance or Exemption

None; this system did not operate under a variance or exemption during 2022.

Summary Information for Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were not required to conduct a Level 1 Assessment or a Level 2 Assessment.