

## APPENDIX B: eCCR Certification Form (Suggested Format)

### Consumer Confidence Report Certification Form

*(To be submitted with a copy of the CCR)*

|                      |                        |
|----------------------|------------------------|
| Water System Name:   | Cow Creek Water System |
| Water System Number: | 1410503                |

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 27-JAN-2025 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by:

|                            |                             |
|----------------------------|-----------------------------|
| Name: Charles Thompson     | Title: Chief of Maintenance |
| Signature:                 | Date: 27-Jan-2025           |
| Phone number: 760-786-3262 | blank                       |

*To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:*

- ☐ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- ☒ CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- ☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
  - ☒ Posting the CCR at the following URL: [www. Annual Reports - Death Valley National Park \(U.S. National Park Service\)](http://www.annualreports-deathvalleynationalpark.com)
  - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
  - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
  - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
  - ☐ Posted the CCR in public places (attach a list of locations)

- ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
- ☐ Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
- ☐ Other (attach a list of other methods used)
- ☐ *For systems serving at least 100,000 persons:* Posted CCR on a publicly accessible internet site at the following URL: www.\_\_\_\_\_
- ☐ *For privately-owned utilities:* Delivered the CCR to the California Public Utilities Commission

### **Consumer Confidence Report Electronic Delivery Certification**

*Water systems utilizing electronic distribution methods for CCR delivery must complete this page by checking all items that apply and fill-in where appropriate.*

- ☐ Water system mailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available website where it can be viewed (attach a copy of the mailed CCR notification). URL: www.\_\_\_\_\_
- ☒ Water system emailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed (attach a copy of the emailed CCR notification). URL: www.\_\_\_\_\_
- ☐ Water system emailed the CCR as an electronic file email attachment.
- ☐ Water system emailed the CCR text and tables inserted or embedded into the body of an email, not as an attachment (attach a copy of the emailed CCR).
- ☐ *Requires prior DDW review and approval.* Water system utilized other electronic delivery method that meets the direct delivery requirement.

*Provide a brief description of the water system's electronic delivery procedures and include how the water system ensures delivery to customers unable to receive electronic delivery.*

Delivery of the CCR used the federal government email system as well as providing the CCR to our Liaison for outside entities such as the Timbisha Tribe, CHP, CALTRANS, Xanterra, and Stovepipe Wells Concessionaire.

|  |
|--|
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |

*This form is provided as a convenience and may be used to meet the certification  
requirement of  
section 64483(c) of the California Code of Regulations.*

## Thompson, Charles D

---

**From:** Thompson, Charles D  
**Sent:** Monday, January 27, 2025 11:34 AM  
**To:** aburns\_contact; aerodriguez.xanterra\_contact; afinnie.xanterra\_contact; amargosacafedvj\_contact; Antonio\_Goolsby\_contact; ap\_contact; btaylor\_contact; carole\_canoes\_contact; cjloggins\_contact; croper\_contact; darren.leo.xanterra\_contact; director53\_contact; dispatch.inyocounty\_contact; dvoffice\_contact; hclark\_contact; jkeller\_contact; kdevereaux.stovepipedeathvalley\_contact; lstone.inyocounty\_contact; marilyn944\_contact; memberships\_contact; mgraeff\_contact; NPS DEVA Administrative Staff; NPS DEVA All Employees; NPS DEVA External Contacts; NPS DEVA Fee Collection Staff; NPS DEVA Interpretation Staff; NPS DEVA Maintenance Staff; NPS DEVA Management Staff; NPS DEVA Morning Report; NPS DEVA Protection Staff; NPS DEVA Resource Mgmt Staff; office\_contact; omorarochoa.inyocounty\_contact; plewis.stovepipedeathvalley\_contact; Renee.A.Jacobson\_contact; robert.haynes.xanterra\_contact; rreuther\_contact; scott7\_contact; ssorrells\_contact; tplunkett\_contact; warehouse\_contact  
**Subject:** 2023 CONSUMER CONFIDENCE REPORT - COW CREEK WATER SYSTEM  
**Attachments:** 2023-CCR-Cover-Letter CC.pdf; Cow Creek CCR - 2023.pdf

### Death Valley National Park Utilities Branch

579 Cow Creek Service Road ● Furnace Creek, CA ● 92328

Phone: (760) 786-3298 ● Fax (760) 786-2844

## **DEATH VALLEY NATIONAL PARK COW CREEK WATER SYSTEM CA1410503 2023 CONSUMER CONFIDENCE REPORT**

We are pleased to provide you with this year's Annual Quality Water Report also known as Consumer Confidence Report (CCR). We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our staff receives updated, professional training on a continuing basis so that we may better serve you.

At the present there are over 60 water customers and users on the system, consisting of more than 6.5 miles of water distribution pipe within Cow Creek. There is one partially buried tank located in Cow Creek that holds approximately 350,000 gallons of water. We are chlorinating, we do so as a protection to our customers and users. Chlorinating kills bacteria that might enter our system. Another question frequently asked of our department is "do you fluoridate"? The answer is "no".

We're pleased to report that our drinking water is safe and meets or exceeds state water board requirements. This report shows our water quality and what it means. If you have any questions about this report or concerns of your water utility, please contact Charles Thompson, at 760-786-3262. We want our customers and users to be informed about their water utility. If you want to learn more, please do not hesitate to contact Maintenance Division Chief.

Death Valley Utilities Branch routinely monitors for constituents in our drinking water according to State laws. Our water system is tested monthly. The attached report shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2023.

**ADDITIONAL COPIES MAY BE OBTAINED FROM**  
**Death Valley National Park Utilities Branch**  
**579 Cow Creek Service Road**  
**Furnace Creek, CA 92328**

Thank you,

Chuck

Charles Thompson, LCDR, USPHS  
Chief of Maintenance  
Death Valley National Park  
Voice: 760-786-3262 (Direct)  
Fax: 760-786-2844  
Mobile: 760-614-1071

[FLEET WORK ORDER](#)

[Housing Request form \(NEW\)](#)

[Housing Work Order form \(NEW\)](#)

DEVA Maps

[Park Tiles zoomed to DEVA](#)

[DEVA Park Atlas](#)

Various DEVA map sources

[PCE Work Tracking Form \(office.com\)](#)

## 2023 Consumer Confidence Report

### Water System Information

**Water System Name:** Cow Creek Water System -1410503

**Report Date:** August 16, 2024

**Type of Water Source(s) in Use:** Ground water

**Name and General Location of Source(s):**

The Cow Creek water supply is collected from the Nevares Spring's infiltration gallery which is located about two miles east of the Cow Creek housing area.

**Drinking Water Source Assessment Information:** A source water assessment was conducted for the sources of the Death Valley National Park public water systems in May 2002. The Nevares Spring is not considered vulnerable to any potentially contaminating activities at this time. The detection of arsenic and fluoride is considered naturally occurring. Reverse osmosis treatment is provided for these. A copy of the complete assessment may be viewed at the Death Valley National Park office or requested from the State Water Resources Control Board, Division of Drinking Water at (909) 383-4328 or 464 West 4th Street, Suite 437, San Bernardino, CA 92401.

The raw water is considered moderately mineralized consisting of sodium, calcium and magnesium, salts and bicarbonate, sulfates, and chloride. The water is considered high silica water in which amorphous silica and magnesium deposits could create serious problems by fouling surfaces of water handling equipment. This type of silica scale is very tenacious and difficult to remove. The Reverse Osmosis Plant is effectively removing the minerals. Specific water quality data relating to system water supplies can be found below.

**Time and Place of Regularly Scheduled Board Meetings for Public Participation:**

Please call Charles Thompson for an appointment at 760-786-3262 or e-mail:  
charles\_thompson@nps.gov

**For More Information, Contact:** Charles Thompson at 760-786-3262

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2022 and may include earlier monitoring data.

### Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse [Cow Creek Water System -1410503] a [760-786-3262] para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 [Cow Creek Water System -1410503]以获得中文的帮助: [760-786-3262].

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa [Cow Creek Water System -1410503] o tumawag sa [760-786-3262] para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ [Cow Creek Water System -1410503] tại [760-786-3262] để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau [Cow Creek Water System -1410503] ntawm [760-786-3262] rau kev pab hauv lus Askiv.

## Terms Used in This Report

| Term                                             | Definition                                                                                                                                                                                                                                                                  |
|--------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Level 1 Assessment                               | A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.                                                                                             |
| Level 2 Assessment                               | A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions. |
| Maximum Contaminant Level (MCL)                  | The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.            |
| Maximum Contaminant Level Goal (MCLG)            | The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).                                                                                                |
| Maximum Residual Disinfectant Level (MRDL)       | The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.                                                                                             |
| Maximum Residual Disinfectant Level Goal (MRDLG) | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.                                                                      |
| Primary Drinking Water Standards (PDWS)          | MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.                                                                                                                                |
| Public Health Goal (PHG)                         | The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.                                                                                                      |
| Regulatory Action Level (AL)                     | The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.                                                                                                                                            |
| Secondary Drinking Water Standards (SDWS)        | MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.                                                                                                                     |
| Treatment Technique (TT)                         | A required process intended to reduce the level of a contaminant in drinking water.                                                                                                                                                                                         |

| Term                     | Definition                                                                                                                                                 |
|--------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Variances and Exemptions | Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions. |
| ND                       | Not detectable at testing limit.                                                                                                                           |
| ppm                      | parts per million or milligrams per liter (mg/L)                                                                                                           |
| ppb                      | parts per billion or micrograms per liter (µg/L)                                                                                                           |
| ppt                      | parts per trillion or nanograms per liter (ng/L)                                                                                                           |
| ppq                      | parts per quadrillion or picogram per liter (pg/L)                                                                                                         |
| pCi/L                    | picocuries per liter (a measure of radiation)                                                                                                              |

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## About Your Drinking Water Quality

### Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**Table 1. Sampling Results Showing the Detection of Coliform Bacteria**

Complete if bacteria are detected.

| Microbiological Contaminants | Highest No. of Detections | No. of Months in Violation | MCL | MCLG | Typical Source of Bacteria   |
|------------------------------|---------------------------|----------------------------|-----|------|------------------------------|
| <i>E. coli</i>               | (In the year)<br>0        | 0                          | (a) | 0    | Human and animal fecal waste |

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive, or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Complete if lead or copper is detected in the last sample set.

| Lead and Copper | Sample Date | No. of Samples Collected | 90 <sup>th</sup> Percentile Level Detected | No. Sites Exceeding AL | AL  | PHG | Typical Source of Contaminant                                                                                                 |
|-----------------|-------------|--------------------------|--------------------------------------------|------------------------|-----|-----|-------------------------------------------------------------------------------------------------------------------------------|
| Lead (ppb)      | 08-01-23    | 5                        | 1.5                                        | 0                      | 15  | 0.2 | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits |
| Copper (ppm)    | 08-01-23    | 5                        | 0.190                                      | 0                      | 1.3 | 0.3 | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives               |

**Table 3. Sampling Results for Sodium and Hardness**

| <b>Chemical or Constituent (and reporting units)</b> | <b>Sample Date</b> | <b>Level Detected</b> | <b>Range of Detections</b> | <b>MCL</b> | <b>PHG (MCLG)</b> | <b>Typical Source of Contaminant</b>                                                                                 |
|------------------------------------------------------|--------------------|-----------------------|----------------------------|------------|-------------------|----------------------------------------------------------------------------------------------------------------------|
| Sodium (ppm)                                         | 10-17-23           | 150                   | NA                         | None       | None              | Salt present in the water and is generally naturally occurring                                                       |
| Hardness (ppm)                                       | 10-17-23           | 190                   | NA                         | None       | None              | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard**

| <b>Chemical or Constituent (and reporting units)</b> | <b>Sample Date</b> | <b>Level Detected</b> | <b>Range of Detections</b> | <b>MCL [MRDL]</b> | <b>PHG (MCLG) [MRDLG]</b> | <b>Typical Source of Contaminant</b>                                                                                      |
|------------------------------------------------------|--------------------|-----------------------|----------------------------|-------------------|---------------------------|---------------------------------------------------------------------------------------------------------------------------|
| Arsenic (ppb)<br>Treated with reverse osmosis        | 10-17-23           | 6.1                   | NA                         | 10                | 0.004                     | Erosion of natural deposits; runoff from orchards; glass and electronics production wastes                                |
| Fluoride (ppm)                                       | 2023               | 1.0                   | ND – 1.6                   | 2.0               | 1                         | Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories. |
| Gross Alpha (pCi/L)                                  | 06-07-23           | 4.72                  | NA                         | 15                | 0                         | Erosion of natural deposits                                                                                               |
| Total Trihalomethanes (ppb)                          | 07-05-23           | 5.83                  | 0 – 5.8                    | 80                | NA                        | By product of drinking water disinfection                                                                                 |

|                              |          |     |           |    |    |                                          |
|------------------------------|----------|-----|-----------|----|----|------------------------------------------|
| Total Haloacetic Acids (ppb) | 07-05-23 | 3.0 | 2.8 – 3.2 | 60 | NA | Byproduct of drinking water disinfection |
|------------------------------|----------|-----|-----------|----|----|------------------------------------------|

**Table 5. Detection of Contaminants with a Secondary Drinking Water Standard**

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | SMCL  | PHG (MCLG) | Typical Source of Contaminant                               |
|-----------------------------------------------|-------------|----------------|---------------------|-------|------------|-------------------------------------------------------------|
| Chloride (ppm)                                | 10-17-23    | 37             | NA                  | 500   | NA         | Runoff/leaching from natural deposits; seawater influence   |
| Odor (Units)                                  | 07-19-22    | 1              | NA                  | 3     | NA         | Naturally occurring organic materials                       |
| Conductivity (µS/cm)                          | 10-17-23    | 1200           | NA                  | 1,600 | NA         | Substances that form ions when in water, seawater influence |
| Sulfate (ppm)                                 | 10-17-23    | 170            | NA                  | 500   | NA         | Runoff/leaching from natural deposits; seawater influence   |
| Total Dissolved Solids (TDS) ppm              | 10-17-23    | 580            | 83-224              | 1000  | NA         | Runoff/leaching from natural deposits                       |

**Table 6. Detection of Unregulated Contaminants**

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | Notification Level | Health Effects |
|-----------------------------------------------|-------------|----------------|---------------------|--------------------|----------------|
| None                                          |             |                |                     |                    |                |

**Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some

elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Enter Water System's Name] is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

### Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

**Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement**

| Violation | Explanation | Duration | Actions Taken to Correct Violation | Health Effects Language |
|-----------|-------------|----------|------------------------------------|-------------------------|
| NONE      |             |          |                                    |                         |

### For Water Systems Providing Groundwater as a Source of Drinking Water

**Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples**

| Microbiological Contaminants (complete if fecal-indicator detected) | Total No. of Detections | Sample Dates | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant |
|---------------------------------------------------------------------|-------------------------|--------------|------------|--------------------|-------------------------------|
| <i>E. coli</i>                                                      | 0                       | NA           | 0          | (0)                | Human and animal fecal waste  |
| Enterococci                                                         | 0                       | NA           | TT         | N/A                | Human and animal fecal waste  |
| Coliphage                                                           | 0                       | NA           | TT         | N/A                | Human and animal fecal waste  |

### Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

**Special Notice of Fecal Indicator-Positive Groundwater Source Sample: N/A**

|                                                                     |
|---------------------------------------------------------------------|
| <b>Special Notice for Uncorrected Significant Deficiencies:</b> N/A |
|---------------------------------------------------------------------|

**Table 9. Violation of Groundwater TT**

| <b>Violation</b> | <b>Explanation</b> | <b>Duration</b> | <b>Actions Taken to Correct Violation</b> | <b>Health Effects Language</b> |
|------------------|--------------------|-----------------|-------------------------------------------|--------------------------------|
| NONE             |                    |                 |                                           |                                |