


## Consumer Confidence Report Certification Form

Water System Name:	Owens Valley Conservation Camp
Water System Number:	1410800

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/29/2021 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by:	Name:	Joseph J. Tabush	
	Signature:		
	Title:	Chief Plant Operator	
	Phone Number:	( 760) 702-1602	Date: <b>8/05/2021</b>

*To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:*

- ☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: Delivered and posted at 3 locations (CDCR office, Calfire office, and Bishop Fire station. Hand delivery to all residents
- 
- ☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
- ☐ Posting the CCR on the Internet at www.
  - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
  - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
  - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
  - ☒ Posted the CCR in public places. Delivered and posted at 3 locations (CDCR office, Calfire office, and Bishop Fire station
  - ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
  - ☐ Delivery to community organizations (attach a list of organizations)
  - ☐ Other (attach a list of other methods used)
- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.

☐ *For investor-owned utilities:* Delivered the CCR to the California Public Utilities Commission

*This form is provided as a convenience for use to meet the certification requirement of the California Code of Regulations, section 64483(c).*

# 2020 Consumer Confidence Report

Attached is the 2020 Consumer Confidence Report for the Owens Valley Conservation Camp. The number one goal of the water crew is to provide our customers with a good tasting, safe, and reliable water supply. as is typical throughout California, we are experiencing extreme drought conditions. Please conserve water as much as possible. Pay particular attention to the waste of water during irrigation. Use water wisely! Thank you all for your assistance this past year. By working together, we will continue to supply the water we need. Thank you for your continuing support of this effort. If you have any questions, please feel free to contact Joe Tabush at 760-702-1602 and I will be happy to answer any of your questions.





## 2020 Consumer Confidence Report

### Water System Information

Water System Name: Owens Valley Conservation Camp

Report Date: 6/28/2021

Type of Water Source in Use: Ground Water

Name and General Location of Source(s): Well #1 (Water System 1410800-001)

Well #2 (Water System 1410800-002)

### Drinking Water Source Assessment Information

Source #	Source ID	Most Vulnerable Activities (PCA)
001	Well 01	Septic systems (low density), Sewer collection system, liquid waste ponds
001	Well 02	Septic systems (low density), Sewer collection system, liquid waste ponds

Time and Place of Regularly Scheduled Board Meetings for Public Participation: N/A

For More Information, Contact: Joe Tabush- Chief Plant Operator Phone: (760)702-1602

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2020 and may include earlier monitoring data.

### Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Owens Valley Conservation Camp a 2781 South Round Valley Road, Bishop CA 93514 760-702-1602 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Owens Valley Conservation Camp 以获得中文的帮助: Owens Valley Conservation Camp a 2781 South Round Valley Road, Bishop CA 93514 760-702-1602.

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Owens Valley Conservation Camp Owens Valley Conservation Camp a 2781 South Round Valley Road, Bishop CA 93514 o tumawag sa 760-702-1602 para matulungan sa wikang Tagalog.



Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Owens Valley Conservation Camp tại Owens Valley Conservation Camp a 2781 South Round Valley Road, Bishop CA 93514 760-702-1702 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Owens Valley Conservation Camp ntawm 760-702-1602 2781 South Round Valley Road, Bishop CA 93514 rau kev pab hauv lus Askiv.

## Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.



Term	Definition
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## About Your Drinking Water Quality

### Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for

certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**Table 1. Sampling Results Showing the Detection of Coliform Bacteria**

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (State Total Coliform Rule)	(In a month) 1	None	1 positive monthly sample <sup>(a)</sup>	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (State Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive	None	Human and animal fecal waste
<i>E. coli</i> (Federal Revised Total Coliform Rule)	(In the year) 0	0	(b)	0	Human and animal fecal waste

(a) Two or more positive monthly samples is a violation of the MCL

(b) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 <sup>th</sup> Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	9/17/2020	10	0	0	15	0.2	0	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	9/17/2020	10	10	10	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives



**Table 3. Sampling Results for Sodium and Hardness**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	5/24/18 6/18/20	6.25	6.7 5.8	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	5/24/18 6/18/20	42	43 41	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Nitrates (mg/L)	6/18/20 6/18/20	<0.4	<0.4	None	None	Runoff/leaching from natural deposits; seawater influences
Fluoride (mg/L)	5/24/18 6/18/20	0.13	0.14 0.12	[Enter No.]	[Enter No.]	Erosion of natural deposits, water additive which promotes strong teeth, discharge from fertilizer and aluminum factories

**Table 5. Detection of Contaminants with a Secondary Drinking Water Standard**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (PPM)	5/24/18 6/18/20	1.1	1.0 1.2	500	N/A	Runoff/leaching from natural deposits; seawater influences
Sulfate	5/24/18 6/18/20	5.65	6.5 4.8	500	N/A	Runoff/leaching from natural deposits; seawater influences
TDS	5/24/18 6/18/20	90	100 80	1000	N/A	Runoff/leaching from natural deposits; seawater influences
Color (Units)	5/24/18 6/18/20	<3.0	<3.0	15	N/A	Runoff/leaching from natural deposits; seawater influences
Specific Conductance]	5/24/18 6/18/20	105	100 110	1600	N/A	Runoff/leaching from natural deposits; seawater influences



**Table 6. Detection of Unregulated Contaminants**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
None					

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Owens Valley Conservation Camp is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Additional Special Language for Lead:

*If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Owens Valley Conservation Camp is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.*



**Federal Revised Total Coliform Rule (RTCR):** *This Consumer Confidence Report (CCR) reflects changes in drinking water regulatory requirements during 2016. All water systems are required to comply with the state Total Coliform Rule. Effective April 1, 2016, all water systems are also required to comply with the federal Revised Total Coliform Rule. The new federal rule maintains the purpose to protect public health by ensuring the integrity of the drinking water distribution system and monitoring for the presence of microbials (i.e., total coliform and E. coli bacteria). The U.S. EPA anticipates greater public health protection as the new rule requires water systems that are vulnerable to microbial contamination to identify and fix problems. Water systems that exceed a specified frequency of total coliform occurrences are required to conduct an assessment to determine if any sanitary defects exist. If found, these must be corrected by the water system.*

### Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

**Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement**

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
None				

### For Water Systems Providing Groundwater as a Source of Drinking Water

**Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples**

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0	N/A	0	(0)	Human and animal fecal waste
Enterococci	0	N/A	TT	N/A	Human and animal fecal waste
Coliphage	0	N/A	TT	N/A	Human and animal fecal waste

### Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

**Special Notice of Fecal Indicator-Positive Groundwater Source Sample: N/A**

**Special Notice for Uncorrected Significant Deficiencies: N/A**



**Table 9. Violation of Groundwater TT**

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
None				

**For Systems Providing Surface Water as a Source of Drinking Water****Table 10. Sampling Results Showing Treatment of Surface Water Sources**

Treatment Technique <sup>(a)</sup> (Type of approved filtration technology used)	[Enter Treatment Technique]
Turbidity Performance Standards <sup>(b)</sup> (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to <u>N/A</u> NTU in 95% of measurements in a month. 2 – Not exceed <u>N/A</u> NTU for more than eight consecutive hours. 3 – Not exceed <u>N/A</u> NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	N/A
Highest single turbidity measurement during the year	N/A
Number of violations of any surface water treatment requirements	N/A

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

**Summary Information for Violation of a Surface Water TT****Table 11. Violation of Surface Water TT**

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
N/A				

**Summary Information for Operating Under a Variance or Exemption**

N/A

## Summary Information for Federal Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

### Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessments to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct 0 Level 1 assessments. 0 Level 1 assessments were completed. In addition, we were required to take 0 corrective actions and we completed 0 of these actions.

During the past year 0 Level 2 assessments were required to be completed for our water system. 0 Level 2 assessments were completed. In addition, we were required to take 0 of these actions.

During the past year 0 Level 1 or 2 assessments were required to be completed for our water system.

### Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

*E. coli* are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

We were not required to complete a Level 2 assessment because we found *E. coli* in our water system. In addition, we were required to take 0 corrective actions and we completed 0 of these actions.