

2020 Consumer Confidence Report

Water System Name: Mettler County Water District

Report Date: June 28, 2021

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2018 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Mettler County Water District a (661) 764-5273 para asistirlo en español.

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Mettler County Water District 以获得中文的帮助:
PO Box 874, Buttonwillow CA 93206, (661) 805-7648

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Mettler County Water District, PO Box 874, Buttonwillow, CA 93206 o tumawag sa (661) 805-7648 para matulungan sa wikang Tagalog.

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Mettler County Water District tại PO Box 874, Buttonwillow, CA 93206; (661)805-7648 để được hỗ trợ giúp bằng tiếng Việt.

Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Mettler County Water District ntawm PO Box 874, Buttonwillow, CA 93206, (661) 805-7648 rau kev pab hauv lus Askiv.

Type of water source(s) in use: Groundwater Wells

Name & general location of source(s): Well #03

Drinking Water Source Assessment information: A Source Assessment was conducted in April 2002. The results of

This assessment indicate that water sources are most vulnerable to the following activities: Septic Systems, Fertilizer/Pesticide/Herbicide application, High density housing, Automobile-gas stations, and Underground storage tanks. You may view the assessment by contacting the District Office at 661-764-5273

Time and place of regularly scheduled board meetings for public participation: Second Tuesday of each month at 7:00 PM at the District Office, 1822 Stevens Drive, Mettler, California

For more information, contact: Mario Cervantes, System Operator Phone: (661) 805-7648

Regina Houchin, Secretary (661) 764-5273

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

| TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA | | | | | |
|---|---------------------------|----------------------------|--|------|--------------------------------------|
| Microbiological Contaminants (complete if bacteria detected) | Highest No. of Detections | No. of Months in Violation | MCL | MCLG | Typical Source of Bacteria |
| Total Coliform Bacteria (state Total Coliform Rule) | (In a month) | 0 | 1 positive monthly sample | 0 | Naturally present in the environment |
| Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule) | (In the year) | 0 | A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive | | Human and animal fecal waste |
| <i>E. coli</i> (federal Revised Total Coliform Rule) | (In the year) | 0 | (a) | 0 | Human and animal fecal waste |

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

| TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER | | | | | | | | |
|---|-------------|--------------------------|--|------------------------|-----|-----|---|---|
| Lead and Copper (complete if lead or copper detected in the last sample set) | Sample Date | No. of Samples Collected | 90 th Percentile Level Detected | No. Sites Exceeding AL | AL | PHG | No. of Schools Requesting Lead Sampling | Typical Source of Contaminant |
| Lead (ppb) | 9/28/19 | 5 | 0.0000 | 0 | 15 | 0.2 | | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits |
| Copper (ppm) | 9/28/19 | 5 | 0.026 | 0 | 1.3 | 0.3 | Not applicable | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
|--|-------------|----------------|---------------------|------|---------------|--|
| Sodium (ppm) | 12/31/19 | 47 | 47 | None | None | Salt present in the water and is generally naturally occurring |
| Hardness (ppm) | 12/31/19 | 180 | 180 | None | None | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant |
|--|---|--|---------------------|---------------|--------------------------|---|
| Nitrate (as N) (ppm) Well #3 | 1/08/20 2/13/20 4/16/20 7/15/20 9/9/20 12/9/20 | 7.0 4.0 3.8 8.3 3.7 3.8 | 3.7-8.3 | 10 | 10 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits |
| Nitrite (as N) (ppm) | 12/30/19 | <.050 | <0.050 | 1000 | 1000 | Runoff and leaching from fertilizer use; leaching from septic tanks, sewage, erosion of natural deposits |
| Aluminum (ppm) | 12/30/19 | <.50 | <.50 | 1 | .06 | Erosion of natural deposits; residue from some surface water treatment processes |
| Antimony (ppb) | 12/30/19 | <2.0 | <2.0 | | | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder |
| Arsenic (ppb) | 12/30/19 | 2.2 | 2.2 | 10 | 0.004 | Erosion of natural products; runoff from orchards, glass and electronics production wastes. |
| Barium (ppb) | 12/30/19 | 76 | 76 | 1000 | 2000 | Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits |
| Beryllium (ppb) | 12/30/19 | <1.0 | <1.0 | 4 | 1 | Discharge from metal refineries; coalburing factories, electrical, aerospace, defense industries. |
| Cadmium (ppb) | 12/30/19 | <1.0 | <1.0 | 5 | 1 | Internal corrosion of galvanized pipes; erosion of natural deposits; discharge from electroplating and industrial chemical factories and metal refineries; runoff from waste batteries and paints |
| Chromium (ppb) | 12/30/19 | <10 | <10 | 50 | 10 | Discharge from steel and pulp mills and chrome plating; erosion of natural deposits |
| Fluoride (ppm) | 12/30/19 | .68 | .68 | 2 | 1 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| Mercury (ppb) | 12/30/19 | <.20 | <.20 | 2 | 1 | Erosion of natural deposits; discharge from refineries and factories; runoff from landfills and cropland |
| Nickel (ppb) | 12/30/19 | <10 | <10 | 100 | 10 | Erosion of natural deposits; discharge from metal factories |
| Perchlorate (ppb) | 12/30/19 | <4.0 | <4.0 | 6 | 4 | Perchlorate is an inorganic chemical used in solid rocket propellant, fireworks, |
| Selenium (ppb) | 12/30/19 | <2.0 | <2.0 | 50 | 50 | Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive) |
| Thallium (ppb) | 12/30/19 | <1.0 | <1.0 | 2 | 1 | Leaching from ore-processing sites; discharge from electronics, glass and drug factories |

| | | | | | | |
|---|---|---|--------|-------|--|--|
| 1,2,3-Trichloropropane (TCP) (ppb) Well #3 | 1/8/20 4/16/20 7/15/20 9/9/20 12/9/20 | <0.0050 <0.0050 <0.0050 <0.0050 <0.0050 | 0.0050 | 0.005 | | Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides. |
|---|---|---|--------|-------|--|--|

TABLE 5 – DETECTION 07/15/20F CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | SMCL | PHG (MCLG) | Typical Source of Contaminant |
|---|-------------|----------------|---------------------|------|------------|---|
| Bicarbonate Alkalinity (ppm) | 12/30/19 | 200 | 200 | None | N/A | |
| Calcium (ppm) | 12/30/19 | 47 | 47 | None | N/A | Erosion of natural deposits |
| Carbonate Alkalinity(ppm) | 12/30/19 | <2.5 | <2.5 | None | | |
| Chloride (ppm) | 12/30/19 | 22 | 22 | 500 | N/A | Runoff/leaching from natural deposits; seawater influence |
| Color | 12/30/19 | 2.0 | 2.0 | 15 | N/A | Naturally-occurring organic materials |
| Copper | 12/30/19 | <10 | <10 | 1000 | | |
| Foaming Agents (MBAS) | 12/30/19 | <0.10 | <0.10 | .5 | | |
| Hardness (Total) AS CAC03 | 12/30/19 | 180 | 180 | None | | |
| Hydroxide Alkalinity | 12/30/19 | <1.4 | <1.4 | None | | |
| Iron (ppb) | 12/30/19 | <50 | <50 | 300 | N/A | Leaching from natural deposits; industrial wastes |
| Manganese (ppm) | 12/30/19 | <10 | <10 | 50 | N/A | Leaching from natural deposits |
| Magnesium (ppm) | 12/30/19 | 14 | 14 | None | N/A | Erosion of Natural Deposits |
| Odor Threshold @ 60C | 12/30/19 | 0 | 0 | 3 | | |
| pH, Laboratory | 12/30/19 | 7.94 | 7.94 | None | | Inherent characteristic of water |
| Silver | 12/30/19 | <10 | <10 | 100 | | |
| Sodium | 12/30/19 | 47 | 47 | None | | |
| Specific Conductance | 12/30/19 | 534 | 534 | 1600 | | Inherent characteristic of water |
| Sulfate (ppm) | 12/30/19 | 66 | 66 | 500 | | Runoff/leaching from natural deposits; industrial wastes |
| Total Dissolved Solids (TDS) (ppm) | 12/30/19 | 330 | 330 | 1000 | | |
| Turbidity (NTU) | 12/30/19 | 0.10 | 0.10 | 5 | N/A | Soil Runoff |
| Zinc (ppb) | 12/30/19 | <50 | <50 | 5000 | N/A | Runoff/leaching from natural deposits; industrial wastes |

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Mettler County Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [**OPTIONAL:** If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The California Department of Health Services continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and as linked to other health effects such as skin damage and circulatory problems.

*1,2,3-Trichloropropane (1,2,3-TCP). 1,2,3-TCP was an impurity in pesticides used in agriculture from the 1950s to 1980s. In 2017, the State Water Board adopted an MCL of 5 ppt for 1,2,3-TCP. *Some people who drink water containing 1,2,3-TCP in excess of the MCL over many years may have an increased risk of getting cancer.* Well #4 is out of compliance with the MCL for 1,2,3-TCP, but, for the protection of our customer's health, the District did not use Well #4 in 2020. The District has completed a State Water Board Approved Corrective Action Plan and is completing the design phase and is seeking funding for a treatment plant to remove 1,2,3-TCP from Well #4 and bring the well back into compliance.

*Nitrate. Well #4, which was not used in 2020, is also out of compliance with the nitrate MCL. Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider. The District has completed a State Water Board Approved Corrective Action Plan and is completing the design phase and is seeking funding to resolve the nitrate issue at Well #4.