2018 Consumer Confidence Report

Water System Name: Clark Street Community Well Report Date: 12-14-2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2018 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse CLARK STREET COMMUNITY WELL a P. O. Box 2770 Lake Isabella, CA 93240 para asistirlo en español.

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 CLARK STREET COMMUNITY WELL 以获得中文的帮助: P. O. Box 2770 Lake Isabella, CA 93240

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa CLARK STREET COMMUNITY WELL o tumawag sa CLARK STREET COMMUNITY WELL P. O. Box 2770 Lake Isabella, CA 93240 para matulungan sa wikang Tagalog.

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ CLARK STREET COMMUNITY WELL tại P. O. Box 2770 Lake Isabella, CA 93240 ể được hỗ trợ giúp bằng tiếng Việt.

Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau CLARK STREET COMMUNITY WELL ntawm P. O. Box 2770 Lake Isabella, CA 93240 rau kev pab hauv lus Askiv.

WELL HUIVIII I. O. DOX 27 / O Lune 150	bonn, ciryozio inn arc F			
Type of water source(s) in use: Well				
Name & general location of source(s):	Isabella, CA 93240			
Drinking Water Source Assessment infor	mation: Well 01, Active/Untreated			
Time and place of regularly scheduled bo	pard meetings for public participation:	Annually-4 th Quarter		
For more information, contact: Debor	rah Eoff	Phone: 760-417-1364		

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of
 industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff,
 agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a month)	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or E. coli (state Total Coliform Rule)	(In the year)	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste
E. coli (federal Revised Total Coliform Rule)	(In the year)	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	7-22-19	5	0.0006		15	0.2		Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	7-22- 2019	5	0.00285		1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	7-18-2017	12		None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	7-18-2017	240		None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring
TABLE 4 – DET	ECTION O	F CONTAMINA	NTS WITH A	PRIMARY	DRINKING	WATER STANDARD
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
TABLE 5 – DETE	CTION OF	CONTAMINAN	ITS WITH A S	ECONDAR	Y DRINKIN	IG WATER STANDARD
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
	TABLE	6 – DETECTION	OF UNREGU	LATED CO) NTAMINA	NTS
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notifica	tion Level	Health Effects Language

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. CLARK STREET COMMUNITY WELL is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at http://www.epa.gov/lead.

TABLE 4 - DETECTION OF C						DARD	Page 4 of 6
Chemical or Constituent	Sample	Level	Range of	MCL	PHG	Typical Source	
(and reporting units)	Date	Detected	Detections		(MCLG)	of Contaminant	
Turbidity	7/18/2017	0.380		TT	N/A	Soil Runoff	
Aluminum	7/18/2017	<50				Erosion of natural deposits; residue from some surface water	
						treatment processes.	
Antimony	7/18/2017	<2.0		6	20	Discharge from petroleum refineries, fire retardants, ceramics,	
						electronics, solder	
Arsenic	7/18/2017	8.100	DLR 6.0	10	0.004	Erosion of natural deposits; runoff	1
						from orchards.	
Atrazine	7/21/2014	<0.30	DLR 1	1	0.15	Runoff from herbicide used on row crops	
						and along railroad and highway right of ways	
Barium	7/18/2017	87.0				Discharge of oil drilling wastes and from metal refineries, erosion	
						of natural deposits	
Beryllium	7/18/2017	<1.0		4	1	Discharge from metal refineries, coal burning factories, and electrical,	
			-	- Annan		aerospace, and defense industries	
Cadmium	7/18/2017	<1.0		5	0.04	Internal corrosion of galvanized pipes, erosion of natural deposits,	
						discharge from electroplating and industrial chemical factories, and	
						metal refineries, runoff from waste batteries and paints	
Chromium	7/18/2017	<10		50	-100	Discharge from steel and pulp mills and chrome plating, erosion of	
						natural deposits	
Fluoride	7/18/2017	0.530		2	1	Erosion of natural deposits	
Mercury	7/18/2017	<0.20		2	1.2	Erosion of natural deposits, discharge from refineries and factories,	
Morodry	7710/2011					runoff from landfills and cropland	
Nickel	7/18/2017	<10		100	12	Erosion of natural deposits, discharge from metal factories	
Nitrate (as NO3)	7/18/2017	0.45		45	45	Runoff and leaching from fertilizer use	
141111111111111111111111111111111111111	7710/2017	01.10				leaching from septic tanks and sewage	
						erosion of natural deposits	
Nitrite (as N)	12/19/2018	0.310		10		Runoff and leaching from fertilizer use, leaching from septic tanks and sewage	Э,
Willie (d3 14)	12/10/2010	0.010				erosion of natural deposits.	
Selenium	7/18/2017	<2.0		50	30	Discharge from petroleum, glass, and metal refineries, erosion of natural	
Celeriari	1710/2011					deposits, discharge from mines and chemicals manufacturers, runoff from	
						livestock lots (feed additive)	
Simazine	9/18/2014	<0.30		4	4	Herbicide runoff	
Thallium	7/18/2017	<1.0		2	0.01	Leaching from ore-processing sites, discharge from electronic, glass	
Triamorri	7710/2017	1.0				and drug factories.	

TABLE 5 - DETECTION OF C								Page 5 of 6
Chemical or Constituent	Sample	Level	Range of	MCL	PHG	Typical Source		
(and reporting units)	Date	Detected	Detections		(MCLG)	of Contaminant		
Color	7/18/2017	1.000		15		Naturally occurring organic materials		
Foaming Agents	7/18/2017	<0.10				Municipal and industrial waste discharges		
Turbidity	7/18/2017	0.4		5		Soil runoff		
Total dissolved solids	7/18/2017	370.0		1000		Runoff/leaching from natural deposits		
Specific Conductance	7/18/2017	582.0		1600		Substances that form ions when in water		
Chloride	7/18/2017	15.0		500		Runoff/leaching from natural deposits		
Sodium	7/18/2017	12.0		None		Generally found in ground and surface water		
Sulfate	7/18/2017	29.0		500		Runoff/leaching from natural deposits		
	7							
				11931 - 129 - 149 (119 - 119 - 119 - 119 - 119 - 119 - 119 - 119 - 119 - 119 - 119 - 119 - 119 - 119 - 119 - 1				
							,	

ADDITIONAL GENERAL INFORMATION ON DRINKING WATER	Page 6 of 6
Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some	
contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk.	
More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe	
Drinking Water Hotline (1-800-426-4791).	
Some people may be more vulnerable to contaminants in drinking water than the general population.	
Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who	
have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some	
elderly, and infants can be particularly at risk from infections. These people should seek advice about	
drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines	
on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial	
contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).	
Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause	
serious health problems, especially for pregnant women and young children. Lead in drinking water	
is primarily from materials and components associated with service lines and home plumbing.	
Clark Street Community Well is responsible for providing high quality drinking water, but cannot	
control the variety of materials used in plumbing components. When your water has been sitting for	
several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds	
to 2 minutes before using water for drinking or cooking. If you do so, you may wish to collect the	
flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned	,
about lead in your water, you may wish to have your water tested. Information on lead in drinking water,	
testing, methods, and steps you can take to minimize exposure is available from the Safe Drinking	
Water Hotline (1-800-426-4701) or at http://www.epa.gov/lead.	
While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic.	
The arsenic standard balances the current understanding of arsenic's possible health effects against the cost of	
removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the	
health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high	
concentrations and is linked to other health effects such as skin damage and circulatory problems.	

APPENDIX A: Regulated Contaminants with Primary Drinking Water Standards

Key

AL = Regulatory Action Level

MCL = Maximum Contaminant Level

MCLG = Maximum Contaminant Level Goal

MRDL = Maximum Residual Disinfectant Level

MRDLG = Maximum Residual Disinfectant Level Goal

PHG = Public Health Goal

TT = Treatment Technique

MFL = million fibers per liter

NTU = Nephelometric Turbidity Units

N/A = not applicable

pCi/L = picocuries per liter (a measure of radioactivity)

mrem/year = millirems per year (a measure of radiation

absorbed by the body)

ppm = parts per million, or milligrams per liter (mg/L) ppb = parts per billion, or micrograms per liter (μ g/L)

ppt = parts per trillion, or nanograms per liter (ng/L)

ppq = parts per quadrillion, or picograms per liter (pg/L)

Microbiological Contaminants

Contaminant (CCR units)	Traditional MCL	To convert for CCR, multiply by	MCL in CCR units	PHG (MCLG) in CCR units	Major Sources of Contamination	Health Effects Language
Total Coliform Bacteria (state Total Coliform Rule)	MCL: Systems that collect ≥40 samples/month: 5.0% of monthly samples are positive; Systems that collect <40 samples/month: 1 positive monthly sample			(0)	Naturally present in the environment	Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.
Fecal Coliform and E. coli (state Total Coliform Rule)	MCL: A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive			(0)	Human and animal fecal waste	Fecal coliforms and <i>E. coli</i> are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.
Total Coliform Bacteria (federal Revised Total Coliform Rule)	TT	N/A	TT	N/A	Naturally present in the environment	Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

Contaminant (CCR units)	Traditional MCL	To convert for CCR, multiply by	MCL in CCR units	PHG (MCLG) in CCR units	Major Sources of Contamination	Health Effects Language
						E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems.
						For the consumer confidence report, if a water system detects E. coli and has violated the E. coli MCL, the water system shall include the following statements, as appropriate.
E. coli (federal Revised Total Coliform Rule)	Footnote ¹	N/A	Footnote ¹	(0)	Human and animal fecal waste	 We had an <i>E. coli</i>-positive repeat sample following a total coliform-positive routine sample. We had a total coliform-positive repeat sample following an <i>E. coli</i>-positive routine sample. We failed to take all required repeat samples following an <i>E. coli</i>-positive routine sample. We failed to test for <i>E. coli</i> when any repeat sample tests positive for total coliform.
						If the E. coli MCL was not violated, the water system may include a statement that explains that although E. coli was detected, the water system is not in violation of the E. coli MCL.
E. coli (federal Revised Total Coliform Rule)	TT	N/A	TT	N/A	Human and animal fecal waste	E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems.
Fecal Indicator E. coli (Ground Water Rule)	0	N/A	0	(0)	Human and animal fecal waste	Fecal coliforms and <i>E. coli</i> are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

¹ Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Contaminant (CCR units)	Traditional MCL	To convert for CCR, multiply by	MCL in CCR units	PHG (MCLG) in CCR units	Major Sources of Contamination	Health Effects Language
Fecal Indicators (enterococci or coliphage) (Ground Water Rule)	TT	N/A	TT	N/A	Human and animal fecal waste	Fecal indicators are microbes whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.
Turbidity	TT	N/A	TT	N/A	Soil runoff	Turbidity has no health effects. However, high levels of turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
Giardia lamblia, Viruses, Heterotrophic Plate Count Bacteria, Legionella, Cryptosporidium	Surface water	er treatment =	TT	HPC = N/A; Others = (0)	Naturally present in the environment	Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Radioactive Contaminants

Contaminant (CCR units)	Traditional MCL	To convert for CCR, multiply by	MCL in CCR units	PHG (MCLG) in CCR units	Major Sources in Drinking Water	Health Effects Language
Gross Beta Particle Activity (pCi/L)	50 ²	N/A	50	(0)		Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta and photon emitters in excess of the MCL over many years may have an increased risk of getting cancer.
Strontium-90 (pCi/L)	8	N/A	8	0.35	Decay of natural and man-made deposits	Some people who drink water containing strontium-90 in excess of the MCL over many years may have an increased risk of getting cancer.
Tritium (pCi/L)	20,000	N/A	20,000	400		Some people who drink water containing tritium in excess of the MCL over many years may have an increased risk of getting cancer.
Gross Alpha Particle Activity (pCi/L)	15	N/A	15	(0)	Erosion of natural deposits	Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

² Effective June 11, 2006, the gross beta particle activity MCL is 4 millirem/year annual dose equivalent to the total body or any internal organ. 50 pCi/L is used as a screening level.

Contaminant (CCR units)	Traditional MCL	To convert for CCR, multiply by	MCL in CCR units	PHG (MCLG) in CCR units	Major Sources in Drinking Water	Health Effects Language
Combined Radium (pCi/L)	5	N/A	5	$(0)^3$	Erosion of natural deposits	Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.
Total Radium (pCi/L) (for nontransient-noncommunity water systems)	5	N/A	5	N/A	Erosion of natural deposits	Some people who drink water containing radium 223, 224, or 226 in excess of the MCL over many years may have an increased risk of getting cancer.
Uranium (pCi/L)	20	N/A	20	0.43	Erosion of natural deposits	Some people who drink water containing uranium in excess of the MCL over many years may have kidney problems or an increased risk of getting cancer.

Inorganic Contaminants

Contaminant (CCR units)	Traditional MCL in mg/L	To convert for CCR, multiply by	MCL in CCR units	PHG (MCLG) in CCR units	Major Sources in Drinking Water	Health Effects Language			
Aluminum (mg/L)	1	-	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes	Some people who drink water containing aluminum in excess of the MCL over many years may experience short-term gastrointestinal tract effects.			
Antimony (µg/L)	0.006	1,000	6	1	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder	Some people who drink water containing antimony in excess of the MCL over many years may experience increases in blood cholesterol and decreases in blood sugar.			
Arsenic (μg/L)	0.010	1,000	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes	Some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems, and may have an increased risk of getting cancer.			
Asbestos (MFL)	7 MFL	-	7	7	Internal corrosion of asbestos cement water mains; erosion of natural deposits	Some people who drink water containing asbestos in excess of the MCL over many years may have an increased risk of developing benign intestinal polyps.			
Barium (mg/L)	1	-	1	2	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits	Some people who drink water containing barium in excess of the MCL over many years may experience an increase in blood pressure.			
Beryllium (µg/L)	0.004	1,000	4	1	Discharge from metal refineries, coal-burning factories, and electrical, aerospace, and defense industries	Some people who drink water containing beryllium in excess of the MCL over many years may develop intestinal lesions.			

³ If reporting results for Ra-226 and Ra-228 as individual constituents, the PHG is 0.05 pCi/L for Ra-226 and 0.019 pCi/L for Ra-228.

Contaminant (CCR units)	$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$		Drinking Water	Health Effects Language				
Cadmium (μg/L)			0.04	pipes; erosion of natural deposits; discharge from electroplating and industrial chemical factories, and	Some people who drink water containing cadmium in excess of the MCL over many years may experience kidney damage.			
Chromium [Total] (μg/L)	0.05	1,000	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits	Some people who use water containing chromium in excess of the MCL over many years may experience allergic dermatitis.		
Copper (mg/L)	AL = 1.3	-	AL = 1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time may experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years may suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.		
Cyanide (µg/L)	0.15	1,000	150	150	Discharge from steel/metal, plastic and fertilizer factories	Some people who drink water containing cyanide in excess of the MCL over many years may experience nerve damage or thyroid problems.		
Fluoride (mg/L)	2.0	. -	2.0	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories	Some people who drink water containing fluoride in excess of the federal MCL of 4 mg/L over many years may get bone disease, including pain and tenderness of the bones. Children who drink water containing fluoride in excess of the state MCL of 2 mg/L may get mottled teeth.		
Lead (μg/L)	AL = 0.015	1,000	AL = 15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits	Infants and children who drink water containing lead in excess of the action level may experience delays in their physical or mental development. Children may show slight deficits in attention span and learning abilities. Adults who drink this water over many years may develop kidney problems or high blood pressure.		
Mercury [Inorganic] (μg/L)	0.002	1,000	2	1.2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills and cropland	Some people who drink water containing mercury in excess of the MCL over many years may experience mental disturbances, or impaired physical coordination, speech and hearing.		
Nickel (μg/L)	0.1	1,000	100	12	Erosion of natural deposits; discharge from metal factories	Some people who drink water containing nickel in excess of the MCL over many years may experience liver and heart effects.		

Contaminant (CCR units)	Traditional MCL in mg/L	To convert for CCR, multiply by	MCL in CCR units	PHG (MCLG) in CCR units	Major Sources in Drinking Water	Health Effects Language			
Nitrate (mg/L)	10 (as N)	-	10 (as N)	10 (as N)	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits	Infants below the age of six months who drink water containing nitrate in excess of the MCL may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. High nitrate levels may also affect the oxygen-carrying ability of the blood of pregnant women.			
Nitrite (mg/L)	1 (as N)	-	1 (as N)	1 (as N)	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits	Infants below the age of six months who drink water containing nitrite in excess of the MCL may quickly become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blueness of the skin.			
Perchlorate (μg/L)	0.006	1,000	6	1	Perchlorate is an inorganic chemical used in solid rocket propellant, fireworks, explosives, flares, matches, and a variety of industries. It usually gets into drinking water as a result of environmental contamination from historic aerospace or other industrial operations that used or use, store, or dispose of perchlorate and its salts.	Perchlorate has been shown to interfere with uptake of iodide by the thyroid gland, and to thereby reduce the production of thyroid hormones, leading to adverse effects associated with inadequate hormone levels. Thyroid hormones are needed for normal prenatal growth and development of the fetus, as well as for normal growth and development in the infant and child. In adults, thyroid hormones are needed for normal metabolism and mental function.			
Selenium (μg/L)	0.05	1,000	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)	Selenium is an essential nutrient. However, some people who drink water containing selenium in excess of the MCL over many years may experience hair or fingernail losses, numbness in fingers or toes, or circulation system problems.			
Thallium (µg/L)	0.002	1,000	2	0.1	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories	Some people who drink water containing thallium in excess of the MCL over many years may experience hair loss, changes in their blood, or kidney, intestinal, or liver problems.			

Synthetic Organic Contaminants including Pesticides and Herbicides

Contaminant (CCR units)	Traditional MCL in mg/L	To convert for CCR, multiply by	MCL in CCR units	PHG (MCLG) in CCR units	Major Sources in Drinking Water	Health Effects Language				
2,4-D (µg/L)	0.07	1,000	70	20	Runoff from herbicide used on row crops, range land, lawns, and aquatic weeds	Some people who use water containing the weed killer 2,4-D in excess of the MCL over many years may experience kidney, liver, o adrenal gland problems.				
2,4,5-TP [Silvex] (μg/L)	0.05	1,000	50	3	Residue of banned herbicide	Some people who drink water containing Silvex in excess of the MCL over many years may experience liver problems.				
Acrylamide	TT	z=	ТТ	(0)	Added to water during sewage/wastewater treatment	Some people who drink water containing high levels of acrylamide over a long period of time may experience nervous system or blood problems, and may have an increased risk of getting cancer.				
Alachlor (μg/L)	0.002	1,000	2	4	Runoff from herbicide used on row crops	Some people who use water containing alachlor in excess of the MCL over many years may experience eye, liver, kidney, or spleen problems, or experience anemia, and may have an increased risk of getting cancer.				
Atrazine (μg/L)	0.001	1,000	1	0.15	Runoff from herbicide used on row crops and along railroad and highway right- of-ways	Some people who use water containing atrazine in excess of the MCL over many years may experience cardiovascular system problems or reproductive difficulties.				
Bentazon (μg/L)	0.018	1,000	18	200	Runoff/leaching from herbicide used on beans, peppers, corn, peanuts, rice, and ornamental grasses	Some people who drink water containing bentazon in excess of the MCL over many years may experience prostate and gastrointestinal effects.				
Benzo(a)pyrene [PAH] (ng/L)	0.0002	1,000,000	200	7	Leaching from linings of water storage tanks and distribution mains	Some people who use water containing benzo(a)pyrene in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer.				
Carbofuran (μg/L)	0.018	1,000	18	0.7	Leaching of soil fumigant used on rice and alfalfa, and grape vineyards	Some people who use water containing carbofuran in excess of the MCL over many years may experience problems with their blood, or nervous or reproductive system problems.				
Chlordane (ng/L)	0.0001	1,000,000	100	30	Residue of banned insecticide	Some people who use water containing chlordane in excess of the MCL over many years may experience liver or nervous system problems, and may have an increased risk of getting cancer.				
Dalapon (μg/L)	0.2	1,000	200	790	Runoff from herbicide used on rights-of-way, and crops and landscape maintenance	Some people who drink water containing dalapon in excess of the MCL over many years may experience minor kidney changes.				
Di(2-ethylhexyl) Adipate (µg/L)	0.4	1,000	400	200	Discharge from chemical factories	Some people who drink water containing di(2-ethylhexyl) adipate in excess of the MCL over many years may experience weight loss, liver enlargement, or possible reproductive difficulties.				

Contaminant (CCR units)	Traditional MCL in mg/L	L in for CCR, CCR in CCR units			Health Effects Language			
Di(2-ethylhexyl) Phthalate (μg/L)	1) 0 004 1 000 4 12 chemical factories: inert			Some people who use water containing di(2-ethylhexyl) phthalate well in excess of the MCL over many years may experience liver problems or reproductive difficulties, and may have an increased risk of getting cancer.				
Dibromochloropropane [DBCP] (ng/L)	0.0002	1,000,000	200	1.7	Banned nematocide that may still be present in soils due to runoff/leaching from former use on soybeans, cotton, vineyards, tomatoes, and tree fruit	Some people who use water containing DBCP in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer.		
Dinoseb (μg/L)	0.007	1,000	7	14	Runoff from herbicide used on soybeans, vegetables, and fruits	Some people who drink water containing dinoseb in excess of the MCL over many years may experience reproductive difficulties.		
Dioxin [2,3,7,8-TCDD] (pg/L)	0.00000003	1,000,000,000	30	0.05	Emissions from waste incineration and other combustion; discharge from chemical factories	Some people who use water containing dioxin in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer.		
Diquat (μg/L)	0.02	1,000	20	6	Runoff from herbicide use for terrestrial and aquatic weeds	Some people who drink water containing diquat in excess of the MCL over many years may get cataracts.		
Endothall (µg/L)	0.1	1,000	100	94	Runoff from herbicide use for terrestrial and aquatic weeds; defoliant	Some people who drink water containing endothall in excess of the MCL over many years may experience stomach or intestinal problems.		
Endrin (μg/L)	0.002	1,000	2	0.3	Residue of banned insecticide and rodenticide	Some people who drink water containing endrin in excess of the MCL over many years may experience liver problems.		
Epichlorohydrin	TT	-	TT	(0)	Discharge from industrial chemical factories; impurity of some water treatment chemicals	Some people who drink water containing high levels of epichlorohydrin over a long period of time may experience stomach problems, and may have an increased risk of getting cancer.		
Ethylene Dibromide [EDB] (ng/L)	0.00005	1,000,000	50	10	Discharge from petroleum refineries; underground gas tank leaks; banned nematocide that may still be present in soils due to runoff and leaching from grain and fruit crops	risk of getting cancer.		
Glyphosate (µg/L)	0.7	1,000	700	900	Runoff from herbicide use	Some people who drink water containing glyphosate in excess of the MCL over many years may experience kidneys problems or reproductive difficulties.		

Contaminant (CCR units)	Traditional MCL in mg/L	To convert for CCR, multiply by	MCL in CCR units	PHG (MCLG) in CCR units	Major Sources in Drinking Water	Health Effects Language
Heptachlor (ng/L)	0.00001	1,000,000	10	8	Residue of banned insecticide	Some people who use water containing heptachlor in excess of the MCL over many years may experience liver damage and may have an increased risk of getting cancer.
Heptachlor Epoxide (ng/L)	0.00001	1,000,000	10	6	Breakdown of heptachlor	Some people who use water containing heptachlor epoxide in excess of the MCL over many years may experience liver damage, and may have an increased risk of getting cancer.
Hexachlorobenzene (μg/L)	0.001	1,000	1	0.03	Discharge from metal refineries and agricultural chemical factories; byproduct of chlorination reactions in wastewater	Some people who drink water containing hexachlorobenzene in excess of the MCL over many years may experience liver or kidney problems, or adverse reproductive effects, and may have an increased risk of getting cancer.
Hexachlorocyclo- pentadiene (μg/L)	0.05	1,000	50	2	Discharge from chemical factories	Some people who use water containing hexachlorocyclopentadiene in excess of the MCL over many years may experience kidney or stomach problems.
Lindane (ng/L)	0.0002	1,000,000	200	32	Runoff/leaching from insecticide used on cattle, lumber, and gardens	Some people who drink water containing lindane in excess of the MCL over many years may experience kidney or liver problems.
Methoxychlor (µg/L)	0.03	1,000	30	0.09	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, and livestock	Some people who drink water containing methoxychlor in excess of the MCL over many years may experience reproductive difficulties.
Molinate [Ordram] (μg/L)	0.02	1,000	20	1	Runoff/leaching from herbicide used on rice	Some people who use water containing molinate in excess of the MCL over many years may experience reproductive effects.
Oxamyl [Vydate] (µg/L)	0.05	1,000	50	26	Runoff/leaching from insecticide used on field crops, fruits and ornamentals, especially apples, potatoes, and tomatoes	Some people who drink water containing oxamyl in excess of the MCL over many years may experience slight nervous system effects.
PCBs [Polychlorinated Biphenyls] (ng/L)	0.0005	1,000,000	500	90	Runoff from landfills; discharge of waste chemicals	Some people who drink water containing PCBs in excess of the MCL over many years may experience changes in their skin, thymus gland problems, immune deficiencies, or reproductive or nervous system difficulties, and may have an increased risk of getting cancer.
Pentachlorophenol (μg/L)	0.001	1,000	1	0.3	Discharge from wood preserving factories, cotton and other insecticidal/herbicidal uses	Some people who use water containing pentachlorophenol in excess of the MCL over many years may experience liver or kidney problems, and may have an increased risk of getting cancer.
Picloram (μg/L)	0.5	1,000	500	166	Herbicide runoff	Some people who drink water containing picloram in excess of the MCL over many years may experience liver problems.

Contaminant (CCR units)	Traditional MCL in mg/L	To convert for CCR, multiply by	MCL in CCR units	PHG (MCLG) in CCR units	Major Sources in Drinking Water	Health Effects Language
Simazine (µg/L)	0.004	1,000	4	4	Herbicide runoff	Some people who use water containing simazine in excess of the MCL over many years may experience blood problems.
Thiobencarb (μg/L)	0.07	1,000	70	42	Runoff/leaching from herbicide used on rice	Some people who use water containing thiobencarb in excess of the MCL over many years may experience body weight and blood effects.
Toxaphene (μg/L)	0.003	1,000	3	0.03	Runoff/leaching from insecticide used on cotton and cattle	Some people who use water containing toxaphene in excess of the MCL over many years may experience kidney, liver, or thyroid problems, and may have an increased risk of getting cancer.
1,2,3-Trichloropropane [TCP] (μg/L)	0.000005	1,000	0.005	0.0007	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.	Some people who drink water containing 1,2,3-trichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.

Volatile Organic Contaminants

Contaminant (CCR units)	Traditional MCL in mg/L	To convert for CCR, multiply by	MCL in CCR units	PHG (MCLG) in CCR units	Major Sources in Drinking Water	Health Effects Language
Benzene (μg/L)	0.001	1,000	1	0.15	Discharge from plastics, dyes and nylon factories; leaching from gas storage tanks and landfills	Some people who use water containing benzene in excess of the MCL over many years may experience anemia or a decrease in blood platelets, and may have an increased risk of getting cancer.
Carbon Tetrachloride (ng/L)	0.0005	1,000,000	500	100	Discharge from chemical plants and other industrial activities	Some people who use water containing carbon tetrachloride in excess of the MCL over many years may experience liver problems and may have an increased risk of getting cancer.
1,2-Dichlorobenzene (µg/L)	0.6	1,000	600	600	Discharge from industrial chemical factories	Some people who drink water containing 1,2-dichlorobenzene in excess of the MCL over many years may experience liver, kidney, or circulatory system problems.
1,4-Dichlorobenzene (µg/L)	0.005	1,000	5	6	Discharge from industrial chemical factories	Some people who use water containing 1,4-dichlorobenzene in excess of the MCL over many years may experience anemia, liver, kidney, or spleen damage, or changes in their blood.

Contaminant (CCR units) Traditiona MCL in mg/L		MCL in 10r CCR, multiply		PHG (MCLG) in CCR units	Major Sources in Drinking Water	Health Effects Language			
1,1-Dichloroethane (μg/L)	0.005	1,000	5	3	Extraction and degreasing solvent; used in manufacture of pharmaceuticals, stone, clay and glass products; fumigant	Some people who use water containing 1,1-dichloroethane in excess of the MCL over many years may experience nervous system or respiratory problems.			
1,2-Dichloroethane (ng/L)	0.0005	1,000,000	500	400	Discharge from industrial chemical factories	Some people who use water containing 1,2-dichloroethane in excess of the MCL over many years may have an increased risk of getting cancer.			
1,1-Dichloroethylene (µg/L)	0.006	1,000	6	10	Discharge from industrial chemical factories	Some people who use water containing 1,1-dichloroethylene in excess of the MCL over many years may experience liver problems.			
cis-1,2-Dichloroethylene (µg/L)	0.006	1,000	6	100	Discharge from industrial chemical factories; major biodegradation byproduct of TCE and PCE groundwater contamination	Some people who use water containing cis-1,2-dichloroethylene in excess of the MCL over many years may experience liver problems.			
rans-1,2-Dichloroethylene _{0.01} μg/L)		01 1,000 10		60	Discharge from industrial chemical factories; minor biodegradation byproduct of TCE and PCE groundwater contamination	Some people who drink water containing trans-1,2-dichloroethyle in excess of the MCL over many years may experience liver problems.			
Dichloromethane (µg/L)	0.005	1,000	5	4	Discharge from pharmaceutical and chemical factories; insecticide	Some people who drink water containing dichloromethane in excess of the MCL over many years may experience liver problems and may have an increased risk of getting cancer.			
1,2-Dichloropropane (μg/L)	0.005	1,000	5	0.5	Discharge from industrial chemical factories; primary component of some fumigants	Some people who use water containing 1,2-dichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.			
1,3-Dichloropropene (ng/L)	0.0005	1,000,000	500	200	Runoff/leaching from nematocide used on croplands	Some people who use water containing 1,3-dichloropropene in excess of the MCL over many years may have an increased risk of getting cancer.			
Ethylbenzene (µg/L)	0.3	1,000	300	300	Discharge from petroleum refineries; industrial chemical factories	Some people who use water containing ethylbenzene in excess of the MCL over many years may experience liver or kidney problems.			
Methyl-tert-butyl ether (μg/L)	0.013	1,000	13	13	Leaking underground storage tanks; discharge from petroleum and chemical factories	Some people who use water containing methyl-tert-butyl ether in excess of the MCL over many years may have an increased risk of getting cancer.			

Contaminant (CCR units)	Traditional MCL in mg/L	To convert for CCR, multiply by	MCL in CCR units	PHG (MCLG) in CCR units	Major Sources in Drinking Water	Health Effects Language
Monochlorobenzene (μg/L)	0.07	1,000	70	70	Discharge from industrial and agricultural chemical factories and dry cleaning facilities	Some people who use water containing monochlorobenzene in excess of the MCL over many years may experience liver or kidney problems.
Styrene (µg/L)	0.1	1,000	100	0.5	Discharge from rubber and plastic factories; leaching from landfills	Some people who drink water containing styrene in excess of the MCL over many years may experience liver, kidney, or circulatory system problems.
$1,1,2,2$ -Tetrachloroethane ($\mu g/L$)	0.001	1,000	1	0.1	Discharge from industrial and agricultural chemical factories; solvent used in production of TCE, pesticides, varnish and lacquers	Some people who drink water containing 1,1,2,2-tetrachloroethane in excess of the MCL over many years may experience liver or nervous system problems.
Tetrachloroethylene (PCE) (µg/L)	0.005	1,000	5	0.06	Discharge from factories, dry cleaners, and auto shops (metal degreaser)	Some people who use water containing tetrachloroethylene in excess of the MCL over many years may experience liver problems, and may have an increased risk of getting cancer.
1,2,4-Trichlorobenzene (µg/L)	0.005	1,000	5	5	Discharge from textile- finishing factories	Some people who use water containing 1,2,4-trichlorobenzene in excess of the MCL over many years may experience adrenal gland changes.
1,1,1-Trichloroethane (μg/L)	0.200	1,000	200	1000	Discharge from metal degreasing sites and other factories; manufacture of food wrappings	Some people who use water containing 1,1,1-trichloroethane in excess of the MCL over many years may experience liver, nervous system, or circulatory system problems.
1,1,2-Trichloroethane (µg/L)	0.005	1,000	5	0.3	Discharge from industrial chemical factories	Some people who use water containing 1,1,2-trichloroethane in excess of the MCL over many years may experience liver, kidney or immune system problems.
Trichloroethylene [TCE] (μg/L)	0.005	1,000	5	1.7	Discharge from metal degreasing sites and other factories	Some people who use water containing trichloroethylene in excess of the MCL over many years may experience liver problems and may have an increased risk of getting cancer.
Toluene (µg/L)	0.15	1,000	150	150	Discharge from petroleum and chemical factories; underground gas tank leaks	Some people who use water containing toluene in excess of the MCL over many years may experience nervous system, kidney, or liver problems.
Trichlorofluoromethane (µg/L)	0.15	1,000	150	1300	Discharge from industrial factories; degreasing solvent; propellant and refrigerant	Some people who use water containing trichlorofluoromethane in excess of the MCL over many years may experience liver problems.
1,1,2-Trichloro-1,2,2-trifluoroethane (mg/L)	1.2		1.2	4	Discharge from metal degreasing sites and other factories; dry-cleaning solvent; refrigerant	Some people who use water containing 1,1,2-trichloro-1,2,2-trifluoroethane in excess of the MCL over many years may experience liver problems.

Health Effects Language	Major Sources in Drinking Water Leaching from PVC piping;	PHG (MCLG) in CCR units	MCL in CCR units	To convert for CCR, multiply by	Traditional MCL in mg/L	Contaminant (CCR)
Some people who use water containing vinyl chloride in excess of the MCL over many years may have an increased risk of getting cancer.	discharge from plastics factories; biodegradation byproduct of TCE and PCE groundwater contamination	0\$	200	000'000' I	\$000.0	Vinyl Chloride (ng/L)
Some people who use water containing xylenes in excess of the MCI over many years may experience nervous system damage.	Discharge from petroleum and chemical factories; fuel solvent	8.1	0 <i>ST</i> .1	-	OST.I	Xylenes (mg/L)

Disinfection Byproducts, Disinfectant Residuals, and Disinfection Byproduct Precursors

and young children who drink water containing chlorite re MCL could experience nervous system effects. s may occur in fetuses of pregnant women who drink ing chlorite in excess of the MCL. Some people may emia.	in excess of the Similar effects	Byproduct of drinking water disinfection	\$0.0	0.1		0.1	Chlorite (mg/L)
who use water containing chlorine well in excess of the experience irritating effects to their eyes and nose. who drink water containing chlorine well in excess of uld experience stomach discomfort.	MRDL could Some people of the MRDL co	Drinking water disinfectant added for treatment	[MKDLG = 4 (as Cl2)]	[MRDL = 4.0 (as	-	$[MRDL = Cl_2]$	(J\gm) enirold
who use water containing chloramines well in excess of uld experience irritating effects to their eyes and nose. who drink water containing chloramines well in excess could experience stomach discomfort or anemia.	the MRDL cor of the MRDL of the	Drinking water disinfectant added for treatment	[MRDLG = 4 (as Cl ₂)]	[MRDL = 4.0 (as CI2)]	-	[MRDL = 4.0 (as Cl2)]	(A\gm) esnimeroldD
who drink water containing bromate in excess of the my years may have an increased risk of getting cancer.	MCL over ma	Byproduct of drinking water disinfection	1.0	10	000'I	010.0	Bromate (µg/L)
who drink water containing haloacetic acids in excess of many years may have an increased risk of getting	the MCL over cancer.		V/N	09	000'I	090.0	AAAS [Sum of 5 Haloacetic (J\2)
who drink water containing trihalomethanes in excess of many years may experience liver, kidney, or central m problems, and may have an increased risk of getting	the MCL over nervous syster cancer.	Byproduct of drinking water disinfection	V/N	08	1,000	080.0	TTHMs [Total (Lgul) (Lgul)
Health Effects Language	5	Major Sources in Drinking Water	WEDEC OL (WCEC) PHG,	MCL or [MRDL] in CCR units	To convert multiply by	Traditional MCL or [MRDL] in mg/L	Contaminant (CCR units)

Contaminant (CCR units)	Traditional MCL or [MRDL] in mg/L	for CCP	in CCR	PHG, (MCLG) or [MRDLG]	Major Sources in Drinking Water	Health Effects Language
Chlorine Dioxide (µg/L)	[MRDL = 0.8 (as ClO ₂)]	1,000	[MRDL = 800 (as ClO ₂)]	[MRDLG = 800 (as ClO ₂)]	Drinking water disinfectant added for treatment	Some infants and young children who drink water containing chlorine dioxide in excess of the MRDL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorine dioxide in excess of the MRDL. Some people may experience anemia.
Control of DBP Precursors (TOC)	TT	-	TT	N/A	Various natural and manmade sources	Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of cancer.

APPENDIX B: Regulated Contaminants with Secondary Drinking Water Standards

Monitoring required by section 64449 of the California Code of Regulations, Title 22.

Constituent	Secondary MCL (units)	To convert to CCR, multiply by	MCL in CCR units	Typical Source of Contaminant Erosion of natural deposits; residual from some surface water treatment processes	
Aluminum	0.2 mg/L	1,000	200 μg/L		
Color	15 Units	-	15 Units	Naturally-occurring organic materials	
Copper	1.0 mg/L	-	1.0 mg/L	Internal corrosion of household plumbing systems; erosion of natur deposits; leaching from wood preservatives	
Foaming Agents [MBAS]	0.5 mg/L	1,000	500 μg/L	Municipal and industrial waste discharges	
Iron	0.3 mg/L	1,000	300 μg/L	Leaching from natural deposits; industrial wastes	
Manganese	0.05 mg/L	1,000	50 μg/L	Leaching from natural deposits	
Methyl- <i>tert</i> -butyl ether [MTBE]	0.005 mg/L	1,000	5 μg/L	Leaking underground storage tanks; discharge from petroleum and chemical factories	
OdorThreshold 3 Units		-	3 Units	Naturally-occurring organic materials	
Silver 0.1 mg/L		1,000	100 μg/L	Industrial discharges	
Thiobencarb	hiobencarb 0.001 mg/L		1 μg/L	Runoff/leaching from rice herbicide	
Turbidity 5 Units		L L	5 Units	Soil runoff	
Zinc	5.0 mg/L	-	5.0 mg/L	Runoff/leaching from natural deposits; industrial wastes	
Total Dissolved Solids [TDS]	1,000 mg/L	-	1,000 mg/L	Runoff/leaching from natural deposits	
Specific 1,600 Conductance µS/cm		-	1,600 Substances that form ions when in water; seawater influence		
Chloride	500 mg/L	-	500 mg/L	Runoff/leaching from natural deposit seawater influence	
Sulfate 500 mg/L		-	500 mg/L Runoff/leaching from natural depoindustrial wastes		

Note: There are no PHGs, MCLGs, or mandatory standard health effects language for these constituents because secondary MCLs are set on the basis of aesthetic concerns.

APPENDIX E: Special Language for Nitrate, Arsenic, Lead, Radon, *Cryptosporidium*, Ground Water Systems, and Surface Water Systems

(A) Nitrate: For systems that detect nitrate above 5 mg/L as nitrogen, but below 10 mg/L as nitrogen, the following language is REQUIRED:

Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

If a utility cannot demonstrate to the State Board with at least five years of the most current monitoring data that its nitrate levels are stable, it must also add the following language to the preceding statement on nitrate:

Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity.

(B) Arsenic: For systems that detect arsenic above 5 μ g/L, but below or equal to 10 μ g/L, the following language is REQUIRED:

While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

(C) Lead¹: Consistent with 40 CFR section 141.154(d)(1), every Consumer Confidence Report (CCR) must include the lead-specific language shown below. A water system may provide its own educational statement, but only after consulting with the State Board.

¹ All water systems are required to comply with the state Lead and Copper Rule (LCR). Water systems are also required to comply with the federal LCR, and its revisions and corrections. The 2007 Short-term Revisions of the LCR included mandatory language requirements that have not yet been adopted by the State Board.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [NAME OF UTILITY] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/lead.

Consistent with the California Code of Regulations, section 64482(c), systems that detect lead above 15 µg/L in more than 5 percent, and up to and including 10 percent, of sites sampled (or if your system samples fewer than 20 sites and has even one sample above the Action Level [AL]), the following language is REQUIRED:

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and/or flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the U.S. EPA Safe Drinking Water Hotline (1-800-426-4791).

(D) Radon: Systems that performed monitoring that indicates the presence of radon in the finished water MUST include the results of the monitoring and an explanation of the significance of the results. The following language MAY be used:

We constantly monitor the water supply for various contaminants. We have detected radon in the finished water supply in ____ out of ____ samples tested. There is no federal regulation for radon levels in drinking water. Exposure over a long period of time to air transmitting radon may cause adverse health effects.

The language below MAY be included if the level of information is helpful.

Radon is a radioactive gas that you cannot see, taste, or smell. It is found throughout the U.S. Radon can move up through the ground and into a home through cracks and holes in the foundation. Radon can build up to high levels in all types of homes. Radon can also get into indoor air when released from tap water from showering, washing dishes, and other household activities. Compared to radon entering the home through soil, radon entering the home through tap water will in most cases be a small source of radon in indoor air. Radon is a known human carcinogen. Breathing air containing radon can lead to lung cancer. Drinking water containing radon may also cause increased risk of

stomach cancer. If you are concerned about radon in your home, test the air in your home. Testing is inexpensive and easy. You should pursue radon removal for your home if the level of radon in your air is 4 picocuries per liter of air (pCi/L) or higher. There are simple ways to fix a radon problem that are not too costly. For additional information, call your State radon program (1-800-745-7236, the U.S. EPA Safe Drinking Water Act Hotline (1-800-426-4791), or the National Safe Council Radon Hotline (1-800-767-7236).

(E) Cryptosporidium: Systems that have performed any monitoring for Cryptosporidium that indicates that Cryptosporidium may be present in the source water or finished water MUST include the results of the monitoring and an explanation of the significance of the results. The following language MAY be used:

Cryptosporidium is a microbial pathogen found in surface water throughout the U.S. Although filtration removes Cryptosporidium, the most commonly-used filtration methods cannot guarantee 100 percent removal. Our monitoring indicates the presence of these organisms in our source water and/or finished water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of Cryptosporidium may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people, infants, small children, and the elderly are at greater risk of developing lifethreatening illness. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. Cryptosporidium must be ingested to cause disease, and it may be spread through means other than drinking water.

(F) Groundwater Systems: For ground water systems that had a treatment technique (TT) violation described in Item S of the document titled "Instructions for Completing the 2018 CCR for Small Water Systems", the following language MAY be used to describe the potential health effects. The U.S. Environmental Protection Agency (EPA) did not provide standard health effect language for these TT violations in the Ground Water Rule; U.S. EPA provided the language in their guidance to water systems.

Inadequately protected or treated water may contain disease-causing organisms. These organisms can cause symptoms such as diarrhea, nausea, cramps, and associated headaches.

(G) Surface Water Systems: For surface water systems that had a TT violation under the Surface Water Treatment Rule (SWTR), Interim Enhanced Surface Water Treatment Rule (IESWTR), Filter Backwash Recycling Rule (FBRR), or Long-term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR), as described in Item U of the document titled "Instructions for Completing the 2018 CCR for Small Water Systems", the following language is REQUIRED to describe the potential health effects:

Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

For surface water systems that had a TT violation under the Long-term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR), as described in Item U of the document titled "Instructions for Completing the 2018 CCR for Small Water Systems", the following language MAY be used to describe the potential health effects. U.S. EPA did not provide standard health effect language for these TT violations in the LT2ESWTR; U.S. EPA provided the language in their guidance to water systems.

LT2ESWTR TT Violation	Health Effect Language				
Uncovered and Untreated Finished Water Reservoir	Inadequately protected water may contain disease-causing organisms. These organisms can cause symptoms such as diarrhea, nausea, cramps, and associated headaches.				
Determine and Report Bin Classification	Inadequately treated water may contain disease-causing organisms. These organisms can cause symptoms such as diarrhea, nausea, cramps, and associated headaches.				
Provide or Install an Additional Level of Treatment	Inadequately treated water may contain disease-causing organisms. These organisms can cause symptoms such as diarrhea, nausea, cramps, and associated headaches.				

APPENDIX F: Certification Form (Suggested Format)

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(To certify electronic delivery of the CCR, use the certification form on the State Board's website at http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:		me: Clark Stre	Clark Street Community Well					
Water System Number: 1502056								
12 Furth	-17-2019 ner, the system	m certifies that the	customers (and appinformation contained	propriate notices of available of in the report is correct	eport was distributed on ability have been given). t and consistent with the entrol Board, Division of			
3		Name:	Deborah Eoff					
		Signature:	Debolah	Debolah Goth				
		Title:	Bookkeeper					
		Phone Number:	(760) 417-1364	Date:	12-17-2019			
	"Good faith following Post	n" efforts were use methods:	ed to reach non-bill	paying consumers. Th	ose efforts included the			
			ostal patrons within the service area (attach zip codes used)					
	Publ	Advertising the availability of the CCR in news media (attach copy of press release) Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)						
	 Posted the CCR in public places (attach a list of locations) Delivery of multiple copies of CCR to single-billed addresses serving several persons, sur as apartments, businesses, and schools 							
Delivery to community organizations (attach a list of organizations)								
	U Othe	er (attach a list of ot	ther methods used)					
		s serving at least 10 ng address: www	00,000 persons: Pos	ted CCR on a publicly-a	accessible internet site at			
	For investo	r-owned utilities: I	Delivered the CCR to	the California Public U	tilities Commission			
This	form is provided	as a convenience for use t	o meet the certification requ	irement of the California Code of	Regulations, section 64483(c).			