

APPENDIX B: eCCR Certification Form (Suggested Format)


Consumer Confidence Report Certification Form

(To be submitted with a copy of the CCR)

Water System Name:	City of Delano
Water System Number:	151005

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/28/2021 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by:

Name: Allen Lutz Jr.	Title: Water Superintendent
Signature: 	Date: 6/30/2021
Phone number: (661) 721-3350	blank

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- ☒ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- ☐ CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- ☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - ☒ Posting the CCR at the following URL: www.cityofdelano.org
 - ☒ Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - ☒ Posted the CCR in public places (attach a list of locations)
 - ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools

- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
- ☐ Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
- ☐ Other (attach a list of other methods used)
- ☐ *For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following URL: www._____
- ☐ *For privately-owned utilities:* Delivered the CCR to the California Public Utilities Commission

Consumer Confidence Report Electronic Delivery Certification

Water systems utilizing electronic distribution methods for CCR delivery must complete this page by checking all items that apply and fill-in where appropriate.

- ☐ Water system mailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available website where it can be viewed (attach a copy of the mailed CCR notification). URL: www._____
- ☐ Water system emailed a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed (attach a copy of the emailed CCR notification). URL: www._____
- ☐ Water system emailed the CCR as an electronic file email attachment.
- ☐ Water system emailed the CCR text and tables inserted or embedded into the body of an email, not as an attachment (attach a copy of the emailed CCR).
- ☐ *Requires prior DDW review and approval.* Water system utilized other electronic delivery method that meets the direct delivery requirement.

Provide a brief description of the water system's electronic delivery procedures and include how the water system ensures delivery to customers unable to receive electronic delivery.

*This form is provided as a convenience and may be used to meet the certification
requirement of
section 64483(c) of the California Code of Regulations.*



2020

ANNUAL WATER QUALITY REPORT

City of Delano – Prepared May 2021

This brochure is a report to consumers regarding the drinking water quality provided by the City of Delano. Included is an explanation of where our water comes from, the results of water quality testing and information on how to interpret this data. We share the results with you, so that you may have confidence in the quality of our drinking water.

We test the water quality for many constituents as required by both State and Federal Regulations. This report gives the results of our monitoring for the period of January 1 through-December 31, 2020.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards.

Este folleto contiene información muy importante sobre la calidad de su agua para beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Mahalaga ang impormasyong ito. Mangyaring ipasalin ito.

Water Source and Location

The City of Delano water system is supplied entirely with groundwater from aquifers beneath the city. There are fourteen wells supplying the water system (Well #32 is inactive). Source Locations are:

Well #20 – 22 nd & Kalibo	Well #31 – Diaz Ave&Channa Dr.
Well #22 – 5 th & Randolph	Well #32 – 400 block S. Lexington
Well #24 – 20 th & Flores	Well #33 – 20 th & Trenton
Well #25 – Schuster & S. Randolph	Well #34 – Stradley & Woollomes
Well #26 – Browning and Poplar	Well #35 – Austin & 1 st Avenue
Well #29 – Veneto & Primavera	Well #38 – S99 & County Line
Well #30 – County Line & Randolph	Well #39 – 21 st & Albany
	Well #40 – N. Kern State Prison

Drinking Water Assessment Information

A source water assessment was conducted for the City of Delano water supply wells in February 2015. The sources are considered most vulnerable to the following activities associated with contaminants detected in the water supply:

- Fertilizer / Pesticide / Herbicide Applications

The water sources are also considered most vulnerable to the following activities not associated with the detected contaminants:

- Automobile Repair Shops and Gas Stations
- Machine Shops
- Photo Processing / Printing/Dry Cleaners

For more information contact:

Department of Public Works, 725 S. Lexington Street, Delano, CA 93215. Telephone (661) 721-3350.

The City Council meets on the first and third Monday of each month at 5:30 pm in the City Hall Council Chambers located at 1015 Eleventh Avenue.

Terms used in this Report

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

µg/L: micrograms per liter or parts per billion (ppb)

ng/L: nanograms per liter or parts per trillion (ppt)

pg/L: picogram per liter or parts per quadrillion (ppq)

pCi/L: picocuries per liter (a measure of radiation)

<: less than

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the STATE Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, is more than one year old.

CITY OF DELANO WATER QUALITY TABLES
(For Explanation of Violations, See End of Tables)

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA							
Microbiological Contaminants	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria ¹		
Total Coliform Bacteria (STATE Total Coliform Rule)	0	0	1 positive monthly sample	0	Naturally present in the environment		
Fecal Coliform or <i>E. coli</i> (STATE Total Coliform Rule)	0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste		
<i>E. coli</i> (FEDERAL Revised Total Coliform Rule)	0	0	(a)	0	Human and animal fecal waste		
(a) Routine and repeat samples are total coliform-positive and either is <i>E. coli</i> -positive or system fails to take repeat samples following <i>E. coli</i> -positive routine sample or system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> . 1: Per the SWRCB CCR Guidelines							
TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper	Sample Date	No. of samples collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant ¹
Lead (ppb)	2020	50	9	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	2020	50	.077	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant ¹
Sodium (ppm)	2020	70.2	41-110	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2020	59.6	11-130	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

1: Per the SWRCB CCR Guidelines

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant ¹
Arsenic (ppb)	2020	6.84	ND-10.0	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium (ppm)	2020	0.12	ND-0.13	1	2	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (ppm)	2020	0.27	0.12-0.50	2	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Gross Alpha (pci/L)	2020	NA	NA	15	(0)	Erosion of natural deposits
Chrome VI (ppb) (Hexavalent Chromium)	2020	7.97	7.6-8.6	50	(100)	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits
Nitrate (ppm) (as Nitrogen, N)	2020	3.67	ND-8.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrite (ppm) (as Nitrogen, N)	2020	0.03	ND-0.09	1	1	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
TTHMs (ppb) (Total Trihalomethanes)	2020	17.37	6.9-39	80	N/A	By-product of drinking water disinfection
Haloacetic Acids (ppb)	2020	4.85	ND-11	60	N/A	Byproduct of drinking water disinfection
Dibromochloropropane (ppt) (DBCP)	2020	22	ND-35	200	1.7	Banned nematocide that may still be present in soils due to runoff/leaching from former use on soybeans, cotton, vineyards, tomatoes, and tree fruit
Chlorine (ppm)	2020	2.03	1.46-2.88	4	4	Drinking water for disinfectant added for treatment

1: Per the SWRCB CCR Guidelines

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant ¹
Iron (ppb)	2020	ND	ND	300	-	Leaching from natural deposits; industrial waste
Turbidity (NTU)	2020	0.3	0.1-0.87	5	-	Soil Runoff
Total Dissolved Solids (ppm)	2020	58	210-470	1000	-	Runoff/leaching from natural deposits
Specific Conductance (μ S/cm)	2020	459	290-710	1600	-	Substances from ions when in water; seawater influence
Chloride (ppm)	2020	53	14-130	500	-	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	2020	58	28-120	500	-	Runoff/leaching from natural deposits; industrial waste

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Health Effects Language
Trichloropropane ² (ppt) (1,2,3-TCP)	2020	5.83	ND-7.70	5	Some people who use water containing 1,2,3- trichloropropane in excess of the notification level over many years may have an increased risk of getting cancer, based on studies in laboratory animals.

1: Per the SWRCB CCR Guidelines

2: The MCL for 1,2,3 TCP is 5 ppt. The City is currently under a compliance order and is sampling all operational wells quarterly performing public notification.

Additional General Information on Drinking Water

While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The U.S. Environmental Protection Agency continue to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in human at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791) or the FDA which regulates bottled water.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Delano is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.