



## ANNUAL CONSUMER CONFIDENCE REPORT

**For the reporting period of January 1, 2024 through December 31, 2024**

### WHAT IS THIS REPORT?

The Rosamond Community Services District (RCSD) is proud of the fine drinking water it provides. This annual water quality report shows the source of our water, lists the results of our tests, and contains important information about water and health.

### WHERE DOES THE WATER COME FROM?

The Rosamond CSD provides water from a blend of surface and groundwater. The Antelope Valley East Kern Water Agency (AVEK) supplies surface water to us. Surface water is blended with water from the Districts two (2) producing water wells and then is distributed through the distribution system to your home. The District also maintains six and one-half million gallons of water storage in five above ground tanks so that you can have drinking water available to your homes.

### WHAT SHOULD BE IN MY WATER?

The source of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

### IMPORTANT HEALTH INFORMATION

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Center for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791) or visit [www.epa.gov/safe](http://www.epa.gov/safe) water.



Rosamond, CA 93560  
3179 35th Street West



PERMIT NO. 1233  
PAID  
U.S. POSTAGE



WHAT ABOUT ARSENIC?

The EPA has been reviewing the drinking water standard for arsenic because of concerns that it may not be stringent enough. In January 2001, the EPA set the new arsenic MCL at 10 ppb. By January 2006 all water systems were required to meet the new arsenic MCL.

While your drinking water meets the current standard for arsenic, it does contain low levels of arsenic. The standard balances the current understanding of arsenic’s possible health effects against the cost of removing arsenic from drinking water. The State Water Resource Control Board continues to re-search the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and other circulatory problems.

HOW TO READ YOUR WATER QUALITY SUMMARY

Our water is tested regularly for many contaminants. The results of tests performed in 2024 are presented here.

The Public Health goal or PHG is the level of a contaminant in drinking water below which there are no known or a health risk. PHGs are set by California Environmental Protection Agency. If the number in this column is in parentheses, it is the Maximum Contaminant Level Goal or MCLG. This is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Maximum Contaminant Level or MCL is the highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Average and Range shows the results observed in our water during the most recent round of testing. AVERAGE is the average of values detected for each contaminant. RANGE is the range of all tested levels from low to high during the testing period.

Source of Contaminants provides an explanation of the typical natural or man-made origins of the contaminant.

Regulatory Action Level (AL) is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Treatment Technique (TT) is a required process intended to reduce the level of a contaminants in drinking water.

Primary Drinking Water Standard (PDWS) MCLs for contaminants that affect health along with their monitoring and reporting requirements and water treatment requirements.

WHAT CONTAMINANTS MIGHT BE IN THE WATER?

Contaminants that may be present in source water include:

(A) Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

(B) Inorganic contaminants, such as salts and metals, that can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

(C) Pesticides and herbicides that may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

(D) Organic chemical contaminants, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems.

(E) Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

In order to insure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the State Water Resource Control Board (Department) prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provides the same protection for public health.

Rosamond Community Services District welcomes any questions or comments. The Board of Directors of the Rosamond Community Services District has regular board meetings on the second and fourth Wednesdays of every month at 6:00 p.m. at the Rosamond Community Services District offices, 3179 35<sup>th</sup> Street, Rosamond, CA 93560.

We can be contacted at 661-256-3411 and additional information about the District can be obtained on our website at [www.rosamondcsd.com](http://www.rosamondcsd.com)

If you have questions about this report or drinking water quality call Kim Domingo, General Manager with Rosamond Community Services District: (661) 256-3411 or the EPA Safe Drinking Water Hotline: (800) 426-4791.

Rosamond Community Services District is a member of:

- American Water Works Association
- Association of California Water Agencies
- California Rural Water Association
- California Special Districts Association
- Water Reuse Association

Este informe contiene informacion muy importante sobre el agua que usted consume. Para mas informacion puede llamar al 661-256-3411.

2024 SUMMARY OF WATER QUALITY DATA  
ROSAMOND COMMUNITY SERVICES DISTRICT WATER SYSTEM

| MICROBIOLOGICAL CONTAMINANTS        | TEST DATE | UNIT     | PHG  | MCL              | AVERAGE | VIOLATION | SOURCE OF CONTAMINANTS                                                                                                                                                                                                                                                                                                                                                                                 |
|-------------------------------------|-----------|----------|------|------------------|---------|-----------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Total Coliform Bacteria             | 2024      |          | 0    | 0                | 0       | No        | Naturally present in the environment.                                                                                                                                                                                                                                                                                                                                                                  |
| DISINFECTION BY-PRODUCTS***         | TEST DATE | UNIT     | PHG  | MCL              | AVERAGE | VIOLATION | SOURCE OF CONTAMINANTS                                                                                                                                                                                                                                                                                                                                                                                 |
| Total Trihalomethane (TTHM)         | 2024      | ppb      | n/a  | 80               | 2.66    | No        | By-product of drinking water chlorination                                                                                                                                                                                                                                                                                                                                                              |
| Total Haloacetic Acids (HAA5)       | 2024      | ppb      | n/a  | 60               | 0.48    | No        | By-product of drinking water chlorination                                                                                                                                                                                                                                                                                                                                                              |
| Chlorine                            | 2024      | ppm      | 4    | 4                | 0.98    | No        | Drinking water disinfectant added for treatment                                                                                                                                                                                                                                                                                                                                                        |
| INORGANIC CHEMICALS                 | TEST DATE | UNIT     | PHG  | MCL              | AVERAGE | VIOLATION | SOURCE OF CONTAMINANTS                                                                                                                                                                                                                                                                                                                                                                                 |
| Nitrate                             | 2024      | ppm      | 10   | 10               | 1.5     | No        | Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.                                                                                                                                                                                                                                                                                              |
| Arsenic                             | 2024      | ppb      | n/a  | 10               | 6.4     | No        | Erosion of natural deposit; runoff from orchards; glass and electronics productions wastes                                                                                                                                                                                                                                                                                                             |
| Fluoride                            | 2024      | ppm      | .15  | 2                | 0.45    | No        | Erosion of natural deposits; water additive, which promotes strong teeth; discharge from fertilizer and aluminum factories.                                                                                                                                                                                                                                                                            |
| Turbidity                           | 2024      | NTU      | n/a  | TT(5.0)          | N/D     | No        | Soil runoff                                                                                                                                                                                                                                                                                                                                                                                            |
| Secondary Drinking Water Standards  | TEST DATE | UNIT     | PHG  | MCL              | AVERAGE | VIOLATION | SOURCE OF CONTAMINANTS                                                                                                                                                                                                                                                                                                                                                                                 |
| Alkalinity                          | 2024      | ppm      | n/a  | n/a              | 105     | No        | Erosion of natural deposits                                                                                                                                                                                                                                                                                                                                                                            |
| Calcium                             | 2024      | ppm      | n/a  | n/a              | 29      | No        | Runoff/leaching from natural deposits; seawater influence                                                                                                                                                                                                                                                                                                                                              |
| Chloride                            | 2024      | ppm      | n/a  | (500)            | 21      | No        | Naturally-occurring polyvalent action present in the water, generally magnesium and calcium                                                                                                                                                                                                                                                                                                            |
| Hardness                            | 2024      | ppm      | n/a  | n/a              | 99.5    | No        | Naturally-occurring salt; seawater influence                                                                                                                                                                                                                                                                                                                                                           |
| Sodium                              | 2024      | ppm      | n/a  | n/a              | 42.5    | No        | Substances that form ions when in water; seawater influence                                                                                                                                                                                                                                                                                                                                            |
| Specific conductance                | 2024      | umhos/cm | n/a  | (1600)           | 395     | No        | Runoff/leaching from natural deposits                                                                                                                                                                                                                                                                                                                                                                  |
| Total dissolved solids              | 2024      | ppm      | n/a  | (1000)           | 240     | No        | Naturally occurring organic materials                                                                                                                                                                                                                                                                                                                                                                  |
| Color                               | 2024      | Units    | n/a  | 15               | ND      |           |                                                                                                                                                                                                                                                                                                                                                                                                        |
| Metals – (LEAD & COPPER Monitoring) | TEST DATE | UNIT     | PHG  | MCL              | AVERAGE | VIOLATION | SOURCE OF CONTAMINANTS                                                                                                                                                                                                                                                                                                                                                                                 |
| Copper                              | 2024      | ppm      | 0.17 | AL = n/a<br>1000 | 0.072   | n/a       | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                                                                                                                                                                                                                                                                                        |
| Lead                                | 2024      | ppb      | 2    | AL = n/a         | ND      | n/a       | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers                                                                                                                                                                                                                                                                                                       |
| KEY TO TABLE                        |           |          |      |                  |         |           | NTU = Nephelometric Turbidity Units * SMCL = Secondary Maximum Contaminant Level * MCLG = Maximum Contaminant Level Goal * <b>ppb</b> /L = picocuries per liter ( a measure of radioactivity) * TT = Treatment Technique * n/a = not applicable ppb = parts per billion, or micrograms per liter * ppm = parts per million, or micrograms per liter * <b>umhos</b> /cm = units of specific conductance |