

2024 Consumer Confidence Report

Water System Information

Water System Name: [California City Water System](#)

Report Date: [July 1, 2025](#)

Type of Water Source(s) in Use: [Four Ground Water Wells and One Supplier Water Source \(AVEK\)](#)

Name and General Location of Source(s): [Well #2, Well#14, Well#15A, and Well#16 are all located in the first community within a three-mile radius from City Hall 21000 Hacienda Blvd; California City, CA 93505. The water source for AVEK is at the NW corner of California City Boulevard and Randsburg Mojave Road.](#)

Drinking Water Source Assessment Information: [Available at California City's City Hall 21000 Hacienda Blvd; California City, CA 93505.](#)

Time and Place of Regularly Scheduled Board Meetings for Public Participation: [Second and Fourth Tuesday of every month at 5:00PM at California City's City Hall 21000 Hacienda Blvd; California City, CA 93505.](#)

For More Information, Contact: [Joe Barragan Director of Public Works at \(760\) 373-7162](#)

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, [2024](#), and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse [City of California City](#) a [21000 Hacienda Blvd; California City, CA 93505 \(760\) 373-7162](#) para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 [City of California City](#) 以获得中文的帮助: [21000 Hacienda Blvd; California City, CA 93505 \(760\) 373-7162](#).

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa [City of California City](#) o tumawag sa [21000 Hacienda Blvd; California City, CA 93505 \(760\) 373-7162](#) para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ [City of California City](#) tại [21000 Hacienda Blvd; California City, CA 93505 \(760\) 373-7162](#) để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau [City of California City](#) ntawm [21000 Hacienda Blvd; California City, CA 93505 \(760\) 373-7162](#) rau kev pab hauv lus Askiv.

Terms Used in This Report

| Term | Definition |
|--|---|
| Level 1 Assessment | A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system. |
| Level 2 Assessment | A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions. |
| Maximum Contaminant Level (MCL) | The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water. |
| Maximum Contaminant Level Goal (MCLG) | The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA). |
| Maximum Residual Disinfectant Level (MRDL) | The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |
| Maximum Residual Disinfectant Level Goal (MRDLG) | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| Primary Drinking Water Standards (PDWS) | MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements. |
| Public Health Goal (PHG) | The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency. |
| Regulatory Action Level (AL) | The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow. |
| Secondary Drinking Water Standards (SDWS) | MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels. |
| Treatment Technique (TT) | A required process intended to reduce the level of a contaminant in drinking water. |
| Variances and Exemptions | Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions. |
| ND | Not detectable at testing limit. |
| ppm | parts per million or milligrams per liter (mg/L) |
| ppb | parts per billion or micrograms per liter (µg/L) |

| Term | Definition |
|-------|--|
| ppt | parts per trillion or nanograms per liter (ng/L) |
| ppq | parts per quadrillion or picogram per liter (pg/L) |
| pCi/L | picocuries per liter (a measure of radiation) |

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do

not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

| Microbiological Contaminants | Highest No. of Detections | No. of Months in Violation | MCL | MCLG | Typical Source of Bacteria |
|------------------------------|---------------------------|----------------------------|-----|------|------------------------------|
| <i>E. coli</i> | (In the year) 0 | 0 | (a) | 0 | Human and animal fecal waste |

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

| Lead and Copper | Sample Date | No. of Samples | 90 th Percentile Level Detected | No. Sites Exceeding AL | Range of Results | AL | PHG | Typical Source of Contaminant |
|-----------------|-------------|----------------|--|------------------------|------------------|-----|-----|---|
| Lead (ppb) | 2024 | 20 | 0.2 | 0 | 0-4 | 15 | 0.2 | Corrosion of household plumbing systems; Erosion of natural deposits |
| Copper (ppm) | 2024 | 20 | 0.0883 | 0 | 0.05-0.26 | 1.3 | 0.3 | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

Table 3. Sampling Results for Sodium and Hardness

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
|---|-------------|----------------|---------------------|------|------------|--|
| Sodium (ppm) | 2023 | 148.5 | 140-157 | None | None | Salt present in the water and is generally naturally occurring |
| Hardness (ppm) | 2023 | 101.8 | 89-120 | None | None | Sum of polyvalent cations present in the water, |

| | | | | | | |
|--|--|--|--|--|--|--|
| | | | | | | generally magnesium and calcium, and are usually naturally occurring |
|--|--|--|--|--|--|--|

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant |
|---|-----------------------------|----------------------------|------------------------------------|---------------------------|------------------------------|--|
| <u>Arsenic (ppb)</u> | <u>2023</u> | <u>7</u> | <u>6 - 9</u> | <u>10</u> | <u>0.004</u> | <u>Erosion of natural deposits; run off from orchards; glass and electronics production wastes.</u> |
| <u>Barium (ppm)</u> | <u>2023</u> | <u>ND</u> | <u>ND</u> | <u>1</u> | <u>2</u> | <u>Discharge of oil drilling wastes and from metal refineries; erosion of national deposits</u> |
| <u>Fluoride (ppm)</u> | <u>2023</u> | <u>1.4</u> | <u>1.29 - 1.57</u> | <u>2</u> | <u>1</u> | <u>Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories</u> |
| <u>Selenium (ppb)</u> | <u>2023</u> | <u>5.8</u> | <u>0 - 12</u> | <u>50</u> | <u>30</u> | <u>Discharge from petroleum, glass and metal refineries; erosion of natural deposits;</u> |

| | | | | | | |
|----------------------|-------------|------------|------------------|-----------|-----------|--|
| | | | | | | <u>discharge from mines and chemical manufacturers; runoff from livestock lots (feed additives)</u> |
| <u>Nitrate (ppm)</u> | <u>2025</u> | <u>0.6</u> | <u>0.28-1.26</u> | <u>10</u> | <u>10</u> | <u>Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits</u> |

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | SMCL | PHG (MCLG) | Typical Source of Contaminant |
|---|-------------|----------------|--------------------------|------------|------------|--|
| <u>Aluminum (ppm)</u> | <u>2023</u> | <u>ND</u> | <u>ND</u> | <u>1</u> | <u>0.6</u> | <u>Erosion of natural deposits; residual from some surface water treatment process</u> |
| <u>Bicarbonate (ppm)</u> | <u>2023</u> | <u>172.5</u> | <u>170 - 180</u> | <u>n/a</u> | <u>n/a</u> | <u>n/a</u> |
| <u>Calcium (ppm)</u> | <u>2023</u> | <u>28.7</u> | <u>25 - 33</u> | <u>n/a</u> | <u>n/a</u> | <u>n/a</u> |
| <u>Alkalinity (ppm)</u> | <u>2023</u> | <u>172.5</u> | <u>170-180</u> | <u>n/a</u> | <u>n/a</u> | <u>n/a</u> |
| <u>Chloride (ppm)</u> | <u>2023</u> | <u>75.8</u> | <u>71 - 80</u> | <u>500</u> | <u>n/a</u> | <u>Runoff/leaching from natural deposits; seawater influence</u> |
| <u>Foaming Agents [MBAS](ppb)</u> | <u>2023</u> | <u>ND</u> | <u>ND</u> | <u>500</u> | <u>n/a</u> | <u>Municipal and industrial waste discharges</u> |
| <u>Iron (ppb)</u> | <u>2023</u> | <u>ND</u> | <u>ND</u> | <u>300</u> | <u>n/a</u> | <u>Leaching from natural deposits; industrial wastes</u> |
| <u>Magnesium (ppb)</u> | <u>2023</u> | <u>0.0073</u> | <u>0.00688 - 0.00858</u> | <u>n/a</u> | <u>n/a</u> | <u>n/a</u> |
| <u>Manganese (ppb)</u> | <u>2023</u> | <u>ND</u> | <u>ND</u> | <u>50</u> | <u>n/a</u> | <u>Leaching from natural deposits</u> |

| | | | | | | |
|---|-------------|--------------|--------------------|--------------|------------|---|
| <u>PH (pH Unit)</u> | <u>2023</u> | <u>8</u> | <u>8 – 8.1</u> | <u>n/a</u> | <u>n/a</u> | <u>n/a</u> |
| <u>Specific Conductance (uS/cm)</u> | <u>2023</u> | <u>892</u> | <u>880 – 910</u> | <u>1600</u> | <u>n/a</u> | <u>Substance that form ions when in water; seawater influence</u> |
| <u>Sulfate (ppm)</u> | <u>2023</u> | <u>91.5</u> | <u>88 – 94</u> | <u>500</u> | <u>n/a</u> | <u>Runoff/leaching from natural deposits; industrial wastes</u> |
| <u>Total Dissolved Solids [TDS] (ppm)</u> | <u>2023</u> | <u>428.5</u> | <u>409 - 448</u> | <u>1,000</u> | <u>n/a</u> | <u>Runoff/leaching from natural deposits</u> |
| <u>Turbidity (NTU)</u> | <u>2023</u> | <u>0.3</u> | <u>0.12 – 0.55</u> | <u>TT</u> | <u>n/a</u> | <u>Soil runoff</u> |
| <u>Potassium (ppm)</u> | <u>2020</u> | <u>2.5</u> | <u>2.3 - 2.6</u> | <u>n/a</u> | <u>n/a</u> | <u>n/a</u> |
| <u>Zinc (ppm)</u> | <u>2023</u> | <u>ND</u> | <u>ND</u> | <u>5.0</u> | <u>n/a</u> | <u>Runoff/leaching from natural deposits; industrial wastes</u> |

Table 6. Detection of Unregulated Contaminants

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | Notification Level | Health Effects |
|---|-------------|----------------|---------------------|--------------------|--|
| <u>Chromium 6(ppb)</u> | <u>2025</u> | <u>7.8</u> | <u>5.9-10</u> | <u>50</u> | <u>Some people who use water containing chromium in excess of MCL over many years may experience allergic dermatitis</u> |

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [NAME OF UTILITY] is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact [NAME OF UTILITY and CONTACT INFORMATION]. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*: [Enter Additional Information Described in Instructions for SWS CCR Document]

State Revised Total Coliform Rule (RTCR): [Enter Additional Information Described in Instructions for SWS CCR Document]

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

| Violation | Explanation | Duration | Actions Taken to Correct Violation | Health Effects Language |
|-------------|-------------|------------|------------------------------------|-------------------------|
| <u>None</u> | <u>N/A</u> | <u>N/A</u> | <u>N/A</u> | <u>N/A</u> |
| <u>None</u> | <u>N/A</u> | <u>N/A</u> | <u>N/A</u> | <u>N/A</u> |

For Water Systems Providing Groundwater as a Source of Drinking Water

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples

| Microbiological Contaminants (complete if fecal-indicator detected) | Total No. of Detections | Sample Dates | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant |
|---|-------------------------|--------------|------------|--------------------|-------------------------------|
| <i>E. coli</i> | <u>0</u> | <u>2020</u> | <u>0</u> | <u>(0)</u> | Human and animal fecal waste |
| Enterococci | <u>0</u> | <u>2020</u> | <u>TT</u> | <u>N/A</u> | Human and animal fecal waste |
| Coliphage | <u>0</u> | <u>2020</u> | <u>TT</u> | <u>N/A</u> | Human and animal fecal waste |

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

Special Notice of Fecal Indicator-Positive Groundwater Source Sample: None

Special Notice for Uncorrected Significant Deficiencies: None

Table 9. Violation of Groundwater TT

| Violation | Explanation | Duration | Actions Taken to Correct Violation | Health Effects Language |
|-------------|-------------|------------|------------------------------------|-------------------------|
| <u>None</u> | <u>N/A</u> | <u>N/A</u> | <u>N/A</u> | <u>N/A</u> |
| <u>None</u> | <u>N/A</u> | <u>N/A</u> | <u>N/A</u> | <u>N/A</u> |

For Systems Providing Surface Water as a Source of Drinking Water

Table 10. Sampling Results Showing Treatment of Surface Water Sources

| | |
|---|--|
| Treatment Technique ^(a) (Type of approved filtration technology used) | <u>N/A</u> |
| Turbidity Performance Standards ^(b) (that must be met through the water treatment process) | <p>Turbidity of the filtered water must:</p> <p>1 – Be less than or equal to <u>N/A</u> NTU in 95% of measurements in a month.</p> <p>2 – Not exceed <u>N/A</u> NTU for more than eight consecutive hours.</p> <p>3 – Not exceed <u>N/A</u> NTU at any time.</p> |
| Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1. | <u>N/A</u> |
| Highest single turbidity measurement during the year | <u>N/A</u> |
| Number of violations of any surface water treatment requirements | <u>N/A</u> |

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a Surface Water TT**Table 11. Violation of Surface Water TT**

| Violation | Explanation | Duration | Actions Taken to Correct Violation | Health Effects Language |
|-------------|-------------|------------|------------------------------------|-------------------------|
| <u>None</u> | <u>N/A</u> | <u>N/A</u> | <u>N/A</u> | <u>N/A</u> |
| <u>None</u> | <u>N/A</u> | <u>N/A</u> | <u>N/A</u> | <u>N/A</u> |

Summary Information for Operating Under a Variance or Exemption

[Enter Additional Information Described in Instructions for SWS CCR Document]

Summary Information for Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

If a water system is required to comply with a Level 1 or Level 2 assessment requirement that is not due to an *E. coli* MCL violation, include the following information below [22 CCR section 64481(n)(1)].

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

N/A

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

N/A