

2024 Consumer Confidence Report**Water System Information**

Water System Name: Lebec County Water District

Report Date: April 1, 2025

Type of Water Source(s) in Use: Ground water from 3 wells.

Name and General Location of Source(s): **Lebec Well #1** (east side of I-5); **State Well #2** (east side of I-5); **Chimney Canyon Well #3** (north side of Frazier Mountain Park Rd)

Drinking Water Source Assessment Information: Water assessment was done in 2002 and may be viewed at the office. Water vulnerability is limited to septic tank proximity, cement plants, gravel mining, wastewater plants and major highway corridors.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: The 2nd Tuesday of every month (except holidays) at 323 Frazier Mountain Park Rd. Lebec, Ca 93243 at 6:00PM.

For More Information, Contact: Lebec County Water District at 661-248-6872

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2024, and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Lebec County Water District a 323 Frazier Mountain Park Rd. Lebec, Ca 93243 para asistirlo en español.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
Ppm	parts per million or milligrams per liter (mg/L)
Ppb	parts per billion or micrograms per liter (µg/L)

Term	Definition
Ppt	parts per trillion or nanograms per liter (ng/L)
Ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	8/13/24	10	2.2	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	8/13/24	10	0.12	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	6/12/23	(Well 1) 57 (Well 2) 78.3 (Well 3) 94.2	57 – 94.2	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	6/12/23	(Well 1) 310 (Well 2) 380 (Well 3) 370	310 - 380	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Aluminum (mg/L)	6-17-2017	(Well 2) 0.13	0.13	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes
Arsenic (µg/L)	6-16-2020	(Well 2) 2.0 (Well 3) 2.8	2.0 – 2.8	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium (mg/L)	6-16-2020	(Well 1) .050 (Well 2) .033 (Well 3) .031	.031 - .050	1	2	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Copper (µg/L)	8-10-2021	(Well 1) 140	140	1000	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Turbidity	6-12-2023 6-12-2023 6-16-2020	(Well 1) 0.16 (Well 2) 0.12 (Well 3) 0.42	0.12 - 0.42	5	N/A	Soil runoff

Gross Alpha Particle Activity (pCi/L)	2024	(Well 1) 11.9 (Well 2) 19.25 (Well 3) 19.7	10.5 – 25.1	15	N/A	Erosion of natural deposits
Uranium pCi/L	2024	(Well 1) 11.6 (Well 2) 17.7 (Well 3) 20.0	8.81 – 21.5	20	0.43	Erosion of natural deposits
Fluoride (mg/L)	2024	(Well 1) 1.6 (Well 2) 2.21 (Well 3) 2.5	1.53 – 2.9	2.0	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen, N) (mg/L)	2024	(Well 1) 6.55 (Well 2) 5.6 (Well 3) 6.67	2.9 – 7.6	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
TTHMs (Total Trihalomethanes) (µg/L)	07-05-2023	(Well 1,2,3) Avg. 3.2	3.2	80	N/A	Byproduct of drinking water disinfection
Selenium (µg/L)	6-16-2020	(Well 2) .0052 (Well 3) .0074	.0052 - .0074	0.05	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	Typical Source of Contaminant
Copper (mg/L)	08-10-2021	(Well 1) 0.14	0.14	1.0	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Total Dissolved Solids (TDS) (mg/L)	06-12-2023	(Well 1) 448 (Well 2) 628 (Well 3) 650	448 - 650	1,000	Runoff/leaching from natural deposits
Specific Conductance (µS/cm)	06-12-2023	(Well 1) 860 (Well 2) 1090 (Well 3) 1110	860 - 1110	1,600	Substances that form ions when in water; seawater influence
Chloride (mg/L)	06-12-2023	(Well 1) 26 (Well 2) 45 (Well 3) 39	26-45	500	Runoff/leaching from natural deposits; seawater influence

Iron (mg/L)	6-16-2020	(Well 1) 0.16 (Well 2) .14 (Well 3) .059	0.14	0.3	Leaching from natural deposits; industrial wastes
Zinc (mg/L)	6-16-2020	(Well 1) .083 (Well 2) 0.49	0.083 – 0.49	5.0	Runoff/leaching from natural deposits; industrial wastes
Color (units)	6-16-2020	(Well 1) 3 (Well 2) 3 (Well 3) 3	3	15	Naturally-occurring organic materials
Odor (units)	6-16-2020	(Well 2) 1	1	3	Naturally-occurring organic materials
Sulfate (mg/L)	06-16-2020	(Well 1) 94 (Well 2) 170 (Well 3) 180	94 - 180	500	Runoff/leaching from natural deposits; industrial wastes

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lebec County Water District is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*: Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

State Revised Total Coliform Rule (RTCR):

- ✓ **Treatment Technique (TT) Violation:** When a water system exceeds a TT trigger specified in Cal. Code Regs., Title 22, § 64426.7(b) and (c) and then fails to conduct the required Level 1 or Level 2 Assessment or corrective actions within the timeframe specified in Cal. Code Regs., Title 22, § 64426.8. See Item X for an explanation of a *E. coli* TT requirement.
- ✓ **Treatment Technique (TT) Violation:** For a seasonal system, failure to complete the requirements in Cal. Code Regs., Title 22, § 64426.9. Under the State RTCR, a seasonal system means a non-community water system (*i.e.*, nontransient-noncommunity water system or a transient-noncommunity water system) that is not operated as a public water system on a year-round basis and starts up and shuts down at the beginning and end of each operating session.

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
Fluoride	Fluoride is naturally in our groundwater wells. Its source is from erosion of natural deposits.	2009 – Present	A grant is currently being processed to drill a new well with low levels of fluoride and uranium. Well construction began in January 2025.	Some people who drink water containing fluoride in excess of the federal MCL of 4 mg/L over many years may get bone disease, including pain and tenderness of the bones. Children who drink water containing fluoride in excess of the state MCL of 2 mg/L may get mottled teeth.
Uranium	Uranium is naturally in our groundwater wells. Its source is from erosion of natural deposits.	2009 – Present	A grant is currently being processed to drill a new well with low levels of fluoride and uranium. Well construction began in January 2025.	Some people who drink water containing uranium in excess of the MCL over many years may have kidney problems or an increased risk of getting cancer.

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0	Monthly	0	(0)	Human and animal fecal waste
Enterococci	0	N/A	TT	N/A	Human and animal fecal waste
Coliphage	0	N/A	TT	N/A	Human and animal fecal waste

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.