

2024 Consumer Confidence Report

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse High Desert Adult & Teen Challenge a 472-230 Johnstonville Road, Susanville CA 96130 para asistirlo en español.

Water System Information

Water System Name: High Desert Adult & Teen Challenge

Report Date: June 30, 2025

Type of Water Source(s) in Use: We have one groundwater well, named Well 01.

Name and General Location of Source(s): Well 01 is located on our facility’s property.

Drinking Water Source Assessment Information: A Drinking Water Source Assessment of Well 1 was performed by the Division of Drinking Water. Well 01 is considered most vulnerable to the following activities not associated with any detected contaminants: Machine shops, the airport, and other water supply wells. Well 01 is also considered vulnerable to the following activities that may be associated with nitrate in the water supply: Low-density septic systems.

For More Information, contact: Tim Lundblade at 530-368-3600

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2024 and may include earlier monitoring data.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Term	Definition
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variations and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter ($\mu\text{g/L}$)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1-6, 8 and “A” list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of E. Coli Bacteria

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	None Detected	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive; or system fails to take repeat samples following *E. coli*-positive routine sample; or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	Range of Results	AL	PHG	Typical Source of Contaminant
Lead (ug/L)	6/28/2022	5	0	0	n/a	15	0.2	Corrosion of household plumbing systems; erosion of natural deposits
Copper (mg/L)	6/28/2022	5	0	0	n/a	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. High Desert Adult & Teen Challenge is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water at High Desert Adult & Teen Challenge, contact the Center's Supervisor. If you are concerned about lead in your water at home, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at US EPA <http://www.epa.gov/safewater/lead>.

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	04/29/2020	18	--	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	04/29/2020	85.2	--	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Arsenic (ug/L)	02/22/2023	3	--	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Fluoride (naturally occurring) (mg/L)	02/22/2023	0.1	--	2	1	Erosion of natural deposits; discharge from fertilizer and aluminum factories
Hexavalent Chromium (ug/L)	03/26/2025 Shown in this 2024 report because there was no MCL when the previous test was done in 2020.	2.7		10 An MCL of 10 became effective on Oct 1, 2024. The previous MCL was removed Sept 11, 2017	0.02	Erosion of natural deposits; transformation of naturally occurring trivalent chromium to hexavalent chromium by natural processes and human activities such as discharges from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities.
Nitrate (as N) (mg/L)	02/21/2024	1.1	--	10 (as N)	10 (as N)	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (mg/L)	04/29/2020	5.0	--	500	N/A	Runoff and leaching from natural deposits; seawater influence
Conductivity @25 C (µS/cm)	04/29/2020	279.0	--	1600	N/A	Substances that form ions when in water; seawater influence

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Sulfate (mg/L)	04/29/2020	2.4	--	500	N/A	Runoff and leaching from natural deposits; seawater influence
Total Dissolved Solids (mg/L)	04/29/2020	200	--	1000	N/A	Runoff and leaching from natural deposits; industrial influence
Turbidity (Turbidity Units)	02/10/2021	0.4	--	5	N/A	Soil Runoff

Table 6. Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Vanadium (ug/L)	02/22/2023	13	--	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 7. Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

None in 2024

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples in 2024

Microbiological Contaminants (complete if fecal-indicator detected)	Total Number of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year) 0	n/a No detections	0	(0)	Human & Animal Fecal Waste

Table A. Additional Detections (This information is not required to be reported.)

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Source of Contaminant
Calcium (mg/L)	(2020)	16.0	--	n/a	--
Magnesium (mg/L)	(2020)	11.0	--	n/a	--
pH (Laboratory) (units)	(2020)	7.6	--	n/a	n/a
Alkalinity (Total) (mg/L)	(2020)	120.0	--	n/a	--
Aggressiveness Index	(2020)	11.3	--	n/a	n/a
Langelier Index	(2020)	-0.5	--	n/a	n/a

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained at at Safe Drinking Water Information | US EPA <https://www.epa.gov/ground-water-and-drinking-water/safe-drinking-water-information>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available at <https://www.cdc.gov/cryptosporidium/prevention/index.html> and <https://www.cdc.gov/drinking-water/prevention/preventing-waterborne-germs-at-home.html>.

Source Water Protection Tips for Consumers

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Learn about Healthy Water Shed Protection <https://www.epa.gov/hwp>. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Refer to U.S. EPA's Adopt Your Watershed <https://nepis.epa.gov/Exe/ZyPDF.cgi/2000412M.PDF?Dockey=2000412M.PDF> or for Tools and Resources to protect watersheds visit <https://www.epa.gov/hwp/tools-and-resources-protect-watersheds>.

Water Conservation Tips for Consumers

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- Take short showers – a 5 minutes shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair, and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They are inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaking toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- If you have a lawn, adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit <https://www.epa.gov/watersense> for more information.