



Wood Environment & Infrastructure Solutions, Inc.
6001 Rickenbacker Road
Los Angeles, CA 90040-3031
USA

T: +1 323.889.5300

www.woodplc.com

June 25, 2021
4953-21-0043

Mr. Brandon Saeteurn
Hanson Aggregates, LLC
13550 Live Oak Avenue
Irwindale, California 91706-1318

Subject: **2020 Annual Consumer Confidence Report
Hanson Aggregates Irwindale Quarry**
13550 Live Oak Avenue
Irwindale, California
Water System No. CA1900018

Dear Mr. Saeteurn:

Wood Environment & Infrastructure Solutions, Inc. (Wood) has prepared this 2020 Annual Consumer Confidence Report (CCR) for the Hanson Aggregates Irwindale Quarry site. This report is required by the California Code of Regulations Title 22, Chapter 15, Article 20, Sections 64480-64483. Hanson Aggregates is required to provide information on concentrations of microbiological contaminants, minerals, physical agents, inorganic chemicals and organic chemicals in its water supply. This report includes specific information obtained during the 2020 calendar year that is summarized in the attached tables.

At least one copy should be posted in a public location at the Hanson Aggregates facility and sent to the Los Angeles County Department of Public Health – Drinking Water Program (DWP) by **July 1, 2021**. The CCR Certification form should be submitted to the DWP no later than **October 1, 2021**.

We appreciate working with you on this project. If you have any questions or require further assistance, please call Matt Fraychineaud at (323) 889-5310.

Sincerely,

Wood Environment & Infrastructure Solutions, Inc.

Ron Lopez
Senior Engineer

Matt Fraychineaud, P.G.
Senior Associate Geologist

P:\4953 Geotech\2021-proj\210043 Hanson Aggregates - Drinking Water\03 DocCtrl\Final Reports\2020 CCR\4953210043CCR.2020.Final.docx



**2020 Consumer Confidence Report
Hanson Aggregates Irwindale Quarry
13550 Live Oak Avenue
Irwindale, California
Water System No. CA1900018**

Hanson Aggregates is pleased to submit this annual consumer confidence (or water quality) report for 2020. This report is designed to inform you about the quality of your drinking water. We test the drinking water quality for many constituents as required by state and federal regulations. This report presents the results of our monitoring for the period of January 1 – December 31, 2020 and may include earlier monitoring data. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.



As shown in the attached tables, the suspect constituents for water samples collected at the Hanson Aggregates site in 2020 were below their respective drinking water maximum contaminant levels (MCLs), where applicable. Although bottled water is provided at the site for drinking purposes, the water system is still sampled and tested as required by California State Water Resources Control Board (State Water Board) guidelines.

If you have any questions regarding this Annual Consumer Confidence Report, please contact Mr. Brandon Saeteurn at (626) 856-6721.

Este informe contiene informacion muy importante sobre su agua para beber. Favor de comunicarse Hanson Aggregates a (626) 856-6721 para asistirlo en español.

Source of Water Supply

Water delivered to the Hanson Aggregates water system comes from the following on-site sources:

- 1900018-002 (Well No. 409)
- 1900018-003 (Well No. 410)

These two groundwater wells are located approximately 1,500 feet south-southeast of the site administrative office building.

Water is a Valuable Natural Resource



Definitions

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the public health goals (PHGs), or maximum contaminant level goals (MCLGs), as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the United States Environmental Protection Agency (US EPA).

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency (Cal EPA).

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: State Water Resources Control Board permissions to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit.

ppm: parts per million or milligrams per liter (mg/L).

ppb: parts per billion or micrograms per liter ($\mu\text{g/L}$).

ppt: parts per trillion or nanograms per liter (ng/L).

ppq: parts per quadrillion or picograms per liter (pg/L).

pCi/L: picocuries per liter (a measure of radiation).

Sources of Drinking Water and Contaminants that may be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:



Microbial Contaminants – such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants – such as salts and metals, that can be naturally-occurring or can result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides – that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants – including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production and can also come from gas stations, urban stormwater runoff, agricultural application and septic systems.



Radioactive Contaminants –that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Water Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the US EPA's Safe Drinking Water Hotline at (800) 426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hanson Aggregates is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800) 426-4791 or at <http://www.epa.gov/lead>.

Tables 1, 2, 3, 4, 5 and 6 include all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding any violation is provided below.

Summary Information for Contaminants Exceeding an MCL, MRDL, AL or Violation of Any TT or Monitoring and Reporting Requirements

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
No exceedances or violations occurred during the 2020 calendar year.				

Prepared by Wood Environment & Infrastructure Solutions, Inc. (June 2021)

2020 WATER QUALITY TABLE - HANSON AGGREGATES RESULTS

TABLE 1 - SAMPLING RESULTS FOR COLIFORM BACTERIA

MICROBIOLOGICAL CONTAMINANTS	UNIT	MCL	PHG (MCLG)	LEVEL DETECTED	RANGE OF DETECTION	DATE SAMPLED	TYPICAL ORIGINS
Total Coliform Bacteria	MPN/100 mL	No more than one positive monthly sample	(0)				Naturally present in the environment
<i>E. coli</i>		A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive					Human and animal fecal waste
No. of Routine Distribution System Samples Collected		12		Absent ^a	Absent ^a	Jan - Dec 2020	
No. of Routine Distribution System Samples Positive		0					
No. of Repeat Distribution System Samples Collected		0					
No. of Repeat Distribution System Samples Positive		0					

TABLE 2 - SAMPLING RESULTS FOR LEAD AND COPPER

PARAMETER	UNIT	AL	PHG	NO. OF SAMPLES COLLECTED	RANGE OF DETECTIONS	90 th PERCENTILE LEVEL DETECTED ^b	DATE SAMPLED	TYPICAL ORIGINS
Lead	µg/L	15	0.2	5	0.7–4.1	3.85	Aug 2018	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper	mg/L	1.3	0.3	5	0.016–0.210	0.143	Aug 2018	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Note: the water system does not provide water to schools; therefore, the number of schools that have requested lead sampling is not applicable.

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

PARAMETER	UNIT	MCL	PHG (MCLG)	LEVEL DETECTED OR AVERAGE	RANGE OF DETECTIONS	DATE SAMPLED	TYPICAL ORIGINS
Sodium	mg/L	No Standard	No Standard	22.3	22.1-22.4	Feb/Aug 2015	Salt present in the water and is generally naturally occurring
Hardness (as CaCo3)	mg/L	No Standard	No Standard	199.5	199-200	May/Nov 2020	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

PARAMETER	UNIT	MCL	PHG (MCLG)	LEVEL DETECTED OR AVERAGE	RANGE OF DETECTIONS	DATE SAMPLED	TYPICAL ORIGINS
Uranium	pCi/L	20	0.43	1.7	1.6-1.8	Feb/Nov 2020	Erosion of natural deposits
Arsenic	µg/L	10	0.004	2.2	—	Apr 2019	Erosion of natural deposits; runoff from orchards
Barium	mg/L	1	2	0.110	—	Apr 2019	Erosion of natural deposits; industrial discharges
Chlorine (Total Residual)	mg/L	[4.0] ^c	[4] ^d	0.70	<0.1-1.99	Jan-Apr 2016	By-product of drinking water disinfection
Chromium	µg/L	50	(100)	0.878J	0.759J-0.997J	May/Nov 2020	Erosion of natural deposits; industrial discharges
Nitrate (as N)	mg/L	10	10	1.25	1.1-1.4	Feb/Nov 2020	Erosion of natural deposits; leaching from fertilizer use/septic tanks
Nickel	µg/L	100	12	0.497J	0.302J-0.691J	May/Nov 2020	Erosion of natural deposits; industrial discharges
Total Trihalomethanes	µg/L	80	N/A	18	—	Aug 2019	By-product of drinking water disinfection
Haloacetic Acids	µg/L	60	N/A	141^e	<2.0- 280^e	Aug/Sept 2019	By-product of drinking water disinfection

TABLE 5 - SAMPLING RESULTS FOR CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

PARAMETER	UNIT	MCL	LEVEL DETECTED OR AVERAGE	RANGE OF DETECTIONS	DATE SAMPLED	TYPICAL ORIGINS
Chloride	mg/L	500	26.5	21-32	May/Nov 2020	Runoff/leaching from natural deposits; seawater influence
Iron	µg/L	300	149.5	145-154	May/Nov 2020	Leaching from natural deposits; industrial wastes
Manganese	µg/L	50	77.5^f	<5- 155^f	Feb/Aug 2015	Leaching from natural deposits
Specific Conductance	µS/cm	1,600	442.5	422-463	May/Nov 2020	Substances that form ions when in water; seawater influence
Sulfate	mg/L	500	26.5	23-30	May/Nov 2020	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids	mg/L	1,000	310	255-365	May/Nov 2020	Runoff/leaching from natural deposits

TABLE 6 - SAMPLING RESULTS FOR UNREGULATED CONSTITUENTS

PARAMETER	UNIT	NOTIFICATION LEVEL	LEVEL DETECTED OR AVERAGE	RANGE OF DETECTIONS	DATE SAMPLED	HEALTH EFFECTS LANGUAGE
Boron	mg/L	1	0.0606	0.0598-0.0614	May/Nov 2020	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Hexavalent Chromium	µg/L	0.02 ^g	0.61	0.58-0.63	May/Nov 2017	Some people who drink water containing hexavalent chromium in excess of the MCL over many years may have an increased risk of getting cancer.
Perfluorooctanoic Acid (PFOA)	ng/L	5.1	2.1	<2.0-2.2	Dec 2020	Perfluorooctanoic acid exposures resulted in increased liver weight and cancer in laboratory animals.

Prepared By: MF 06/01/2021

Checked By: RL 06/06/2021

Acronyms/Abbreviations

MPN/100 mL = most probable number per 100 mL

mg/L = milligrams per liter (parts per million)

µg/L = micrograms per liter (parts per billion)

ng/L = nanograms per liter (parts per trillion)

pCi/L = picoCuries per liter

AL = Action Level

N/A = not applicable

PHG = Public Health Goal

MCL = Maximum Contaminant Level

MCLG = Maximum Contaminant Level Goal

J = Concentration is between respective laboratory method detection limit and reporting (practical quantitation) limit.

µS/cm = microSiemens per centimeter = µmhos/cm (µmhos/cm = micromhos per centimeter)

Notes

Data in tables above is from Well No. 409, Well No. 410, and/or a distribution system sampling point.

When you read about water quality, you might ask yourself:

- *How much is one part per million (1ppm)?*
 - **Answer:** 1 ppm is equal to 1 drop of water in 14 gallons, 1 second in 12 days, 1 inch in 16 miles or 1 cent in \$10,000
- *How much is one part per billion (1ppb)?*
 - **Answer:** 1 ppb is equal to 1 drop of water in 14,000 gallons, 1 second in 32 years, 1 inch in 16,000 miles or 1 cent in \$10 million.

Footnotes

^a Absent (Standard Methods for the Examination of Water and Wastewater [SM 9223: Enzyme Substrate Test] used for Present/Absent determination)

^b 90th percentile level based on results from five sample locations

^c EPA Maximum Residual Disinfectant Level (MRDL)

^d Maximum Residual Disinfectant Level Goal (MRDLG)

^e Exceedance was summarized and addressed in the 2019 Consumer Confidence Report. The sample collected in August 2019 contained a haloacetic acids (HAA5) concentration of 280 µg/L which is above the HAA5 primary MCL of 60 µg/L. The elevated HAA5 value was caused by a problem with the treatment system flow sensor switch that caused the water in the distribution system to be "overtreated". The treatment system was inspected and repaired, and a confirmation sample was collected and analyzed with a HAA5 result of <2.0 µg/L. The data presented is from the most recent monitoring performed in compliance with the regulations.

^f Exceedance was summarized and addressed in the 2015 Consumer Confidence Report. The sample collected in February 2015 contained a manganese concentration of 155 mg/L which is above the manganese secondary MCL of 50 mg/L. However, manganese was not detected in a subsequent sample collected later in the year. The data presented is from the most recent monitoring performed in compliance with the regulations.

^g 0.02 µg/L is the PHG, not a notification level. No MCL exists for hexavalent chromium as the previous MCL of 10 µg/L was withdrawn in September 2017.