

2023 Consumer Confidence Report

Water System Information

Water System Name: West Side Park Mutual Water Company

Report Date: June 20, 2024

Type of Water Source(s) in Use: Two Ground Water Wells

Name and General Location of Sources: Well 01 and Well 02, 40317 11th Street West, Palmdale, CA 93551,

Well 01 and AVEK (supplemental water) were used to distribute water to shareholders during 2023. Well 02 was kept on active status during investigation and probable repairs and testing, however was not distributed to shareholders. This report has the testing result for Well 01 and also includes (as a separate report) the quality of water purchased from AVEK and distributed to our shareholders during 2023.

Drinking Water Source Assessment Information: Well 01 -The source is considered most vulnerable to the following activities not associated with any detected contaminants; septic systems, high density (< 1 acre).

Well 02 – Has shown no vulnerability at this time associated with the chemicals in the water. The Source is considered most vulnerable to the following activities not associated with any detected contaminants; Septic systems, high density (< 1 acre). Above ground storage tanks, and animal operations that may be in the proximity.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: 7:00 p.m., First Thursday of each month. If you wish to address the Board, please call ahead to be placed on the agenda.

For More Information, Contact: Mary Wood, 1 877-500-3880, Ext. 3

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2023 and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse West Side Park Mutual Water Co. a 40317 11th Street West, Palmdale, CA para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 West Side Park Mutual Water Co 以获得中文的帮助: 40317 11th St. West, Palmdale, 877-500-3880.

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa West Side Park Mutual Water Co. o tumawag sa 877-500-3880, Ext 3 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ West Side Park Mutual Water Co. tại 40317 11th Street West, Palmdale, 877-500-3880 Ext 3 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau West Side Park Mutual Water Co. ntawm 40317 11th Street West, Palmdale, CA, 877-500-3880 rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.

Term	Definition
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter ($\mu\text{g/L}$)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	0	None	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	8/29/22	5	N/D	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.
Copper (ppm)	8/29/22	5	0.23	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm) Well 01	7/13/21	110	N/A	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm) Well 01	7/13/21	270	N/A	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring.

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Nitrate (ppm) Well 01	7/19/23	0.44	N/A	10	0.40	Runoff/leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits.
Fluoride (ppm) Well 01	7/13/21	0.24	N/A	2.0	0.10	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Radium 226 PCi/L Well01	7/13/21	0.10	N/A	5	5	Erosion of natural deposits.
Radium 228 PCi/L Well 01	7/13/21	1.29	N/A	5	5	Erosion of natural deposits.
Uranium PCi/L	7/13/21	1.6	N/A	20	0.43	Erosion of natural deposits.
Iron (ppm)	7/13/21	410	N/A	300	100	Leaching from natural deposits; industrial wastes.
						-

TTHM (ppb) Distribution system	5/22/22	28.6	N/A	80	1.0	Byproduct of drinking water disinfection
HAA5 (ppb)	5/22/22	6.3	N/A	60	1.0	Byproduct of drinking water disinfection

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm) Well01	7/13/21	70	N/A	500	500	Runoff/leaching from natural deposits; sea-water influence.
Sulphate (SO4) Well 01	7/13/21	180	N/A	500	500	Runoff/leaching from natural deposits
Specific Well 01 Conductance ECuS.cn	7/13/21	920	N/A	1600	1600	Erosion of natural deposits.
Total Dissolved Solids Well 01 (TDS ppm)	7/13/21	530	N/A	1000	5	Substances that form ions when in water, industrial wastes.
Turbidity NTU Wel 01	7/13/21	0.10	N/A	5	5	Soil Runoff

SubTable 6. Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Vanadium (ppb) Well 01	7/13/21	13	N/A	50	Vanadium exposure resulted in developmental and reproductive effects in rats

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Enter Water System's Name] is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*:

State Revised Total Coliform Rule (RTCR): This Consumer Confidence Report (CCR) reflects changes in drinking water regulatory requirements during 2021. These revisions add the requirements of the Federal Revised Total Coliform Rule, effective since April 1, 2016, to the existing State Total Coliform Rules. The revised rule maintains the purpose to protect public health by ensuring the integrity of the drinking water distribution system and monitoring for the presence of microbials (i.e. total coliform and E. coli bacteria). The U. S. EPA anticipates greater public protection as the rule requires water systems that are vulnerable to microbial contamination to identify and fix problems. Water Systems that exceed a specified frequency of total coliform occurrences are required to conduct an assessment to determine if any sanitary defects exist. If found, these must be corrected by the water system. The State Revised Total Coliform Rule became effective July 1, 2021. Please note: On page 2 of this report, there is reference to Level 1 and 2 Assessments.

State Revised Total Coliform Rule (RTCR): [Enter Additional Information Described in Instructions for SWS CCR Document] See Directly Above.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
None	N/A	N/A	N/A	N/A

For Water Systems Providing Groundwater as a Source of Drinking Water

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0	N/A	0	(0)	Human and animal fecal waste
Enterococci	0	N/A	TT	N/A	Human and animal fecal waste
Coliphage	0	N/A	TT	N/A	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

Special Notice of Fecal Indicator-Positive Groundwater Source Sample: [Enter Special Notice of Fecal Indicator-Positive Groundwater Source Sample]

Special Notice for Uncorrected Significant Deficiencies: [Enter Special Notice for Uncorrected Significant Deficiencies]

Table 9. Violation of Groundwater TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
NONE	N/A	N/A	N/A	N/A

For Systems Providing Surface Water as a Source of Drinking Water

Table 10. Sampling Results Showing Treatment of Surface Water Sources

Treatment Technique ^(a) (Type of approved filtration technology used)	No Surface Water used in this system; refer to AVEK water quality document for their answer to this question
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to [Enter Turbidity Performance Standard to Be Less Than or Equal to 95% of Measurements in a Month] NTU in 95% of measurements in a month. 2 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded for More Than Eight Consecutive Hours] NTU for more than eight consecutive hours. 3 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded at Any Time] NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	[Enter No.]
Highest single turbidity measurement during the year	[Enter No.]
Number of violations of any surface water treatment requirements	[Enter No.]

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a Surface Water TT

Table 11. Violation of Surface Water TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
NONE	N/A	N/A	N/A	N/A

Summary Information for Operating Under a Variance or Exemption NONESummary Information for Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

If a water system is required to comply with a Level 1 or Level 2 assessment requirement that is not due to an *E. coli* MCL violation, include the following information below [22 CCR section 64481(n)(1)].

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

There were no positive coliform results in monthly routine testing our.

During the past year we were required to conduct 0 of Level 1 Assessments. 0 Level 1 Assessments] were completed. In addition, we were required to take 0 Number of Corrective Actions] corrective actions and we completed 0 of these actions.

During the past year 0 Level 2 assessments were required to be completed for our water system. 0 Level 2 assessments were completed. In addition, we were required to take 0 and we completed 0 of these actions. No Positive coliforms were in our routine testing monthly.

If a water system is required to comply with a Level 2 assessment requirement that is due to an *E. coli* MCL violation, include the information below [22 CCR section 64481(n)(2)]. No Level 2 Assessments were required because we had no Coliform Bacteria results in any of our monthly testing.

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

We were required to complete 0 Level 2 assessment because we found no *E. coli* in our water system. In addition, we were required to take 0 corrective actions and we completed [Insert Number 0 of these actions. There was no *E. coli* in our monthly testing, therefore we were not required to take any action.

Although we did not have any result over the MCL, Health Effects language has been provided for your information if there was any detection.

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD. Primary standards are set for Health purposes.

NITRATE – Infants below the age of six months who drink water containing nitrate in excess of the MCL (10 ppm) may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. High nitrate levels may also affect oxygen-carrying ability of the blood of pregnant women.

Our result was .87.

FLUORIDE -Some people who drink water containing Fluoride in excess of the Federal MCL 94 ppm) over many years may get bone disease, including pain and tenderness of the bones. Children who drink water containing Fluoride in excess of the State MCL of 2 ppm may get mottled teeth. Our result was 0.24.

RADIUM 226 AMD 228 – Some people who drink water containing radium 226 and 228 in excess of the MCL over many years, may have an increased risk of getting cancer. The level result was 1.6 and the MCL is 20.

URANIUM – Some People who drink water containing Uranium in excess of the MCL, over many years, may have kidney problems or an increased risk of getting cancer. Our result was 1.6 and the MCL is 5, so we are well below the MCL.

TTHM – Some people who drink water containing trihalomethanes in excess of the MCL (80 ppb) over many years may experience liver, kidney, or central nervous system problems. Also, they may have an increased risk of getting cancer. Our result was 28.6, below the MCL of 80 ppb.

HAA5 – Some people who drink water containing halocetic acids in excess of the MCL (60 ppb) over many years may experience liver, kidney, or central nervous system problems. They may also have an increased risk of getting cancer. Our result was 6.3, below the MCL of 60 ppb.

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD. Secondary standards are set on aesthetics.

CHLORIDE and **SPECIFIC CONDUCTANCE** have no effects at the level detected.

SULFATE – Although there are no known health effects, persons who drink water with a higher level than the MCL may experience diarrhea.

TOTAL DISSOLVED SOLIDS (TDS) -TDS are the sum of solids that have dissolved in the water, such as calcium, minerals, and some organics. Higher levels may cause scaling in plumbing.

RADIUM 226 and 228 – Some people who drink water containing radium 226 and 228 in excess of the MCL over many years may have an increased risk of getting cancer. Our results were below the MCL

URANIUM – Some people who drink water containing uranium in excess of the MCL over many years may have kidney problems or an increased risk of getting cancer. Our result was 1.6, and the MCL is 20 pCi/L.

REMEMBER: Even though the drought had eased, please use water wisely to conserve this non-renewable source.