

## 2023 Consumer Confidence Report

### Water System Information

Water System Name: Golden Sands Mobile Home Park

Report Date: February 16<sup>th</sup>, 2023

Type of Water Source(s) in Use: Community Water System

Name and General Location of Source(s): Well, Central Location Of Property

Drinking Water Source Assessment Information: Monthly Testing, AVEK

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Monthly Meetings Are Not Being Scheduled At This Time.

For More Information, Contact: Gene A. Stabe (661) 478-5372

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2022 and may include earlier monitoring data.

### Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse [Enter Water System's Name] a [Enter Water System's Address or Phone Number] para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 [Enter Water System Name] 以获得中文的帮助: [Enter Water System's Address][Enter Water System's Phone Number].

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa [Enter Water System's Name and Address] o tumawag sa [Enter Water System's Phone Number] para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ [Enter Water System's Name] tại [Enter Water System's Address or Phone Number] để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau [Enter Water System's Name] ntawm [Enter Water System's Address or Phone Number] rau kev pab hauv lus Askiv.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4 and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

**Table 1 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2021)	27	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2021)	115	n/a	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (mg/L)	(2021)	0.1	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Hexavalent Chromium (ug/L)	(2014)	9.2	n/a		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate as N (mg/L)	(2022)	1.4	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2021)	1.3	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2019)	2.1	n/a	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2022)	1.26	n/a	20	0.43	Erosion of natural deposits



<b>Table 3 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>MCL</b>	<b>PHG (MCLG)</b>	<b>Typical Sources of Contaminant</b>
Chloride (mg/L)	(2021)	35	n/a	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2021)	5	n/a	15	n/a	Naturally-occurring organic materials
Specific Conductance (umhos/cm)	(2021)	390	n/a	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2021)	53.6	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2021)	250	n/a	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2021)	0.3	n/a	5	n/a	Soil runoff

<b>Table 4 - DETECTION OF UNREGULATED CONTAMINANTS</b>					
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>Notification Level</b>	<b>Typical Sources of Contaminant</b>
Vanadium (ug/L)	(2021)	14	n/a	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

<b>Table 5 - ADDITIONAL DETECTIONS</b>					
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Average Level Detected</b>	<b>Range of Detections</b>	<b>Notification Level</b>	<b>Typical Sources of Contaminant</b>
Calcium (mg/L)	(2021)	41	n/a	n/a	n/a
Magnesium (mg/L)	(2021)	3	n/a	n/a	n/a
pH (units)	(2021)	8.3	n/a	n/a	n/a
Alkalinity (mg/L)	(2021)	80	n/a	n/a	n/a
Aggressiveness Index	(2021)	12.2	n/a	n/a	n/a
Langelier Index	(2021)	0.4	n/a	n/a	n/a

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead Specific Language for Community Water Systems:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Golden Sands MHP* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

# **2022 Consumer Confidence Report**

## **Drinking Water Assessment Information**

### **Assessment Information**

A source water assessment was conducted for the WELL 02 of the GOLDEN SANDS MOBILE HOME PARK water system in January, 2002.

WELL 02 - has shown to be at most vulnerable to the chemicals: None

### **Discussion of Vulnerability**

At this time, no chemicals have been detected that will affect the quality of the drinking water.

### **Acquiring Information**

A copy of the complete assessment may be viewed at:

Golden Sands Mobile Home Park

2059 East Avenue I

Lancaster, CA 93534

The Consumer Confidence Report is posted on a bulletin board in the Common Area Club House. Within this building it is accessible to the general public and all persons effected by ground water Well 02 water system number 1900649.

You may request a summary of the assessment be sent to you by contacting:

Vince Gallegos

Environmental Health Specialist III

County of Los Angeles Public Health Water Quality Program

5050 Commerce Drive

Baldwin Park, CA 91706

Tel (626) 430-5420

Fax(627) 813-3016



# Golden Sands MHP

## Analytical Results By FGL - 2022

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			27	27 - 27
WELL 02	SP 2102321-1	mg/L				2021-02-17	27		
Hardness		mg/L		none	none			115	115 - 115
WELL 02	SP 2102321-1	mg/L				2021-02-17	115		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Fluoride		mg/L		2	1			0.1	0.1 - 0.1
WELL 02	SP 2102321-1	mg/L				2021-02-17	0.1		
Hexavalent Chromium		ug/L			0.02			9.2	9.2 - 9.2
WELL 02	SP 1414581-1	ug/L				2014-12-15	9.2		
Nitrate as N		mg/L		10	10			1.4	1.4 - 1.4
WELL 02	SP 2220381-1	mg/L				2022-12-22	1.4		
Nitrate + Nitrite as N		mg/L		10	10			1.3	1.3 - 1.3
WELL 02	SP 2102321-1	mg/L				2021-02-17	1.3		
Gross Alpha		pCi/L		15	(0)			2.10	2.10 - 2.10
WELL 02	SP 1902363-1	pCi/L				2019-02-20	2.10		
Uranium		pCi/L		20	0.43			1.26	1.26 - 1.26
WELL 02	SP 2215190-1	pCi/L				2022-09-21	1.26		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			35	35 - 35
WELL 02	SP 2102321-1	mg/L				2021-02-17	35		
Color		Units		15	n/a			5	5 - 5
WELL 02	SP 2102321-1	Units				2021-02-17	5		
Specific Conductance		umhos/cm		1600	n/a			390	390 - 390
WELL 02	SP 2102321-1	umhos/cm				2021-02-17	390		
Sulfate		mg/L		500	n/a			53.6	53.6 - 53.6
WELL 02	SP 2102321-1	mg/L				2021-02-17	53.6		
Total Dissolved Solids		mg/L		1000	n/a			250	250 - 250
WELL 02	SP 2102321-1	mg/L				2021-02-17	250		
Turbidity		NTU		5	n/a			0.3	0.3 - 0.3
WELL 02	SP 2102321-1	NTU				2021-02-17	0.3		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Vanadium		ug/L		NS	n/a			14	14 - 14
WELL 02	SP 2102321-1	ug/L				2021-02-17	14		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			41	41 - 41
WELL 02	SP 2102321-1	mg/L				2021-02-17	41		
Magnesium		mg/L			n/a			3	3 - 3
WELL 02	SP 2102321-1	mg/L				2021-02-17	3		
pH		units			n/a			8.3	8.3 - 8.3
WELL 02	SP 2102321-1	units				2021-02-17	8.3		
Alkalinity		mg/L			n/a			80	80 - 80

WELL 02	SP 2102321-1	mg/L				2021-02-17	80		
<b>Aggressiveness Index</b>					n/a			12.2	12.2 - 12.2
WELL 02	SP 2102321-1					2021-02-17	12.2		
<b>Langelier Index</b>					n/a			0.4	0.4 - 0.4
WELL 02	SP 2102321-1					2021-02-17	0.4		

# Golden Sands MHP

## CCR Login Linkage - 2022

FGL Code	Lab ID	Date Sampled	Method	Description	Property
CuPb-ss10	SP 2210107-10	2022-06-13	Metals, Total	Space #147	Copper & Lead Monitoring
CuPb-ss07	SP 2210107-7	2022-06-13	Metals, Total	Space #111 Maintenance	Copper & Lead Monitoring
CuPb-ss08	SP 2210107-8	2022-06-13	Metals, Total	Space #112	Copper & Lead Monitoring
CuPb-ss09	SP 2210107-9	2022-06-13	Metals, Total	Space #127	Copper & Lead Monitoring
CuPb-ss01	SP 2210107-1	2022-06-13	Metals, Total	Space #14 & 15 Manager	Copper & Lead Monitoring
CuPb-ss02	SP 2210107-2	2022-06-13	Metals, Total	Space #27	Copper & Lead Monitoring
CuPb-ss03	SP 2210107-3	2022-06-13	Metals, Total	Space #51	Copper & Lead Monitoring
CuPb-ss04	SP 2210107-4	2022-06-13	Metals, Total	Space #53	Copper & Lead Monitoring
CuPb-ss05	SP 2210107-5	2022-06-13	Metals, Total	Space #67	Copper & Lead Monitoring
CuPb-ss06	SP 2210107-6	2022-06-13	Metals, Total	Space #84	Copper & Lead Monitoring
Well 2	SP 1414581-1	2014-12-15	Wet Chemistry	WELL 02	Chrome 6 Monitoring
WELL 02	SP 1902363-1	2019-02-20	Radio Chemistry	WELL 02	GOLDEN SANDS MOBILE HOME PARK
	SP 2102321-1	2021-02-17	General Mineral	WELL 02	Water Quality Monitoring
	SP 2102321-1	2021-02-17	Metals, Total	WELL 02	Water Quality Monitoring
	SP 2102321-1	2021-02-17	Wet Chemistry	WELL 02	Water Quality Monitoring
	SP 2215190-1	2022-09-21	Metals, Total	WELL 02	GOLDEN SANDS MOBILE HOME PARK
Well #2	SP 2220381-1	2022-12-22	Wet Chemistry	WELL 02	Golden Sands MHP



## SANITARY SURVEY APPOINTMENT\_1900537\_OAK GROVE FAMILY PARK

---

From: DeLisa Dabney (ddabney@ph.lacounty.gov)

To: pastorgenestabe@aol.com

Cc: btway@ph.lacounty.gov

Date: Thursday, February 15, 2024 at 10:18 AM PST

---

Pastor Gene,

A Sanitary Survey has been scheduled for 11:30 a.m. Wednesday, May 15, 2024 at 1900537 OAK GROVE FAMILY PARK.

Please have a water system representative available to meet me.

I am also requesting a confirmation for the appointment via e-mail.

*Please note we have confirmed Sanitary Survey appointment at 1900717 Casa Dulce Estates at 10:00 a.m. on the same day.*

Thank you.

Delisa Y. Dabney EHS III, MBA  
Department of Public Health/Environmental Health Division  
Environmental Protection Branch  
Drinking Water Program  
5050 Commerce Drive  
Baldwin Park, CA 91706  
Office: (626) 430-5420  
[ddabney@ph.lacounty.gov](mailto:ddabney@ph.lacounty.gov)