

# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at  
[http://www.swrcb.ca.gov/drinking\\_water/certific\(drinkingwater\)/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certific(drinkingwater)/CCR.shtml))

Water System Name:	Sleepy Valley Water Co., Inc.
Water System Number:	1900903

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 5-4-21 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Daniel A. O'Connor	
	Signature:	Daniel A. O'Connor	
	Title:	President SVWC	
	Phone Number:	(661) 219-3446	Date: 4/30/2021

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

Mailed

☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> \_\_\_\_\_
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> \_\_\_\_\_

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at  
[http://www.swrcb.ca.gov/drinking\\_water/certific\(drinkingwater\)/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certific(drinkingwater)/CCR.shtml))

Water System Name:	Sleepy Valley Water Co., Inc.
--------------------	-------------------------------

# 2020 Consumer Confidence Report

Water System Name: Sleepy Valley Water Co., Inc.

Report Date: \_\_\_\_\_

April 2021

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 2 source(s):** Well 01 and Well 02

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings are held at 13045 Chrisco Street, Sleepy Valley, CA. 91390 on the first Saturday of each month, at 8:30am. Meeting date/time are subject to change.

For more information about this report, or any questions relating to your drinking water, please call (661) 510-3092 and ask for Brad Kinney.

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**pCi/L:** picocuries per liter (a measure of radiation)

**NTU:** Nephelometric Turbidity Units

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)



### Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

**Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.**

**Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2020)	5	0.15	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2020)	61	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2020)	555	552 - 557	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

wood preservatives

**Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2020)	61	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2020)	555	552 - 557	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally



Fluoride (mg/L)	(2020)	0.3	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2020)	9.3	8.8 - 9.6	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2020)	9.1	8.8 - 9.4	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ug/L)	(2020)	5	n/a	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2019)	5.24	4.61 - 5.87	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2019)	5	4.80 - 5.19	20	0.43	Erosion of natural deposits
Diethylhexyladipate (ug/L)	(2018)	ND	n/a	400	200	Discharge from chemical factories

**Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2020)	106	102 - 109	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2020)	18	ND - 35	15	n/a	Naturally-occurring organic materials
Iron (ug/L)	(2020)	2710	ND - 5420	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2020)	160	ND - 320	50	n/a	Leaching from natural deposits
Odor Threshold at 60 °C (TON)	(2020)	1	ND - 2	3	n/a	Naturally-occurring organic materials.
Specific Conductance (umhos/cm)	(2020)	1435	1430 - 1440	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2020)	184	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2020)	895	890 - 900	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2020)	2.5	0.2 - 4.8	5	n/a	Soil runoff
Zinc (mg/L)	(2020)	ND	ND - 0.05	5	n/a	Runoff/leaching from natural deposits

**Table 5 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant	
Boron (mg/L)	(2020)	0.2	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.	
					industrial wastes	
Total Dissolved Solids (mg/L)	(2020)	895	890 - 900	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2020)	2.5	0.2 - 4.8	5	n/a	Soil runoff
Zinc (mg/L)	(2020)	ND	ND - 0.05	5	n/a	Runoff/leaching from natural deposits

**Table 5 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2020)	0.2	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
					industrial wastes



Alkalinity (mg/L)	(2020)	335	330 - 340	n/a	n/a
Aggressiveness Index	(2020)	12.6	12.5 - 12.6	n/a	n/a
Langelier Index	(2020)	0.7	0.6 - 0.7	n/a	n/a

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead Specific Language for Community Water Systems:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Sleepy Valley Water Co., Inc.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Color				Color was found at levels that exceed the secondary MCL. The color MCL was set to protect you against unpleasant aesthetic affects due to color. Violating this MCL does not pose a risk to public health.
Iron				Iron was found at levels that

components associated with the service lines and home plumbing. *Sleepy Valley Water Co., Inc.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement



Manganese				Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.
-----------	--	--	--	---

**About your Nitrate as N:** Nitrate above 5 mg/L as nitrogen (50 percent of the MCL), but below 10 mg/L as nitrogen (the MCL); Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

## 2020 Consumer Confidence Report

### Drinking Water Assessment Information

#### Assessment Information

A source water assessment was conducted for the WELL 01 and WELL 02 of the SLEEPY VALLEY WATER CO., INC. water system in July, 2002.

Well 01 - is considered most vulnerable to the following activities not associated with any detected contaminants:  
Septic systems - low density [ $<1/\text{acre}$ ]

Well 02 - is considered most vulnerable to the following activities not associated with any detected contaminants:  
Septic systems - low density [ $<1/\text{acre}$ ]

#### Discussion of Vulnerability

Well 01 is located in a secured shed and is within a secured fenced area. There are no industrial or commercial types of activities around the well. The well is surrounded by large residential lots which are on onsite sewage disposal systems. These lots are also approved for horses. large stable were not noted within 1000 feet of the well locations. There has been no violations of the Coliform rule at this facility. There has been no recorded MCL violations and the bacteriological monthly testing is conducted by an independent laboratory and the reports submitted to the Los Angeles County Health Department and no contaminations have been reported at any time. Onsite sewage system approvals and installations must be conducted around the well location to assure groundwater protection.

Well 02 is located in a secured shed and is within a secured fenced area. There are no industrial or commercial types of activities around the well. The well is surrounded by large residential lots which are on onsite sewage disposal systems. These lots are also approved for horses. large stable were not noted within 1000 feet of the well locations. There has been no violations of the Coliform rule at this facility. There has been no recorded MCL violations and the bacteriological monthly testing is conducted by an independent laboratory and the reports submitted to the Los Angeles County Health Department and no contaminations have been reported at any time. Onsite sewage system approvals and installations must be conducted around the well location to assure groundwater protection.

Well 02 is located in a secured shed and is within a secured fenced area. There are no industrial or commercial types of activities around the well. The well is surrounded by large residential lots which are on onsite sewage disposal systems. These lots are also approved for horses. large stable were not noted within 1000 feet of the well locations. There has been no violations of the Coliform rule at this facility. There has been no recorded MCL violations and the bacteriological monthly testing is conducted by an independent laboratory and the reports submitted to the Los Angeles County Health Department and no contaminations have been reported at any time. Onsite sewage system approvals and installations must be conducted around the well location to assure groundwater protection.