


# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at [http://www.swrcb.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name:	<b>Sleepy Valley Water Co., Inc.</b>
Water System Number:	<b>CA1900903</b>

The water system named above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	<b>Daniel O'Connor</b>	
	Signature:		
	Title:	<b>President</b>	
	Phone Number:	<b>( 661 ) 219-3446</b>	Date: <b>5-8-2023</b>

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

CCR was hand delivered to all attendees of the SVWC Annual Membership Meeting  
held on June 3, 2023. Also delivered via USP to all residences served by SVWC.

☐ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ☐ Posted the CCR on the internet at <http://> \_\_\_\_\_
- ☐ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertised the availability of the CCR in news media (attach a copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)
- ☐ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://> \_\_\_\_\_

☐ For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

# 2022 Consumer Confidence Report

Water System Name: Sleepy Valley Water Co., Inc.

Report Date: April 2023

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2022.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 2 source(s):** WELL 01 and WELL 02  
**and from 2 treated location(s):** 13045 Chrisco Street and After Filter

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings are held at 13045 Chrisco Street, Sleepy Valley, CA. 91390 on the first Saturday of each month, at 8:30am. Meeting date/time are subject to change.

For more information about this report, or any questions relating to your drinking water, please call (661) 510-3092 and ask for Brad Kinney.

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**pCi/L:** picocuries per liter (a measure of radiation)

**NTU:** Nephelometric Turbidity Units

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

**Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2020)	5	0.15	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2020)	61	n/a	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2020)	555	552 - 557	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Barium (mg/L)	(2020)	ND	ND - 0.10	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium (ug/L)	(2020)	20	19 - 21	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits

Fluoride (mg/L)	(2020)	0.3	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2022)	9.5	5.7 - 15.3	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2020)	9.1	8.8 - 9.4	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ug/L)	(2020)	5	n/a	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2019)	5.24	4.61 - 5.87	15	(0)	Erosion of natural deposits.
Diethylhexyladipate (ug/L)	(2018)	ND	n/a	400	200	Discharge from chemical factories
Uranium (pCi/L)	(2019)	5	4.80 - 5.19	20	0.43	Erosion of natural deposits

**Table 4 - TREATED DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Nitrate as N (mg/L)	(2022)	10.2	4.0 - 15.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

**Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2020)	106	102 - 109	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2020)	18	ND - 35	15	n/a	Naturally-occurring organic materials
Iron (ug/L)	(2020)	2710	ND - 5420	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2020)	160	ND - 320	50	n/a	Leaching from natural deposits
Odor Threshold at 60 °C (TON)	(2020)	1	ND - 2	3	n/a	Naturally-occurring organic materials.
Specific Conductance (umhos/cm)	(2020)	1435	1430 - 1440	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2020)	184	n/a	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2020)	895	890 - 900	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2020)	2.5	0.2 - 4.8	5	n/a	Soil runoff
Zinc (mg/L)	(2020)	ND	ND - 0.05	5	n/a	Runoff/leaching from natural deposits

**Table 6 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2020)	0.2	n/a	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

Table 7 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2020)	134	n/a	n/a	n/a
Magnesium (mg/L)	(2020)	54	53 - 54	n/a	n/a
pH (units)	(2020)	7.5	7.4 - 7.6	n/a	n/a
Alkalinity (mg/L)	(2020)	335	330 - 340	n/a	n/a
Aggressiveness Index	(2020)	12.6	12.5 - 12.6	n/a	n/a
Langelier Index	(2020)	0.7	0.6 - 0.7	n/a	n/a

Table 8 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE							
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Haloacetic Acids (five) (ug/L)	(2022)	5	n/a	60	n/a	No	By-product of drinking water disinfection

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Sleepy Valley Water Co., Inc.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Nitrate as N				Infants below the age of six months who drink water containing nitrate in excess of the MCL may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. High nitrate levels may also affect the oxygen-carrying ability of the blood of Pregnant women.
Color				Color was found at levels that exceed the secondary MCL. The color MCL was set to protect you against unpleasant aesthetic affects due to color. Violating this MCL does not pose a risk to public health.
Iron				Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.
Manganese				Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

**About your Nitrate as N:** Nitrate above 5 mg/L as nitrogen (50 percent of the MCL), but below 10 mg/L as nitrogen (the MCL); Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

# **2022 Consumer Confidence Report**

## **Drinking Water Assessment Information**

### **Assessment Information**

A source water assessment was conducted for the WELL 01 and WELL 02 of the SLEEPY VALLEY WATER CO., INC. water system in July, 2002.

### **Discussion of Vulnerability**

Well 01 is located in a secured shed and is within a secured fenced area. There are no industrial or commercial types of activities around the well. The well is surrounded by large residential lots which are on onsite sewage disposal systems. These lots are also approved for horses. large stable were not noted within 1000 feet of the well locations. There has been no violations of the Coliform rule at this facility. There has been no recorded MCL violations and the bacteriological monthly testing is conducted by an independent laboratory and the reports submitted to the Los Angeles County Health Department and no contaminations have been reported at any time. Onsite sewage system approvals and installations must be conducted around the well location to assure groundwater protection.

Well 02 is located in a secured shed and is within a secured fenced area. There are no industrial or commercial types of activities around the well. The well is surrounded by large residential lots which are on onsite sewage disposal systems. These lots are also approved for horses. large stable were not noted within 1000 feet of the well locations. There has been no violations of the Coliform rule at this facility. There has been no recorded MCL violations and the bacteriological monthly testing is conducted by an independent laboratory and the reports submitted to the Los Angeles County Health Department and no contaminations have been reported at any time. Onsite sewage system approvals and installations must be conducted around the well location to assure groundwater protection.

### **Acquiring Information**

View a copy of the complete assessment at:  
Los Angeles County Environmental Health  
5050 Commerce Place  
Baldwin Park, CA 91706

Request a summary of the assessment be sent to you by contacting:  
Russ Johnson  
Chief Environmental Health Specialist  
(626) 430-5380

# Sleepy Valley Water Co., Inc.

## Analytical Results By FGL - 2022

### LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
<b>Copper</b>		mg/L		1.3	.3			0.15	5
13042 Ridge	SP 2008623-3	mg/L				2020-07-01	0.21		
13045 Chrisco Street	SP 2008623-4	mg/L				2020-07-01	0.09		
13060 Chrisco	SP 2008623-5	mg/L				2020-07-01	ND		
13136 Reservoir	SP 2008623-1	mg/L				2020-07-01	ND		
13181 Reservoir	SP 2008623-2	mg/L				2020-07-01	0.07		

### SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Sodium</b>		mg/L		none	none			61	61 - 61
WELL 01	SP 2008935-1	mg/L				2020-07-08	61		
WELL 02	SP 2008935-2	mg/L				2020-07-08	61		
<b>Hardness</b>		mg/L		none	none			555	552 - 557
WELL 01	SP 2008935-1	mg/L				2020-07-08	552		
WELL 02	SP 2008935-2	mg/L				2020-07-08	557		

### PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Barium</b>		mg/L	2	1	2			ND	ND - 0.10
WELL 01	SP 2008935-1	mg/L				2020-07-08	ND		
WELL 02	SP 2008935-2	mg/L				2020-07-08	0.10		
<b>Chromium</b>		ug/L	100	50.0	n/a			20	19 - 21
WELL 01	SP 2008935-1	ug/L				2020-07-08	21		
WELL 02	SP 2008935-2	ug/L				2020-07-08	19		
<b>Fluoride</b>		mg/L		2	1			0.3	0.3 - 0.3
WELL 01	SP 2008935-1	mg/L				2020-07-08	0.3		
WELL 02	SP 2008935-2	mg/L				2020-07-08	0.3		
<b>Nitrate as N</b>		mg/L		10	10			9.5	5.7 - 15.3
WELL 01	SP 2219431-2	mg/L				2022-12-07	9.5		
WELL 01	SP 2217504-2	mg/L				2022-11-02	9.1		
WELL 01	SP 2216433-2	mg/L				2022-10-12	8.7		
WELL 01	SP 2214308-2	mg/L				2022-09-07	8.9		
WELL 01	SP 2212513-2	mg/L				2022-08-03	8.8		
WELL 01	SP 2211043-2	mg/L				2022-07-06	9.4		
WELL 01	SP 2210490-1	mg/L				2022-06-22	8.9		
WELL 01	SP 2209170-2	mg/L				2022-06-01	9.9		
WELL 01	SP 2207432-2	mg/L				2022-05-04	10.6		
WELL 01	SP 2205484-1	mg/L				2022-04-06	11.5		
WELL 01	SP 2203275-2	mg/L				2022-03-02	13.3		
WELL 01	SP 2201791-3	mg/L				2022-02-02	14.9		
WELL 01	SP 2200183-1	mg/L				2022-01-05	15.3		
WELL 02	SP 2219431-3	mg/L				2022-12-07	5.7		
WELL 02	SP 2217504-3	mg/L				2022-11-02	6.2		
WELL 02	SP 2216433-3	mg/L				2022-10-12	6.4		
WELL 02	SP 2214308-3	mg/L				2022-09-07	6.3		
WELL 02	SP 2212513-3	mg/L				2022-08-03	6.3		
WELL 02	SP 2211043-3	mg/L				2022-07-06	7.1		
WELL 02	SP 2210490-2	mg/L				2022-06-22	7.2		
WELL 02	SP 2209170-3	mg/L				2022-06-01	8.2		
WELL 02	SP 2207432-3	mg/L				2022-05-04	8.0		
WELL 02	SP 2205484-2	mg/L				2022-04-06	9.8		



WELL 02	SP 2203275-3	mg/L				2022-03-02	11.4		
WELL 02	SP 2201791-2	mg/L				2022-02-02	12.3		
WELL 02	SP 2200183-2	mg/L				2022-01-05	12.6		
<b>Nitrate + Nitrite as N</b>		mg/L		10	10			9.1	8.8 - 9.4
WELL 01	SP 2008935-1	mg/L				2020-07-08	8.8		
WELL 02	SP 2008935-2	mg/L				2020-07-08	9.4		
<b>Selenium</b>		ug/L	50	50	30			5	5 - 5
WELL 01	SP 2008935-1	ug/L				2020-07-08	5		
WELL 02	SP 2008935-2	ug/L				2020-07-08	5		
<b>Gross Alpha</b>		pCi/L		15	(0)			5.24	4.61 - 5.87
WELL 01	SP 1917580-1	pCi/L				2019-12-26	5.87		
WELL 02	SP 1917580-2	pCi/L				2019-12-26	4.61		
<b>Diethylhexyladipate</b>		ug/L	400	400	200			ND	ND - ND
WELL 01	SP 1803967-1	ug/L				2018-03-26	ND		
WELL 02	SP 1803967-2	ug/L				2018-03-26	NDD		
<b>Uranium</b>		pCi/L		20	0.43			5.00	4.80 - 5.19
WELL 01	SP 1917580-1	pCi/L				2019-12-26	4.80		
WELL 02	SP 1917580-2	pCi/L				2019-12-26	5.19		

TREATED PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Nitrate as N</b>		mg/L		10	10			10.2	4.0 - 15.7
13045 Chrisco Street	SP 2220541-1	mg/L				2022-12-28	8.5		
13045 Chrisco Street	SP 2220372-1	mg/L				2022-12-22	8.7		
13045 Chrisco Street	SP 2219897-1	mg/L				2022-12-14	8.8		
13045 Chrisco Street	SP 2219431-1	mg/L				2022-12-07	9.3		
13045 Chrisco Street	SP 2218947-1	mg/L				2022-11-29	8.8		
13045 Chrisco Street	SP 2218661-1	mg/L				2022-11-22	8.7		
13045 Chrisco Street	SP 2218292-1	mg/L				2022-11-16	8.6		
13045 Chrisco Street	SP 2217978-1	mg/L				2022-11-10	8.7		
13045 Chrisco Street	SP 2217504-1	mg/L				2022-11-02	9.0		
13045 Chrisco Street	SP 2217175-1	mg/L				2022-10-26	8.5		
13045 Chrisco Street	SP 2216828-1	mg/L				2022-10-19	8.1		
13045 Chrisco Street	SP 2216433-1	mg/L				2022-10-12	8.8		
13045 Chrisco Street	SP 2216032-1	mg/L				2022-10-05	8.8		
13045 Chrisco Street	SP 2215594-1	mg/L				2022-09-28	9.0		
13045 Chrisco Street	SP 2215178-1	mg/L				2022-09-21	9.3		
13045 Chrisco Street	SP 2214757-1	mg/L				2022-09-14	8.2		
13045 Chrisco Street	SP 2214308-1	mg/L				2022-09-07	8.8		
13045 Chrisco Street	SP 2214045-1	mg/L				2022-08-31	8.7		
13045 Chrisco Street	SP 2213722-1	mg/L				2022-08-24	8.8		
13045 Chrisco Street	SP 2213415-1	mg/L				2022-08-17	8.7		
13045 Chrisco Street	SP 2212931-1	mg/L				2022-08-10	9.3		
13045 Chrisco Street	SP 2212513-1	mg/L				2022-08-03	9.0		
13045 Chrisco Street	SP 2212111-1	mg/L				2022-07-27	9.0		
13045 Chrisco Street	SP 2211798-1	mg/L				2022-07-20	9.2		
13045 Chrisco Street	SP 2211424-1	mg/L				2022-07-13	9.1		
13045 Chrisco Street	SP 2211043-1	mg/L				2022-07-06	9.5		
13045 Chrisco Street	SP 2210779-1	mg/L				2022-06-29	9.4		
13045 Chrisco Street	SP 2210489-1	mg/L				2022-06-22	9.2		
13045 Chrisco Street	SP 2210111-1	mg/L				2022-06-15	9.1		
13045 Chrisco Street	SP 2209652-1	mg/L				2022-06-08	9.6		
13045 Chrisco Street	SP 2209170-1	mg/L				2022-06-01	10.2		
13045 Chrisco Street	SP 2208882-1	mg/L				2022-05-25	10.4		
13045 Chrisco Street	SP 2208393-1	mg/L				2022-05-18	10.7		
13045 Chrisco Street	SP 2207930-1	mg/L				2022-05-11	11.0		
13045 Chrisco Street	SP 2207432-1	mg/L				2022-05-04	11.1		
13045 Chrisco Street	SP 2206921-1	mg/L				2022-04-27	11.3		
13045 Chrisco Street	SP 2206568-1	mg/L				2022-04-20	11.9		





# Sleepy Valley Water Co., Inc.

## CCR Login Linkage - 2022

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
CuPb-ss03	SP 2008623-3	2020-07-01	Metals, Total	13042 Ridge	Copper & Lead Monitoring
CuPb-ss04	SP 2008623-4	2020-07-01	Metals, Total	13045 Chrisco Street	Copper & Lead Monitoring
Bacti-Rout-ss01	SP 2200179-1	2022-01-05	Coliform	13045 Chrisco Street	Bacteriological Monitoring
13045 CHRISCO	SP 2200183-4	2022-01-05	Wet Chemistry	13045 Chrisco Street	Water Quality Monitoring
Bacti-Rout-ss01	SP 2200587-1	2022-01-12	Wet Chemistry	13045 Chrisco Street	Bacteriological Monitoring
13045 CHRISCO	SP 2201006-1	2022-01-19	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2201424-1	2022-01-26	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
Bacti-Rout-ss01	SP 2201790-1	2022-02-02	Coliform	13045 Chrisco Street	Bacteriological Monitoring
	SP 2201791-1	2022-02-02	Wet Chemistry	13045 Chrisco Street	Water Quality Monitoring
13045 CHRISCO	SP 2202233-1	2022-02-09	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2202643-1	2022-02-16	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2202977-1	2022-02-23	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2203275-1	2022-03-02	Wet Chemistry	13045 Chrisco Street	Nitrate Monitoring
Bacti-Rout-ss01	SP 2203262-1	2022-03-02	Coliform	13045 Chrisco Street	Bacteriological Monitoring
13045 Chrisco S	SP 2203742-1	2022-03-09	Wet Chemistry	13045 Chrisco Street	Sleepy Valley Wate Co.
13045 CHRISCO	SP 2204268-1	2022-03-16	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2204664-1	2022-03-23	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
13045 Chrisco S	SP 2205062-1	2022-03-30	Wet Chemistry	13045 Chrisco Street	Brad Kinney
Bacti-Rout-ss01	SP 2205485-1	2022-04-06	Coliform	13045 Chrisco Street	Bacteriological Monitoring
13045 CHRISCO	SP 2205484-3	2022-04-06	Wet Chemistry	13045 Chrisco Street	Water Quality Monitoring
	SP 2206065-1	2022-04-13	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2206568-1	2022-04-20	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
13045 Chrisco S	SP 2206921-1	2022-04-27	Wet Chemistry	13045 Chrisco Street	Nitrate Monitoring
Bacti-Rout-ss01	SP 2207434-1	2022-05-04	Coliform	13045 Chrisco Street	Bacteriological Monitoring
	SP 2207432-1	2022-05-04	Wet Chemistry	13045 Chrisco Street	Nitrate Monitoring
13045 CHRISCO	SP 2207930-1	2022-05-11	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2208393-1	2022-05-18	Wet Chemistry	13045 Chrisco Street	Nitrate Monitoring
	SP 2208882-1	2022-05-25	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2209170-1	2022-06-01	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
Bacti-Rout-ss01	SP 2209137-1	2022-06-01	Coliform	13045 Chrisco Street	Bacteriological Monitoring
13045 CHRISCO	SP 2209652-1	2022-06-08	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2210111-1	2022-06-15	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2210489-1	2022-06-22	Wet Chemistry	13045 Chrisco Street	Nitrate Monitoring
	SP 2210492-1	2022-06-22	EPA 552.2	13045 Chrisco Street	DBPR Monitoring
	SP 2210779-1	2022-06-29	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2211043-1	2022-07-06	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
Bacti-Rout-ss01	SP 2211041-1	2022-07-06	Coliform	13045 Chrisco Street	Bacteriological Monitoring
13045 CHRISCO	SP 2211424-1	2022-07-13	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2211798-1	2022-07-20	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2212111-1	2022-07-27	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2212513-1	2022-08-03	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
Bacti-Rout-ss01	SP 2212512-1	2022-08-03	Coliform	13045 Chrisco Street	Bacteriological Monitoring
13045 CHRISCO	SP 2212931-1	2022-08-10	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2213415-1	2022-08-17	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2213722-1	2022-08-24	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2214045-1	2022-08-31	Wet Chemistry	13045 Chrisco Street	Nitrate Monitoring
Bacti-Rout-ss01	SP 2214307-1	2022-09-07	Coliform	13045 Chrisco Street	Bacteriological Monitoring
13045 CHRISCO	SP 2214308-1	2022-09-07	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2214757-1	2022-09-14	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2215178-1	2022-09-21	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2215594-1	2022-09-28	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2216032-1	2022-10-05	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2216433-1	2022-10-12	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
Bacti-Rout-ss01	SP 2216432-1	2022-10-12	Coliform	13045 Chrisco Street	Bacteriological Monitoring
13045 CHRISCO	SP 2216828-1	2022-10-19	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring

	SP 2217175-1	2022-10-26	Wet Chemistry	13045 Chrisco Street	Nitrate Monitoring
	SP 2217504-1	2022-11-02	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
Bacti-Rout-ss01	SP 2217498-1	2022-11-02	Coliform	13045 Chrisco Street	Bacteriological Monitoring
	SP 2217978-1	2022-11-10	Wet Chemistry	13045 Chrisco Street	Bacteriological Monitoring
13045 CHRISCO	SP 2218292-1	2022-11-16	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2218661-1	2022-11-22	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2218947-1	2022-11-29	Wet Chemistry	13045 Chrisco Street	Nitrate Monitoring
Bacti-Rout-ss01	SP 2219432-1	2022-12-07	Coliform	13045 Chrisco Street	Bacteriological Monitoring
13045 CHRISCO	SP 2219431-1	2022-12-07	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2219897-1	2022-12-14	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2220372-1	2022-12-22	Wet Chemistry	13045 Chrisco Street	Drinking Water Monitoring
	SP 2220541-1	2022-12-28	Wet Chemistry	13045 Chrisco Street	Nitrate Monitoring
CuPb-ss05	SP 2008623-5	2020-07-01	Metals, Total	13060 Chrisco	Copper & Lead Monitoring
13136 Reservoir	SP 2008623-1	2020-07-01	Metals, Total	13136 Reservoir	Copper & Lead Monitoring
CuPb-ss02	SP 2008623-2	2020-07-01	Metals, Total	13181 Reservoir	Copper & Lead Monitoring
After Filter	SP 2200183-3	2022-01-05	Wet Chemistry	After Filter	Water Quality Monitoring
WELL 01	SP 1803967-1	2018-03-26		WELL 01	Water Quality - SOC's
	SP 1917580-1	2019-12-26	Radio Chemistry	WELL 01	2019 Water Quality-Radio/CN
	SP 2008935-1	2020-07-08	Metals, Total	WELL 01	Water Quality Monitoring
	SP 2008935-1	2020-07-08	Wet Chemistry	WELL 01	Water Quality Monitoring
	SP 2008935-1	2020-07-08	General Mineral	WELL 01	Water Quality Monitoring
	SP 2200183-1	2022-01-05	Wet Chemistry	WELL 01	Water Quality Monitoring
	SP 2201791-3	2022-02-02	Wet Chemistry	WELL 01	Water Quality Monitoring
	SP 2203275-2	2022-03-02	Wet Chemistry	WELL 01	Nitrate Monitoring
	SP 2205484-1	2022-04-06	Wet Chemistry	WELL 01	Water Quality Monitoring
Well #1	SP 2207432-2	2022-05-04	Wet Chemistry	WELL 01	Nitrate Monitoring
WELL 01	SP 2209170-2	2022-06-01	Wet Chemistry	WELL 01	SLEEPY VALLEY WATER COMPANY
	SP 2210490-1	2022-06-22	Wet Chemistry	WELL 01	Water Quality Monitoring
	SP 2211043-2	2022-07-06	Wet Chemistry	WELL 01	SLEEPY VALLEY WATER COMPANY
	SP 2212513-2	2022-08-03	Wet Chemistry	WELL 01	SLEEPY VALLEY WATER COMPANY
	SP 2214308-2	2022-09-07	Wet Chemistry	WELL 01	SLEEPY VALLEY WATER COMPANY
	SP 2216433-2	2022-10-12	Wet Chemistry	WELL 01	SLEEPY VALLEY WATER COMPANY
	SP 2217504-2	2022-11-02	Wet Chemistry	WELL 01	SLEEPY VALLEY WATER COMPANY
	SP 2219431-2	2022-12-07	Wet Chemistry	WELL 01	SLEEPY VALLEY WATER COMPANY
WELL 02	SP 1803967-2	2018-03-26		WELL 02	Water Quality - SOC's
	SP 1917580-2	2019-12-26	Radio Chemistry	WELL 02	Radio Monitoring
	SP 2008935-2	2020-07-08	General Mineral	WELL 02	Water Quality Monitoring
	SP 2008935-2	2020-07-08	Metals, Total	WELL 02	Water Quality Monitoring
	SP 2008935-2	2020-07-08	Wet Chemistry	WELL 02	Water Quality Monitoring
	SP 2200183-2	2022-01-05	Wet Chemistry	WELL 02	Water Quality Monitoring
	SP 2201791-2	2022-02-02	Wet Chemistry	WELL 02	Water Quality Monitoring
	SP 2203275-3	2022-03-02	Wet Chemistry	WELL 02	Nitrate Monitoring
	SP 2205484-2	2022-04-06	Wet Chemistry	WELL 02	Water Quality Monitoring
Well #2	SP 2207432-3	2022-05-04	Wet Chemistry	WELL 02	Nitrate Monitoring
WELL 02	SP 2209170-3	2022-06-01	Wet Chemistry	WELL 02	SLEEPY VALLEY WATER COMPANY
	SP 2210490-2	2022-06-22	Wet Chemistry	WELL 02	Water Quality Monitoring
	SP 2211043-3	2022-07-06	Wet Chemistry	WELL 02	SLEEPY VALLEY WATER COMPANY
	SP 2212513-3	2022-08-03	Wet Chemistry	WELL 02	SLEEPY VALLEY WATER COMPANY
	SP 2214308-3	2022-09-07	Wet Chemistry	WELL 02	SLEEPY VALLEY WATER COMPANY
	SP 2216433-3	2022-10-12	Wet Chemistry	WELL 02	SLEEPY VALLEY WATER COMPANY
	SP 2217504-3	2022-11-02	Wet Chemistry	WELL 02	SLEEPY VALLEY WATER COMPANY
	SP 2219431-3	2022-12-07	Wet Chemistry	WELL 02	SLEEPY VALLEY WATER COMPANY