

2024 Consumer Confidence Report

Water System Information

Water System Name: Lily of the Valley

Report Date: June 13, 2025

Type of Water Source(s) in Use: Ground Water Well 04

Name and General Location of Source(s): Well 04 across Bouquet Canyon Road west of Mobile Home Park

Drinking Water Source Assessment Information: Well 04 – The source is considered most vulnerable to the following activities not associated with any detected contaminants, animal operations, septic systems, high density (< 1 acre), wells and agricultural/irrigation. It may also be vulnerable to storage tanks.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: There are no board meetings, however, residents are notified by written notices of any information needed.

For More Information, Contact: Manager's office, Diana Sanders. 661-296-8540

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2024, and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Lily of the Valley a 29021 Bouquet Canyon Road, Saugus, CA, 661-296-8540 [Enter Water System's Phone Number] para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Lily of the Valley 以获得中文的帮助: 29021 Bouquet Canyon Road, Saugus, CA, 661-296-8540][Enter Water System's Phone Number].

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Lily of the Valley, o tumawag sa 29021 Bouquet Canyon Road para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ [Enter Water System's Name] tại Lily of the Valley, 661-296-8540 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu ra Lily of the Valley ntawm 29021 Bouquet Canyon Road, Saugus, CA rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	None	N/A	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	08/01/2024	10	N/D	None	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	08/01/2024	10	0.14	None	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm) Well 04	9/27/22	62	N/A	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm) Well 04	9/27/22	260	N/A	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are

						usually naturally occurring.
--	--	--	--	--	--	------------------------------

The system conducted a Lead and Copper inventory to determine if there were any lead pipe in the system. There were none.

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Nitrate (ppm) Well 04	9/17/24	3.6	N/A	10	0.40	Erosion of natural deposits, runoff from orchards, glass and electronics production.
Fluoride (ppm) Well 04	9/27/22	0.32	N/A	2	0.10	Erosion of natural deposits, runoff from orchards, glass and electronics production.
Total THM (ppb) Distribution system	7/26/24	8.6	N/A	1.0	80	Byproduct of drinking water disinfectant
HAA5 (ppb) Distribution system	7/26/24	2.1	N/A	1.0	60	Byproduct of drinking water disinfectant
Gross Alpha Well04	8/27/19	4.6	N/A	15	3	Erosion of natural deposit.
Uranium Well 04	8/27/19	3.5	N/A	20	1	Erosion of Natural deposits.

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm) Well 04	9/27/22	5.9	N/A	500	1.0	Runoff/leaching from natural deposits; seawater influence.
Sulfate (ppm) Well 04	9/27/22	31	N/A	500	0.5	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (ECucm)Well 04	9/27/22	500	N/A	1600	2.0	Substances that form ions when in water; industrial wastes.
Odor Threshold (TON) Well 04	9/27/22	1.0	N/A	3	1.0	Naturally occurring materials.

Table 6. Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
NONE	N/A	N/A	N/A	N/A	N/A

During 2024 Lily of the Valley water system completed a Lead Inventory to identify the service line material for the piping. There were no lead lines found in our system. If you have questions, please contact management office.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC)

guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lily of the Valley is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>. **No lead has been found in any tests taken at Lily of the Valley water system. There was also a lead and copper inventory conducted, and no lead piping was found.**

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*: **There was a level in a Nitrate Test at the Park of 3.6 the MCL is 10 ppm; this is not a dangerous level. Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 pp., may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.**

State Revised Total Coliform Rule (RTCR): **This Confidence Report (CCR) reflects changes in drinking water regulatory requirements during 2021. These revisions add the requirements of the Federal Revised Total Coliform Rule, effective Since April 1, 2016, to the existing State Total Coliform rules. The revised rule maintains the purpose to protect public health by insuring the integrity of the drinking water distribution system and monitoring for the presence of microbials (i.e. total coliform and E. Coli bacteria) The U. S. EPA anticipates greater public protection as the rule requires water systems that are vulnerable to microbial contamination to identify and fix problems. Water Systems that exceed a specified frequency of total coliform occurrences are required to conduct an assessment to determine if any sanitary defects exist. If found, these must be corrected by the water system. The State Revised Total Coliform rule became effective July 1, 2021. Please note: On page 2 of this report there is reference to Level 1 and 2 Assessments.**

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
NONE	N/A	N/A	N/A	N/A

For Water Systems Providing Groundwater as a Source of Drinking Water**Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples**

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	None	N/A	0	(0)	Human and animal fecal waste
Enterococci	None	N/A	TT	N/A	Human and animal fecal waste
Coliphage	None	N/A	TT	N/A	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

Special Notice of Fecal Indicator-Positive Groundwater Source Sample: [Enter Special Notice of Fecal Indicator-Positive Groundwater Source Sample] THERE WERE NONE.

Special Notice for Uncorrected Significant Deficiencies: [Enter Special Notice for Uncorrected Significant Deficiencies] THERE WERE NONE

Table 9. Violation of Groundwater TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
NONE	N/A	N/A	N/A	N/A

For Systems Providing Surface Water as a Source of Drinking Water**Table 10. Sampling Results Showing Treatment of Surface Water Sources. Surface water is not a source at this system.**

Treatment Technique ^(a) (Type of approved filtration technology used)	N/A
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to [Enter Turbidity Performance Standard to Be Less Than or Equal to 95% of Measurements in a Month] NTU in 95% of measurements in a month.

	<p>2 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded for More Than Eight Consecutive Hours] NTU for more than eight consecutive hours.</p> <p>3 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded at Any Time] NTU at any time.</p>
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	None
Highest single turbidity measurement during the year	None
Number of violations of any surface water treatment requirements	None

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a Surface Water TT

Table 11. Violation of Surface Water TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
NONE	N/A	N/A	N/A	N/A

Summary Information for Operating Under a Variance or Exemption

LILY OF THE VALLEY DID NOT OPERATE UNDER A VARIANCE OR EXEMPTION.

Summary Information for Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

If a water system is required to comply with a Level 1 or Level 2 assessment requirement that is not due to an *E. coli* MCL violation, include the following information below [22 CCR section 64481(n)(1)].

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. There were NO coliforms indicating the need to look for potential problems in water treatment or distribution.

The water system shall include the following statements, as appropriate: Lily of the Valley was required to conduct No Level 1 or 2 Assessments because there were no coliforms found in the distribution system.

During the past year we were required to conduct NO Level 1 assessment(s) required.

[For Violation of the Total Coliform Bacteria TT Requirement, THERE WERE NONE REQUIRED.

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation: THERE WAS NO *E. coli* FOUND IN OUR WATER SYSTEM.

If a water system detects *E. coli* and has violated the *E. coli* MCL THERE WAS NO DETECTION OR VIOLATION.

HEALTH EFFECTS LANGUAGE RESULTS IN THIS REPORT – Although this water system has not detected any result over the MCL, this language has been provided for you information. There were no tests that resulted in over the MCL.

TABLE 4 –PRIMARY DRINKING WATER STANDARDS. THESE ARE BASED ON HEALTH EFFECTS.

Nitrate – Infants below the age of six months, who drink water containing nitrate in excess of the MCL (10 ppm) may quickly become seriously ill and, if untreated may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. High nitrate levels may also affect oxygen-carrying ability of the blood of pregnant women.

Fluoride – Some people who drink water containing fluoride in excess of the Federal MCL (4ppm) over many years may get bone disease, including pain and tenderness of the bones. Children who drink water containing Fluoride in excess of the State MCL (2 ppm) may get mottled teeth.

TTHM – The level detected in our drinking is well below the MCL. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience liver/kidney, or central nervous system problems and may have an increased risk of getting cancer.

HAA5 – Some people who drink water containing halocetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

GROSS ALPHA – Certain minerals are radioactive and may emit a form of radiation know as Alpha Radiation. Some people who drink water containing uranium in excess of the MCL, over many years may have kidney problems or an increased risk of getting cancer.

URANIUM – Some people who drink water containing uranium in excess of the MCL over many years may have kidney problems or an increased risk of getting cancer.

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD. SECONDARY STANDARDS ARE SET ON THE BASIS OF ASTHETICS.

CHLORIDE – Chloride is not considered the cause of any effect.

SULFATE – Sulfate is not considered the cause of any effect; persons who drink water with a higher level than the MCL may experience diarrhea.

SPECIFIC CONDUCTANCE – Has no known effect.

TOTAL DISSOLVED SOLIDS (TDS) – TDS are the sum of solids that have dissolved in the water, such as calcium, minerals, and some organics. Although there are no known effects to humans, higher levels may cause scaling in plumbing.

PLEASE REMEMBER TO BE CONSERVATIVE IN YOUR WATER USE.