

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at
http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: **NORTH TRAILS MUTUAL WATER CO**

Water System Number: **1907014**

The water system above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By: Name _____
 Signature _____
 Title _____
 Phone Number () _____ Date _____

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

_____ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

_____ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

_____ Posted the CCR on the internet at http:// _____

_____ Mailed the CCR to postal patrons within the service area (attach zip codes used)

_____ Advertised the availability of the CCR in news media (attach a copy of press release)

_____ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

_____ Posted the CCR in public places (attach a list of locations)

_____ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools

_____ Delivery to community organizations (attach a list of organizations)

_____ Other (attach a list of other methods used)

_____ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http:// _____

_____ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

2017 Consumer Confidence Report

Water System Name: NORTH TRAILS MUTUAL WATER CO

Report Date: May 2018

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2017.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, the Sources are Groundwater. The Assessments were done using the Default Groundwater System Method.

Your water comes from 3 source(s): Well 07, Well 08 - PENDING and Well 09
and from 1 treated location(s): NO3 - 11540 Durango Lane

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are held annually, fliers are sent out announcing the location, date, and time.

For more information about this report, or any questions relating to your drinking water, please call 661-268-8125 and ask for Mark Whatley.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (ppm)	10 (2015)	0.05	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (ppm)	(2011 - 2015)	86	60 - 111	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	(2011 - 2015)	131	20.7 - 242	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Aluminum (ppm)	(2011 - 2015)	0.63	ND - 1.90	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes
Arsenic (ppb)	(2011 - 2017)	4	ND - 7	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes

Fluoride (ppm)	(2011 - 2017)	1.6	0.3 - 2.9	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (ppm)	(2016)	1.7	ND - 3.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (ppm)	(2011 - 2015)	2.8	0.4 - 5.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2017)	12	2.69 - 21.1	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2017)	5.047	ND - 10.1	20	0.43	Erosion of natural deposits
Toluene (ppb)	(2011 - 2015)	ND	ND - 0.6	150	150	Discharge from petroleum and chemical factories; underground gas tank leaks

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (ppm)	(2011 - 2015)	59	27 - 90	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ppb)	(2011 - 2015)	425	ND - 850	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ppb)	(2011 - 2015)	ND	ND - 20	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2011 - 2015)	628	525 - 730	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (ppm)	(2011 - 2015)	29	25 - 33	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	(2011 - 2015)	345	310 - 380	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2011)	0.6	n/a	5	n/a	Soil runoff

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (ppm)	(2011 - 2015)	1.5	0.1 - 2.9	1	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.
Vanadium (ppm)	(2011 - 2015)	ND	ND - 0.004	0.05	The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental effects, based on studies in laboratory animals.

Table 6 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2011 - 2015)	37	5 - 69	n/a	n/a
Magnesium (mg/L)	(2011 - 2015)	10	2 - 17	n/a	n/a
pH (units)	(2011 - 2015)	8.2	7.9 - 8.5	n/a	n/a
Alkalinity (mg/L)	(2011 - 2015)	170	n/a	n/a	n/a
Aggressiveness Index	(2011 - 2015)	12.1	11.8 - 12.4	n/a	n/a
Langelier Index	(2011 - 2015)	0.25	-0.01 - 0.5	n/a	n/a

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *North Trails Mutual Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Aluminum: Some people who drink water containing aluminum in excess of the MCL over many years may experience short-term gastrointestinal tract effects.

About our Fluoride: Some people who drink water containing fluoride in excess of the federal MCL of 4 mg/L over many years may get bone disease, including pain and tenderness of the bones. Children who drink water containing fluoride in excess of the state MCL of 2 mg/L may get mottled teeth.

About our Gross Alpha: Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

About our Iron: Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

2017 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 06 and WELL 07 of the NORTH TRAILS MUTUAL WATER CO water system in April, 2002. A source water assessment was conducted for the WELL 08 of the NORTH TRAILS MUTUAL WATER CO water system in August, 2004. The source WELL 09 of the NORTH TRAILS MUTUAL WATER CO is located only 10 feet from WELL 06, therefore is subject to the same activities. The 11540 DURANGO LANE of the NORTH TRAILS MUTUAL WATER CO is a central meeting point of the water from each well therefore does not require an assessment.

- Well 07 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Grazing [> 5 large animals or equivalent per acre]
Septic systems - low density [<1/acre]
- Well 08 - PENDING - is considered most vulnerable to the following activities not associated with any detected contaminants:
Grazing [> 5 large animals or equivalent per acre]
Septic systems - low density [<1/acre]
- Well 09 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Grazing [> 5 large animals or equivalent per acre]
Septic systems - low density [<1/acre]

Discussion of Vulnerability

WELLS 06, 07, 09: This water system draws from 4 - 5 wells and the water delivered from this system is known to have elevated nitrate levels - over half the MCL of 45 ppm. This water system is currently drawing water from other wells to assure that the water it delivers is below the MCL. Los Angeles County Environmental Health currently oversees this system and conducts the required monitoring tests. Please note that although Well 06 is dry the Assessment info has been included in this report as a reference for Well 09, as WELL 09 is subject to the same Possible Contaminating Activity (PCE) as WELL 06 and uses the same source water assessment.

WELL 08: This water system draws from 2 wells. The water delivered is known to have elevated nitrate and uranium levels, over half of respective MCLs. In addition, three standby wells have high uranium ranging from 211 to 285 pCi/L. Los Angeles County Environmental Health currently oversees this water system and conducted the required monitoring. There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Acquiring Information

A copy of the complete WELL06/WELL09 and WELL07 assessment may be viewed at:
Los Angeles County Environmental Health
2525 Corporate Pl. Room 150
Monterey Park, CA 91754

A copy of the complete WELL 08 assessment may be viewed at:
Los Angeles County Environmental Health
5050 Commerce Drive
Baldwin Park, CA 91706-1423

You may request a summary of the complete WELL06/WELL09 and WELL07 assessments be sent to you by contacting:
Russ Johnson
Chief Environmental Health Specialist
(323) 881-4147
(323) 269-4327 (fax)

You may request a summary of the WELL 08 assessment be sent to you by contacting:
Patrick Nejadian
Chief, Environmental Health Specialist
(626)430-5380
(626)813-3016 (fax)
pnejadian@dhs.co.la.ca.us

North Trails Mutual Water Co.

Analytical Results By FGL - 2017

LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		ppm		1.3	.3			0.05	10
CuPb - 11540 Durango Lane	SP 1506534-5	ppm				2015-06-10	ND		
CuPb - 11540 Durango Ln.	SP 1514068-5	ppm				2015-12-16	ND		
CuPb - 11705 Laramie Way	SP 1506534-3	ppm				2015-06-10	ND		
CuPb - 11710 Chisholm Ct.	SP 1506534-1	ppm				2015-06-10	ND		
CuPb - 11720 Laramie Way	SP 1506534-4	ppm				2015-06-10	ND		
CuPb - 11735 Chisholm Ct.	SP 1514068-8	ppm				2015-12-16	ND		
CuPb - 11735 Chisholm Ct.	SP 1506534-2	ppm				2015-06-10	ND		
CuPb - 33244 Pewter Rd.	SP 1514068-9	ppm				2015-12-16	0.09		
CuPb - 33310 Trail Ranch	SP 1514068-7	ppm				2015-12-16	0.05		
CuPb - 33410 Trail Ranch Rd.	SP 1514068-6	ppm				2015-12-16	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		ppm		none	none			86	60 - 111
Well 07	SP 1514065-1	ppm				2015-12-16	111		
Well 09	SP 1108651-1	ppm				2011-08-25	60		
Hardness		ppm		none	none			131.4	20.7 - 242
Well 07	SP 1514065-1	ppm				2015-12-16	20.7		
Well 09	SP 1108651-1	ppm				2011-08-25	242		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Aluminum		ppm		1	0.6			0.63	ND - 1.90
Well 07	SP 1514065-1	ppm				2015-12-16	ND		
Well 09	SP 1110771-1	ppm				2011-10-19	ND		
Well 09	SP 1108651-1	ppm				2011-08-25	1.90		
Arsenic		ppb		10	0.004			4	ND - 7
Well 07	SP 1707121-1	ppb				2017-06-14	7		
Well 09	SP 1108651-1	ppb				2011-08-25	ND		
Fluoride		ppm		2	1			1.6	0.3 - 2.9
Well 07	SP 1707121-1	ppm				2017-06-14	2.9		
Well 09	SP 1108651-1	ppm				2011-08-25	0.3		
Nitrate as N		ppm		10	10			1.7	ND - 3.7
Well 07	SP 1602680-5	ppm				2016-03-09	1.4		
Well 08 - PENDING	SP 1602680-7	ppm				2016-03-09	ND		
Well 09	SP 1602680-8	ppm				2016-03-09	3.7		
Nitrate + Nitrite as N		ppm		10	10			2.8	0.4 - 5.2
Well 07	SP 1514065-1	ppm				2015-12-16	0.4		
Well 09	SP 1108651-1	ppm				2011-08-25	5.2		
Gross Alpha		pCi/L		15	(0)			11.53	2.69 - 21.1
Well 07	SP 1708964-1	pCi/L				2017-07-26	2.69		
Well 08 - PENDING	SP 1708964-2	pCi/L				2017-07-26	10.8		
Well 09	SP 1708964-3	pCi/L				2017-07-26	21.1		
Uranium		pCi/L		20	0.43			5.047	ND - 10.1
Well 07	SP 1708964-1	pCi/L				2017-07-26	ND		
Well 08 - PENDING	SP 1708964-2	pCi/L				2017-07-26	5.04		
Well 09	SP 1708964-3	pCi/L				2017-07-26	10.1		
Toluene		ppb		150	150			ND	ND - 0.6
Well 07	SP 1514065-1	ppb				2015-12-16	ND		
Well 09	SP 1108651-1	ppb				2011-08-25	0.6		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		ppm		500	n/a			59	27 - 90
Well 07	SP 1514065-1	ppm				2015-12-16	27		
Well 09	SP 1108651-1	ppm				2011-08-25	90		
Iron		ppb		300	n/a			425	ND - 850
Well 07	SP 1514065-1	ppb				2015-12-16	ND		
Well 09	SP 1108651-1	ppb				2011-08-25	850		
Manganese		ppb		50	n/a			ND	ND - 20
Well 07	SP 1514065-1	ppb				2015-12-16	ND		
Well 09	SP 1108651-1	ppb				2011-08-25	20		
Specific Conductance		umhos/cm		1600	n/a			628	525 - 730
Well 07	SP 1514065-1	umhos/cm				2015-12-16	525		
Well 09	SP 1108651-1	umhos/cm				2011-08-25	730		
Sulfate		ppm		500	n/a			29	25 - 33
Well 07	SP 1514065-1	ppm				2015-12-16	25		
Well 09	SP 1108651-1	ppm				2011-08-25	33		
Total Dissolved Solids		ppm		1000	n/a			345	310 - 380
Well 07	SP 1514065-1	ppm				2015-12-16	310		
Well 09	SP 1108651-1	ppm				2011-08-25	380		
Turbidity		NTU		5	n/a			0.6	0.6 - 0.6
Well 09	SP 1108651-1	NTU				2011-08-25	0.6		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		ppm		NS	n/a			1.5	0.1 - 2.9
Well 07	SP 1514065-1	ppm				2015-12-16	2.9		
Well 09	SP 1108651-1	ppm				2011-08-25	0.1		
Vanadium		ppm		NS	n/a			ND	ND - 0.004
Well 07	SP 1514065-1	ppm				2015-12-16	ND		
Well 09	SP 1108651-1	ppm				2011-08-25	0.004		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			37	5 - 69
Well 07	SP 1514065-1	mg/L				2015-12-16	5		
Well 09	SP 1108651-1	mg/L				2011-08-25	69		
Magnesium		mg/L			n/a			10	2 - 17
Well 07	SP 1514065-1	mg/L				2015-12-16	2		
Well 09	SP 1108651-1	mg/L				2011-08-25	17		
pH		units			n/a			8.2	7.9 - 8.5
Well 07	SP 1514065-1	units				2015-12-16	8.5		
Well 09	SP 1108651-1	units				2011-08-25	7.9		
Alkalinity		mg/L			n/a			170	170 - 170
Well 07	SP 1514065-1	mg/L				2015-12-16	170		
Well 09	SP 1108651-1	mg/L				2011-08-25	170		
Aggressiveness Index					n/a			12.1	11.8 - 12.4
Well 07	SP 1514065-1					2015-12-16	11.8		
Well 09	SP 1108651-1					2011-08-25	12.4		
Langelier Index					n/a			0.25	-0.01 - 0.5
Well 07	SP 1514065-1					2015-12-16	-0.01		
Well 09	SP 1108651-1					2011-08-25	0.5		

North Trails Mutual Water Co.

CCR Login Linkage - 2017

FGL Code	Lab ID	Date Sampled	Method	Description	Property
Bacti-Rout-ss01	SP 1700353-1	2017-01-11	Coliform	Bacti - 11540 Durango Lane	Bacti Monitoring
	SP 1701701-6	2017-02-08	Coliform	Bacti - 11540 Durango Lane	BacT
	SP 1702907-1	2017-03-08	Coliform	Bacti - 11540 Durango Lane	Bacti Monitoring
	SP 1704719-1	2017-04-19	Coliform	Bacti - 11540 Durango Lane	Bacti Monitoring
	SP 1706286-1	2017-05-24	Coliform	Bacti - 11540 Durango Lane	Bacti Monitoring
	SP 1706796-1	2017-06-07	Coliform	Bacti - 11540 Durango Lane	Bacti Monitoring
	SP 1708963-1	2017-07-26	Coliform	Bacti - 11540 Durango Lane	Bacti Monitoring
	SP 1710284-1	2017-08-23	Coliform	Bacti - 11540 Durango Lane	Bacti Monitoring
	SP 1711127-1	2017-09-13	Coliform	Bacti - 11540 Durango Lane	Bacteriological Monitoring
	SP 1712526-1	2017-10-11	Coliform	Bacti - 11540 Durango Lane	Bacteriological Monitoring
	SP 1713787-1	2017-11-08	Coliform	Bacti - 11540 Durango Lane	Bacteriological Monitoring
11540 Durango L	SP 1506534-5	2015-06-10	Metals, Total	CuPb - 11540 Durango Lane	Cu & Pb Monitoring
CuPb-ss05	SP 1514068-5	2015-12-16	Metals, Total	CuPb - 11540 Durango Ln.	Cu & Pb Monitoring
11705 Laramie W	SP 1506534-3	2015-06-10	Metals, Total	CuPb - 11705 Laramie Way	Cu & Pb Monitoring
11710 Chisholm	SP 1506534-1	2015-06-10	Metals, Total	CuPb - 11710 Chisholm Ct.	Cu & Pb Monitoring
11720 Laramie W	SP 1506534-4	2015-06-10	Metals, Total	CuPb - 11720 Laramie Way	Cu & Pb Monitoring
11735 Chisholm	SP 1506534-2	2015-06-10	Metals, Total	CuPb - 11735 Chisholm Ct.	Cu & Pb Monitoring
CuPb-ss02	SP 1514068-8	2015-12-16	Metals, Total	CuPb - 11735 Chisholm Ct.	Cu & Pb Monitoring
CuPb-ss06	SP 1514068-9	2015-12-16	Metals, Total	CuPb - 33244 Pewter Rd.	Cu & Pb Monitoring
CuPb-ss07	SP 1514068-7	2015-12-16	Metals, Total	CuPb - 33310 Trail Ranch	Cu & Pb Monitoring
CuPb-ss08	SP 1514068-6	2015-12-16	Metals, Total	CuPb - 33410 Trail Ranch Rd.	Cu & Pb Monitoring
WELL 07	SP 1514065-1	2015-12-16	General Mineral	Well 07	Water Quality - Well 7
	SP 1514065-1	2015-12-16	Metals, Total	Well 07	Water Quality - Well 7
	SP 1514065-1	2015-12-16	EPA 524.2	Well 07	Water Quality - Well 7
Well 07	SP 1602680-5	2016-03-09	Wet Chemistry	Well 07	Nitrate Monitoring
WELL 07	SP 1707121-1	2017-06-14	Wet Chemistry	Well 07	Water Quality - Well 7
	SP 1707121-1	2017-06-14	Metals, Total	Well 07	Water Quality - Well 7
	SP 1708964-1	2017-07-26	Radio Chemistry	Well 07	NORTH TRAILS MUTUAL WATER CO
WELL 08	SP 1602680-7	2016-03-09	Wet Chemistry	Well 08 - PENDING	Nitrate Monitoring
	SP 1708964-2	2017-07-26	Radio Chemistry	Well 08 - PENDING	NORTH TRAILS MUTUAL WATER CO
Well 09	SP 1108651-1	2011-08-25	General Mineral	Well 09	Title 22 Analysis
	SP 1108651-1	2011-08-25	Metals, Total	Well 09	Title 22 Analysis
	SP 1108651-1	2011-08-25	Wet Chemistry	Well 09	Title 22 Analysis
	SP 1108651-1	2011-08-25	EPA 524.2	Well 09	Title 22 Analysis
	SP 1110771-1	2011-10-19	Metals, Total	Well 09	Well 9
WELL 09	SP 1602680-8	2016-03-09	Wet Chemistry	Well 09	Nitrate Monitoring
Well #9	SP 1708964-3	2017-07-26	Radio Chemistry	Well 09	NORTH TRAILS MUTUAL WATER CO