

# 2023 Consumer Confidence Report

Water System Name: NORTH TRAILS MUTUAL WATER CO

Report Date: April 2024

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2023.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, the Sources are Groundwater. The Assessments were done using the Default Groundwater System Method.

**Your water comes from 3 source(s):** WELL 07, WELL 08 and WELL 09

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings are held annually, fliers are sent out announcing the location, date, and time.

For more information about this report, or any questions relating to your drinking water, please call 661-268-8125 and ask for Mark Whatley.

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**mg/L:** milligrams per liter or parts per million (ppm)

**ug/L:** micrograms per liter or parts per billion (ppb)

**pCi/L:** picocuries per liter (a measure of radiation)

**NTU:** Nephelometric Turbidity Units

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.



**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

**Table 1 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2021 - 2022)	81	53 - 106	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2021 - 2022)	112	32.3 - 203	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2021 - 2023)	8	ND - 11	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Fluoride (mg/L)	(2021 - 2023)	3.2	0.3 - 4.7	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2023)	0.8	ND - 1.4	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2021 - 2022)	2.6	0.6 - 6.0	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits



Selenium (ug/L)	(2021 - 2022)	6	ND - 11	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2017 - 2022)	6.35	2.69 - 10.8	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2017 - 2022)	2.79	ND - 4.19	20	0.43	Erosion of natural deposits

<b>Table 3 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD</b>						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2021 - 2022)	66	41 - 86	500	n/a	Runoff/leaching from natural deposits; seawater influence
Manganese (ug/L)	(2021 - 2022)	33	ND - 80	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2021 - 2022)	621	539 - 721	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2021 - 2022)	34.1	31.0 - 37.0	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2021 - 2022)	363	340 - 390	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2021 - 2022)	0.1	ND - 0.2	5	n/a	Soil runoff

<b>Table 4 - DETECTION OF UNREGULATED CONTAMINANTS</b>					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2021 - 2022)	1	0.2 - 2.3	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Manganese (ug/L)	(2021 - 2022)	33	ND - 80	500	Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.

<b>Table 5 - ADDITIONAL DETECTIONS</b>					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2021 - 2022)	30	8 - 55	n/a	n/a
Magnesium (mg/L)	(2021 - 2022)	9	3 - 16	n/a	n/a
pH (units)	(2021 - 2022)	7.82	7.53 - 8.36	n/a	n/a
Alkalinity (mg/L)	(2021 - 2022)	163	160 - 170	n/a	n/a
Aggressiveness Index	(2021 - 2022)	11.8	11.6 - 11.9	n/a	n/a
Langelier Index	(2021 - 2022)	0	-0.3 - 0.04	n/a	n/a

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.



USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead Specific Language for Community Water Systems:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *North Trails Mutual Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Arsenic				Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
Fluoride				Some people who drink water containing fluoride in excess of the federal MCL of 4 mg/L over many years may get bone disease, including pain and tenderness of the bones. Children who drink water containing fluoride in excess of the state MCL of 2 mg/L may get mottled teeth.
Manganese				Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system.

**About your Arsenic:** For Arsenic detected above 5 ug/L (50% of the MCL) but below or equal to 10 ug/L: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

# **2023 Consumer Confidence Report**

## **Drinking Water Assessment Information**

### **Assessment Information**

A source water assessment was conducted for the WELL 06 and WELL 07 of the NORTH TRAILS MUTUAL WATER CO water system in April, 2002. A source water assessment was conducted for the WELL 08 of the NORTH TRAILS MUTUAL WATER CO water system in August, 2004. The source WELL 09 of the NORTH TRAILS MUTUAL WATER CO is located only 10 feet from WELL 06, therefore is subject to the same activities. The 11540 DURANGO LANE of the NORTH TRAILS MUTUAL WATER CO is a central meeting point of the water from each well therefore does not require an assessment.

WELL 07 - is considered most vulnerable to the following activities not associated with any detected contaminants:  
Grazing [> 5 large animals or equivalent per acre]  
Septic systems - low density [<1/acre]

WELL 08 - is considered most vulnerable to the following activities not associated with any detected contaminants:  
Grazing [> 5 large animals or equivalent per acre]  
Septic systems - low density [<1/acre]

WELL 09 - is considered most vulnerable to the following activities not associated with any detected contaminants:  
Grazing [> 5 large animals or equivalent per acre]  
Septic systems - low density [<1/acre]

### **Discussion of Vulnerability**

WELLS 06, 07, 09: This water system draws from 4 - 5 wells and the water delivered from this system is known to have elevated nitrate levels - over half the MCL of 45 ppm. This water system is currently drawing water from other wells to assure that the water it delivers is below the MCL. Los Angeles County Environmental Health currently oversees this system and conducts the required monitoring tests. Please note that although Well 06 is dry the Assessment info has been included in this report as a reference for Well 09, as WELL 09 is subject to the same Possible Contaminating Activity (PCE) as WELL 06 and uses the same source water assessment.

WELL 08: This water system draws from 2 wells. The water delivered is known to have elevated nitrate and uranium levels, over half of respective MCLs. In addition, three standby wells have high uranium ranging from 211 to 285 pCi/L. Los Angeles County Environmental Health currently oversees this water system and conducted the required monitoring. There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

### **Acquiring Information**

A copy of the complete WELL06/WELL09 and WELL07 assessment may be viewed at:  
Los Angeles County Environmental Health  
2525 Corporate Pl. Room 150  
Monterey Park, CA 91754

A copy of the complete WELL 08 assessment may be viewed at:  
Los Angeles County Environmental Health  
5050 Commerce Drive  
Baldwin Park, CA 91706-1423

You may request a summary of the complete WELL06/WELL09 and WELL07 assessments be sent to you by contacting:  
Russ Johnson  
Chief Environmental Health Specialist  
(323) 881-4147  
(323) 269-4327 (fax)

You may request a summary of the WELL 08 assessment be sent to you by contacting:  
Patrick Nejadian  
Chief, Environmental Health Specialist  
(626)430-5380  
(626)813-3016 (fax)



# North Trails Mutual Water Co.

## Analytical Results By FGL - 2023

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			81	53 - 106
WELL 07	SP 2112482-1	mg/L				2021-09-08	106		
WELL 08	SP 2216421-1	mg/L				2022-10-12	84		
WELL 09	SP 2116104-1	mg/L				2021-11-10	53		
Hardness		mg/L		none	none			112.4	32.3 - 203
WELL 07	SP 2112482-1	mg/L				2021-09-08	32.3		
WELL 08	SP 2216421-1	mg/L				2022-10-12	102		
WELL 09	SP 2116104-1	mg/L				2021-11-10	203		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			8	ND - 11
WELL 07	SP 2320480-1	ug/L				2023-12-13	10		
WELL 07	SP 2315544-1	ug/L				2023-09-13	10		
WELL 07	SP 2309981-1	ug/L				2023-06-14	11		
WELL 07	SP 2303417-1	ug/L				2023-03-08	10		
WELL 08	SP 2216421-1	ug/L				2022-10-12	8		
WELL 09	SP 2116104-1	ug/L				2021-11-10	ND		
Fluoride		mg/L		2	1			3.2	0.3 - 4.7
WELL 07	SP 2320480-1	mg/L				2023-12-13	4.3		
WELL 07	SP 2315544-1	mg/L				2023-09-13	4.5		
WELL 07	SP 2309981-1	mg/L				2023-06-14	4.6		
WELL 07	SP 2303417-1	mg/L				2023-03-08	4.7		
WELL 08	SP 2216421-1	mg/L				2022-10-12	0.7		
WELL 09	SP 2116104-1	mg/L				2021-11-10	0.3		
Nitrate as N		mg/L		10	10			0.8	ND - 1.4
WELL 07	SP 2317240-1	mg/L				2023-10-11	0.7		
WELL 07	SP 2315544-1	mg/L				2023-09-13	0.6		
WELL 07	SP 2311929-1	mg/L				2023-07-12	0.6		
WELL 07	SP 2305465-1	mg/L				2023-04-12	0.7		
WELL 07	SP 2300434-1	mg/L				2023-01-11	0.6		
WELL 08	SP 2317240-2	mg/L				2023-10-11	1.4		
WELL 08	SP 2311929-2	mg/L				2023-07-12	1.4		
WELL 08	SP 2305465-2	mg/L				2023-04-12	1.4		
WELL 08	SP 2300434-2	mg/L				2023-01-11	ND		
WELL 09	SP 2317244-1	mg/L				2023-10-11	1.0		
WELL 09	SP 2311928-1	mg/L				2023-07-12	0.8		
WELL 09	SP 2305463-1	mg/L				2023-04-12	0.6		
Nitrate + Nitrite as N		mg/L		10	10			2.6	0.6 - 6.0
WELL 07	SP 2112482-1	mg/L				2021-09-08	0.6		
WELL 08	SP 2216421-1	mg/L				2022-10-12	1.1		
WELL 09	SP 2116104-1	mg/L				2021-11-10	6.0		
Selenium		ug/L	50	50	30			6	ND - 11
WELL 07	SP 2112482-1	ug/L				2021-09-08	ND		
WELL 08	SP 2216421-1	ug/L				2022-10-12	11		
WELL 09	SP 2116104-1	ug/L				2021-11-10	6		
Gross Alpha		pCi/L		15	(0)			6.35	2.69 - 10.8
WELL 07	SP 1708964-1	pCi/L				2017-07-26	2.69		
WELL 08	SP 2216421-1	pCi/L				2022-10-12	10.8		
WELL 09	SP 2203737-1	pCi/L				2022-03-09	5.55		
Uranium		pCi/L		20	0.43			2.790	ND - 4.19
WELL 07	SP 1708964-1	pCi/L				2017-07-26	ND		



WELL 08	SP 2216421-1	pCi/L				2022-10-12	4.18		
WELL 09	SP 2203737-1	pCi/L				2022-03-09	4.19		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Chloride</b>		mg/L		500	n/a			66	41 - 86
WELL 07	SP 2112482-1	mg/L				2021-09-08	41		
WELL 08	SP 2216421-1	mg/L				2022-10-12	71		
WELL 09	SP 2116104-1	mg/L				2021-11-10	86		
<b>Manganese</b>		ug/L		50	n/a			33	ND - 80
WELL 07	SP 2112482-1	ug/L				2021-09-08	ND		
WELL 08	SP 2216421-1	ug/L				2022-10-12	20		
WELL 09	SP 2116104-1	ug/L				2021-11-10	80		
<b>Specific Conductance</b>		umhos/cm		1600	n/a			621	539 - 721
WELL 07	SP 2112482-1	umhos/cm				2021-09-08	539		
WELL 08	SP 2216421-1	umhos/cm				2022-10-12	604		
WELL 09	SP 2116104-1	umhos/cm				2021-11-10	721		
<b>Sulfate</b>		mg/L		500	n/a			34.1	31.0 - 37.0
WELL 07	SP 2112482-1	mg/L				2021-09-08	31.0		
WELL 08	SP 2216421-1	mg/L				2022-10-12	34.2		
WELL 09	SP 2116104-1	mg/L				2021-11-10	37.0		
<b>Total Dissolved Solids</b>		mg/L		1000	n/a			363	340 - 390
WELL 07	SP 2112482-1	mg/L				2021-09-08	360		
WELL 08	SP 2216421-1	mg/L				2022-10-12	340		
WELL 09	SP 2116104-1	mg/L				2021-11-10	390		
<b>Turbidity</b>		NTU		5	n/a			0.1	ND - 0.2
WELL 07	SP 2112482-1	NTU				2021-09-08	ND		
WELL 08	SP 2216421-1	NTU				2022-10-12	0.2		
WELL 09	SP 2116104-1	NTU				2021-11-10	ND		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Boron</b>		mg/L		NS	n/a			1.0	0.2 - 2.3
WELL 07	SP 2112482-1	mg/L				2021-09-08	2.3		
WELL 08	SP 2216421-1	mg/L				2022-10-12	0.4		
WELL 09	SP 2116104-1	mg/L				2021-11-10	0.2		
<b>Manganese</b>		ug/L		NS	n/a			33	ND - 80
WELL 07	SP 2112482-1	ug/L				2021-09-08	ND		
WELL 08	SP 2216421-1	ug/L				2022-10-12	20		
WELL 09	SP 2116104-1	ug/L				2021-11-10	80		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Calcium</b>		mg/L			n/a			30	8 - 55
WELL 07	SP 2112482-1	mg/L				2021-09-08	8		
WELL 08	SP 2216421-1	mg/L				2022-10-12	26		
WELL 09	SP 2116104-1	mg/L				2021-11-10	55		
<b>Magnesium</b>		mg/L			n/a			9	3 - 16
WELL 07	SP 2112482-1	mg/L				2021-09-08	3		
WELL 08	SP 2216421-1	mg/L				2022-10-12	9		
WELL 09	SP 2116104-1	mg/L				2021-11-10	16		
<b>pH</b>		units			n/a			7.82	7.53 - 8.36
WELL 07	SP 2112482-1	units				2021-09-08	8.36		
WELL 08	SP 2216421-1	units				2022-10-12	7.57		
WELL 09	SP 2116104-1	units				2021-11-10	7.53		
<b>Alkalinity</b>		mg/L			n/a			163	160 - 170

WELL 07	SP 2112482-1	mg/L				2021-09-08	160		
WELL 08	SP 2216421-1	mg/L				2022-10-12	160		
WELL 09	SP 2116104-1	mg/L				2021-11-10	170		
<b>Aggressiveness Index</b>					n/a			11.8	11.6 - 11.9
WELL 07	SP 2112482-1					2021-09-08	11.9		
WELL 08	SP 2216421-1					2022-10-12	11.6		
WELL 09	SP 2116104-1					2021-11-10	11.9		
<b>Langelier Index</b>					n/a			-0.08	-0.3 - 0.04
WELL 07	SP 2112482-1					2021-09-08	0.02		
WELL 08	SP 2216421-1					2022-10-12	-0.3		
WELL 09	SP 2116104-1					2021-11-10	0.04		



# North Trails Mutual Water Co.

## CCR Login Linkage - 2023

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
CuPb-ss05	SP 2108081-5	2021-06-16	Metals, Total	11540 Durango Ln.	Cu & Pb Monitoring
	SP 2117571-5	2021-12-07	Metals, Total	11540 Durango Ln.	Cu & Pb Monitoring
CuPb-ss03	SP 2108081-3	2021-06-16	Metals, Total	11705 Laramie Wy.	Cu & Pb Monitoring
	SP 2117571-3	2021-12-07	Metals, Total	11705 Laramie Wy.	Cu & Pb Monitoring
CuPb-ss01	SP 2108081-1	2021-06-16	Metals, Total	11710 Chisholm Ct.	Cu & Pb Monitoring
	SP 2117571-1	2021-12-07	Metals, Total	11710 Chisholm Ct.	Cu & Pb Monitoring
CuPb-ss04	SP 2108081-4	2021-06-16	Metals, Total	11720 Laramie Wy.	Cu & Pb Monitoring
	SP 2117571-4	2021-12-07	Metals, Total	11720 Laramie Wy.	Cu & Pb Monitoring
CuPb-ss02	SP 2108081-2	2021-06-16	Metals, Total	11735 Chisholm Ct.	Cu & Pb Monitoring
	SP 2117571-2	2021-12-07	Metals, Total	11735 Chisholm Ct.	Cu & Pb Monitoring
Bacti-Rout-ss04	SP 2300433-1	2023-01-11	Coliform	33495 Overland Trail	Bacti Monitoring
	SP 2301952-1	2023-02-08	Coliform	33495 Overland Trail	Bacti Monitoring
	SP 2303416-1	2023-03-08	Coliform	33495 Overland Trail	Bacti Monitoring
	SP 2305462-1	2023-04-12	Coliform	33495 Overland Trail	Bacti Monitoring
	SP 2307596-1	2023-05-10	Coliform	33495 Overland Trail	Bacti Monitoring
33495 Overland	SP 2309983-1	2023-06-14	Coliform	33495 Overland Trail	Bacteriological Monitoring
	SP 2311930-1	2023-07-12	Coliform	33495 Overland Trail	Bacteriological Monitoring
	SP 2313604-1	2023-08-09	Coliform	33495 Overland Trail	Bacteriological Monitoring
Bacti-Rout-ss04	SP 2315545-1	2023-09-13	Coliform	33495 Overland Trail	Bacti Monitoring
	SP 2317239-1	2023-10-11	Coliform	33495 Overland Trail	Bacti Monitoring
33495 Overland	SP 2318746-1	2023-11-08	Coliform	33495 Overland Trail	Bacteriological Monitoring
	SP 2320482-1	2023-12-13	Coliform	33495 Overland Trail	Bacteriological Monitoring
WELL 07	SP 1708964-1	2017-07-26	Radio Chemistry	WELL 07	NORTH TRAILS MUTUAL WATER CO
	SP 2112482-1	2021-09-08	General Mineral	WELL 07	Water Quality - Well 7
	SP 2112482-1	2021-09-08	Metals, Total	WELL 07	Water Quality - Well 7
	SP 2112482-1	2021-09-08	Wet Chemistry	WELL 07	Water Quality - Well 7
	SP 2214746-1	2022-09-14		WELL 07	Water Quality - Well 7
	SP 2300434-1	2023-01-11	Wet Chemistry	WELL 07	Nitrate Monitoring
	SP 2303417-1	2023-03-08	Wet Chemistry	WELL 07	Water Quality - Well 7
	SP 2303417-1	2023-03-08	Metals, Total	WELL 07	Water Quality - Well 7
	SP 2305465-1	2023-04-12	Wet Chemistry	WELL 07	Nitrate Monitoring
	SP 2309981-1	2023-06-14	Wet Chemistry	WELL 07	Water Quality - Well 7
	SP 2309981-1	2023-06-14	Metals, Total	WELL 07	Water Quality - Well 7
	SP 2311929-1	2023-07-12	Wet Chemistry	WELL 07	Nitrate Monitoring
	SP 2315544-1	2023-09-13	Metals, Total	WELL 07	Water Quality - Well 7
	SP 2315544-1	2023-09-13	Wet Chemistry	WELL 07	Water Quality - Well 7
	SP 2317240-1	2023-10-11	Wet Chemistry	WELL 07	Nitrate Monitoring
	SP 2320480-1	2023-12-13	Wet Chemistry	WELL 07	Water Quality - Well 7
	SP 2320480-1	2023-12-13	Metals, Total	WELL 07	Water Quality - Well 7
WELL 08	SP 1807934-1	2018-06-18		WELL 08	Water Quality - Well 8
	SP 2216421-1	2022-10-12	General Mineral	WELL 08	Water Quality - Well 8
	SP 2216421-1	2022-10-12	Metals, Total	WELL 08	Water Quality - Well 8
	SP 2216421-1	2022-10-12	Wet Chemistry	WELL 08	Water Quality - Well 8
	SP 2216421-1	2022-10-12		WELL 08	Water Quality - Well 8
	SP 2216421-1	2022-10-12	Radio Chemistry	WELL 08	Water Quality - Well 8
	SP 2300434-2	2023-01-11	Wet Chemistry	WELL 08	Nitrate Monitoring
	SP 2305465-2	2023-04-12	Wet Chemistry	WELL 08	Nitrate Monitoring
WELL DISTRIBUTI	SP 2311929-2	2023-07-12	Wet Chemistry	WELL 08	Nitrate Monitoring
	SP 2317240-2	2023-10-11	Wet Chemistry	WELL 08	Nitrate Monitoring
WELL 09	SP 2116104-1	2021-11-10	General Mineral	WELL 09	Water Quality - Well 9
	SP 2116104-1	2021-11-10	Metals, Total	WELL 09	Water Quality - Well 9
	SP 2116104-1	2021-11-10	Wet Chemistry	WELL 09	Water Quality - Well 9
	SP 2203737-1	2022-03-09	Radio Chemistry	WELL 09	Radio Monitoring
	SP 2203737-1	2022-03-09	Metals, Total	WELL 09	Radio Monitoring

	SP 2305463-1	2023-04-12	Wet Chemistry	WELL 09	Water Quality - Well 9
	SP 2311928-1	2023-07-12	Wet Chemistry	WELL 09	Water Quality - Well 9
	SP 2317244-1	2023-10-11	Wet Chemistry	WELL 09	Water Quality - Well 9