

2025 Consumer Confidence Report

Water System Name: NORTH TRAILS MUTUAL WATER CO

Report Date: March 2026

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, the Sources are Groundwater. The Assessments were done using the Default Groundwater System Method.

Your water comes from 4 source(s): Well 07, WELL 08, Well 08 - PENDING and Well 09

and from 3 treated location(s): 11540 Durango Lane, 33423 Domino Hill Road and Water Tank

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are held annually, fliers are sent out announcing the location, date, and time.

For more information about this report, or any questions relating to your drinking water, please call 661-268-8125 and ask for Mark Whatley.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Table(s) 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

| Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA | | | | | |
|--|----------------------------------|-----------------------------------|--|-------------|---------------------------------------|
| Microbiological Contaminants (complete if bacteria detected) | Highest No. of Detections | No. of Months in Violation | MCL | MCLG | Typical Sources of Contaminant |
| Total Coliform Bacteria | 1/year (2025) | 0 | no more than 1 positive monthly sample | 0 | Naturally present in the environment. |
| Fecal coliform and E. coli | 0 (2025) | ND | | | Human and animal fecal waste. |

| Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS | | | | | | |
|---|--------------------|-------------------------------|----------------------------|------------|-------------------|--|
| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Sources of Contaminant |
| Sodium (mg/L) | (2021 - 2025) | 83 | 53 - 106 | none | none | Salt present in the water and is generally naturally occurring |
| Hardness (mg/L) | (2021 - 2025) | 94.6 | 32.3 - 203 | none | none | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

| Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD | | | | | | |
|---|--------------------|-------------------------------|----------------------------|-------------------|---------------------------|--|
| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Sources of Contaminant |
| Arsenic (ug/L) | (2021 - 2025) | 8 | ND - 11 | 10 | 0.004 | Erosion of natural deposits; runoff from orchards, glass and electronics production wastes |
| Chromium (ug/L) | (2024 - 2025) | ND | ND - 14 | 50.0 | n/a | Discharge from steel and pulp mills and chrome plating; erosion of natural deposits |

| | | | | | | |
|-------------------------------|---------------|-------|-------------|----|------|--|
| Fluoride (mg/L) | (2021 - 2025) | 2.7 | 0.3 - 4.7 | 2 | 1 | Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories. |
| Nitrate as N (mg/L) | (2025) | 3.1 | ND - 7.7 | 10 | 10 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits |
| Nitrate + Nitrite as N (mg/L) | (2021 - 2025) | 1.8 | 0.6 - 6.0 | 10 | 10 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits |
| Selenium (ug/L) | (2021 - 2025) | 6 | ND - 11 | 50 | 30 | Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive) |
| Gross Alpha (pCi/L) | (2017 - 2025) | 8.19 | 2.69 - 13.4 | 15 | (0) | Erosion of natural deposits. |
| Uranium (pCi/L) | (2017 - 2025) | 4.699 | ND - 11.8 | 20 | 0.43 | Erosion of natural deposits |

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Sources of Contaminant |
|--|---------------|------------------------|---------------------|------|------------|---|
| Chloride (mg/L) | (2021 - 2025) | 62 | 41 - 86 | 500 | n/a | Runoff/leaching from natural deposits; seawater influence |
| Iron (ug/L) | (2024 - 2025) | 13 | ND - 40 | 300 | n/a | Leaching from natural deposits; Industrial wastes |
| Manganese (ug/L) | (2021 - 2025) | 14 | ND - 40 | 50 | n/a | Leaching from natural deposits |
| Specific Conductance (umhos/cm) | (2021 - 2025) | 596 | 539 - 721 | 1600 | n/a | Substances that form ions when in water; seawater influence |
| Sulfate (mg/L) | (2021 - 2025) | 34.7 | 31.0 - 37.2 | 500 | n/a | Runoff/leaching from natural deposits; industrial wastes |
| Total Dissolved Solids (mg/L) | (2021 - 2025) | 355 | 330 - 390 | 1000 | n/a | Runoff/leaching from natural deposits |
| Turbidity (NTU) | (2021 - 2025) | 0.13 | ND - 0.30 | 5 | n/a | Soil runoff |

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | Notification Level | Health Effects |
|--|---------------|------------------------|---------------------|--------------------|--|
| Boron (mg/L) | (2021 - 2025) | 1 | 0.2 - 2.3 | 1 | Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats. |
| Vanadium (ug/L) | (2024 - 2025) | 4 | 2 - 6 | 50 | Vanadium exposures resulted in developmental and reproductive effects in rats. |
| Manganese (ug/L) | (2021 - 2025) | 14 | ND - 40 | 500 | Manganese exposures resulted in neurological effects. High levels of manganese in people have been shown to result in adverse effects to the nervous system. |

Table 6 - ADDITIONAL DETECTIONS

| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | Notification Level | Typical Sources of Contaminant |
|--|---------------|------------------------|---------------------|--------------------|--------------------------------|
| Calcium (mg/L) | (2021 - 2025) | 25 | 8 - 55 | n/a | n/a |
| Magnesium (mg/L) | (2021 - 2025) | 8 | 3 - 16 | n/a | n/a |
| pH (units) | (2021 - 2025) | 8.03 | 7.53 - 8.7 | n/a | n/a |
| Alkalinity (mg/L) | (2021 - 2025) | 167 | 160 - 170 | n/a | n/a |
| Aggressiveness Index | (2021 - 2025) | 12 | 11.6 - 12.4 | n/a | n/a |
| Langelier Index | (2021 - 2025) | 0.09 | -0.3 - 0.5 | n/a | n/a |

| Table 7 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE | | | | | | | |
|--|--------------------|-------------------------------|----------------------------|-------------------|-------------------|------------------|--|
| Chemical or Constituent (and reporting units) | Sample Date | Average Level Detected | Range of Detections | MCL (MRDL) | PHG (MCLG) | Violation | Typical Sources of Contaminant |
| Chlorine, Total (mg/L) | (2025) | 1.40 | n/a | 4.0 | 4.0 | No | Drinking water disinfectant added for treatment. |

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *North Trails Mutual Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

| VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT | | | | |
|--|--------------------|-----------------|---|---|
| Violation | Explanation | Duration | Actions Taken To Correct the Violation | Health Effects Language |
| Total Coliform Bacteria | | | | Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments. |
| Arsenic | | | | Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer. |
| Fluoride | | | | Some people who drink water containing fluoride in excess of the federal MCL of 4 mg/L over many years may get bone disease, including pain and tenderness of the bones. Children who drink water containing fluoride in excess of the state MCL of 2 mg/L may get mottled teeth. |

About your Arsenic: For Arsenic detected above 5 ug/L (50% of the MCL) but below or equal to 10 ug/L: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

2025 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 06 and WELL 07 of the NORTH TRAILS MUTUAL WATER CO

water system in April, 2002. A source water assessment was conducted for the WELL 08 of the NORTH TRAILS MUTUAL WATER CO water system in August, 2004. The source WELL 09 of the NORTH TRAILS MUTUAL WATER CO is located only 10 feet from WELL 06, therefore is subject to the same activities. The 11540 DURANGO LANE of the NORTH TRAILS MUTUAL WATER CO is a central meeting point of the water from each well therefore does not require an assessment.

- Well 07 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Grazing [> 5 large animals or equivalent per acre]
Septic systems - low density [<1 /acre]
- WELL 08 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Grazing [> 5 large animals or equivalent per acre]
Septic systems - low density [<1 /acre]
- Well 08 - PENDING - is considered most vulnerable to the following activities not associated with any detected contaminants:
Grazing [> 5 large animals or equivalent per acre]
Septic systems - low density [<1 /acre]
- Well 09 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Grazing [> 5 large animals or equivalent per acre]
Septic systems - low density [<1 /acre]

Discussion of Vulnerability

WELLS 06, 07, 09: This water system draws from 4 - 5 wells and the water delivered from this system is known to have elevated nitrate levels - over half the MCL of 45 ppm. This water system is currently drawing water from other wells to assure that the water it delivers is below the MCL. Los Angeles County Environmental Health currently oversees this system and conducts the required monitoring tests. Please note that although Well 06 is dry the Assessment info has been included in this report as a reference for Well 09, as WELL 09 is subject to the same Possible Contaminating Activity (PCE) as WELL 06 and uses the same source water assessment.

WELL 08: This water system draws from 2 wells. The water delivered is known to have elevated nitrate and uranium levels, over half of respective MCLs. In addition, three standby wells have high uranium ranging from 211 to 285 pCi/L. Los Angeles County Environmental Health currently oversees this water system and conducted the required monitoring. There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Acquiring Information

A copy of the complete WELL06/WELL09 and WELL07 assessment may be viewed at:
Los Angeles County Environmental Health
2525 Corporate Pl. Room 150
Monterey Park, CA 91754

A copy of the complete WELL 08 assessment may be viewed at:
Los Angeles County Environmental Health
5050 Commerce Drive
Baldwin Park, CA 91706-1423

You may request a summary of the complete WELL06/WELL09 and WELL07 assessments be sent to you by contacting:
Russ Johnson
Chief Environmental Health Specialist
(323) 881-4147
(323) 269-4327 (fax)

You may request a summary of the WELL 08 assessment be sent to you by contacting:
Patrick Nejadian
Chief, Environmental Health Specialist

(626)430-5380
(626)813-3016 (fax)
pnejadian@dhs.co.la.ca.us

North Trails Mutual Water Co.

Analytical Results By FGL - 2025

| MICROBIOLOGICAL CONTAMINANTS | | | | | | | | | |
|-----------------------------------|--------------|-------|------|--------|-----|------------|---------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Total Coliform Bacteria | | | 0 | 5% | n/a | | | 0 | - |
| 33361 Pewter Road | SP 2511708-3 | | | | | 2025-07-11 | Absent | | |
| 33423 Domino Hill Road | SP 2511708-4 | | | | | 2025-07-11 | Absent | | |
| 33495 Overland Trail | SP 2521184-1 | | | | | 2025-12-10 | Absent | | |
| 33495 Overland Trail | SP 2519367-1 | | | | | 2025-11-12 | Absent | | |
| 33495 Overland Trail | SP 2517147-1 | | | | | 2025-10-08 | Absent | | |
| 33495 Overland Trail | SP 2515370-1 | | | | | 2025-09-10 | Absent | | |
| 33495 Overland Trail | SP 2513802-1 | | | | | 2025-08-14 | Absent | | |
| 33495 Overland Trail | SP 2511708-1 | | | | | 2025-07-11 | <1 | | |
| 33495 Overland Trail | SP 2511580-1 | | | | | 2025-07-09 | Present | | |
| 33495 Overland Trail | SP 2510003-1 | | | | | 2025-06-11 | Absent | | |
| 33495 Overland Trail | SP 2508024-1 | | | | | 2025-05-14 | Absent | | |
| 33495 Overland Trail | SP 2505592-1 | | | | | 2025-04-09 | Absent | | |
| 33495 Overland Trail | SP 2503829-1 | | | | | 2025-03-12 | Absent | | |
| 33495 Overland Trail | SP 2502467-1 | | | | | 2025-02-18 | Absent | | |
| 33495 Overland Trail | SP 2500330-1 | | | | | 2025-01-08 | Absent | | |
| Water Tank | SP 2511708-2 | | | | | 2025-07-11 | Absent | | |
| Fecal coliform and E. coli | | | 0 | | n/a | | | ND | - |
| 33361 Pewter Road | SP 2511708-3 | | | | | 2025-07-11 | Absent | | |
| 33423 Domino Hill Road | SP 2511708-4 | | | | | 2025-07-11 | Absent | | |
| 33495 Overland Trail | SP 2521184-1 | | | | | 2025-12-10 | Absent | | |
| 33495 Overland Trail | SP 2519367-1 | | | | | 2025-11-12 | Absent | | |
| 33495 Overland Trail | SP 2517147-1 | | | | | 2025-10-08 | Absent | | |
| 33495 Overland Trail | SP 2515370-1 | | | | | 2025-09-10 | Absent | | |
| 33495 Overland Trail | SP 2513802-1 | | | | | 2025-08-14 | Absent | | |
| 33495 Overland Trail | SP 2511708-1 | | | | | 2025-07-11 | <1 | | |
| 33495 Overland Trail | SP 2511580-1 | | | | | 2025-07-09 | Absent | | |
| 33495 Overland Trail | SP 2510003-1 | | | | | 2025-06-11 | Absent | | |
| 33495 Overland Trail | SP 2508024-1 | | | | | 2025-05-14 | Absent | | |
| 33495 Overland Trail | SP 2505592-1 | | | | | 2025-04-09 | Absent | | |
| 33495 Overland Trail | SP 2503829-1 | | | | | 2025-03-12 | Absent | | |
| 33495 Overland Trail | SP 2502467-1 | | | | | 2025-02-18 | Absent | | |
| 33495 Overland Trail | SP 2500330-1 | | | | | 2025-01-08 | Absent | | |
| Water Tank | SP 2511708-2 | | | | | 2025-07-11 | Absent | | |

| LEAD AND COPPER RULE | | | | | | | | | |
|----------------------|--------------|-------|------|--------|-----|------------|--------|-----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | 90th Percentile | # Samples |
| Lead | | ug/L | 0 | 15 | 0.2 | | | 0 | 5 |
| 11540 Durango Lane | SP 2409544-5 | ug/L | | | | 2024-06-11 | ND | | |
| 11705 Laramie Wy. | SP 2409544-3 | ug/L | | | | 2024-06-11 | ND | | |
| 11710 Chisholm Ct. | SP 2409544-1 | ug/L | | | | 2024-06-11 | ND | | |
| 11720 Laramie Wy. | SP 2409544-4 | ug/L | | | | 2024-06-11 | ND | | |
| 11735 Chisholm Ct. | SP 2409544-2 | ug/L | | | | 2024-06-11 | ND | | |
| Copper | | mg/L | | 1.3 | .3 | | | 0 | 5 |
| 11540 Durango Lane | SP 2409544-5 | mg/L | | | | 2024-06-11 | ND | | |
| 11705 Laramie Wy. | SP 2409544-3 | mg/L | | | | 2024-06-11 | ND | | |
| 11710 Chisholm Ct. | SP 2409544-1 | mg/L | | | | 2024-06-11 | ND | | |
| 11720 Laramie Wy. | SP 2409544-4 | mg/L | | | | 2024-06-11 | ND | | |
| 11735 Chisholm Ct. | SP 2409544-2 | mg/L | | | | 2024-06-11 | ND | | |

| SAMPLING RESULTS FOR SODIUM AND HARDNESS | | | | | | | | | |
|--|--|-------|------|--------|-----|---------|--------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |

| | | | | | | | | | |
|-----------------|--------------|------|--|------|------|------------|------|------|------------|
| Sodium | | mg/L | | none | none | | | 83 | 53 - 106 |
| Well 07 | SP 2414768-1 | mg/L | | | | 2024-09-11 | 98 | | |
| WELL 07 | SP 2112482-1 | mg/L | | | | 2021-09-08 | 106 | | |
| Well 08 | SP 2518170-1 | mg/L | | | | 2025-10-22 | 84 | | |
| WELL 08 | SP 2216421-1 | mg/L | | | | 2022-10-12 | 84 | | |
| Well 09 | SP 2418729-1 | mg/L | | | | 2024-11-13 | 75 | | |
| WELL 09 | SP 2116104-1 | mg/L | | | | 2021-11-10 | 53 | | |
| Hardness | | mg/L | | none | none | | | 94.6 | 32.3 - 203 |
| Well 07 | SP 2414768-1 | mg/L | | | | 2024-09-11 | 37.3 | | |
| WELL 07 | SP 2112482-1 | mg/L | | | | 2021-09-08 | 32.3 | | |
| Well 08 | SP 2518170-1 | mg/L | | | | 2025-10-22 | 83.7 | | |
| WELL 08 | SP 2216421-1 | mg/L | | | | 2022-10-12 | 102 | | |
| Well 09 | SP 2418729-1 | mg/L | | | | 2024-11-13 | 109 | | |
| WELL 09 | SP 2116104-1 | mg/L | | | | 2021-11-10 | 203 | | |

| PRIMARY DRINKING WATER STANDARDS (PDWS) | | | | | | | | | |
|---|--------------|-------|------|--------|-------|------------|--------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Arsenic | | ug/L | | 10 | 0.004 | | | 8 | ND - 11 |
| Well 07 | SP 2521185-1 | ug/L | | | | 2025-12-10 | 4 | | |
| Well 07 | SP 2515369-1 | ug/L | | | | 2025-09-10 | 4 | | |
| Well 07 | SP 2510004-1 | ug/L | | | | 2025-06-11 | 8 | | |
| Well 07 | SP 2503830-1 | ug/L | | | | 2025-03-12 | 9 | | |
| WELL 07 | SP 2320480-1 | ug/L | | | | 2023-12-13 | 10 | | |
| WELL 07 | SP 2315544-1 | ug/L | | | | 2023-09-13 | 10 | | |
| WELL 07 | SP 2309981-1 | ug/L | | | | 2023-06-14 | 11 | | |
| WELL 07 | SP 2303417-1 | ug/L | | | | 2023-03-08 | 10 | | |
| Well 08 | SP 2518170-1 | ug/L | | | | 2025-10-22 | 10 | | |
| WELL 08 | SP 2216421-1 | ug/L | | | | 2022-10-12 | 8 | | |
| Well 09 | SP 2418729-1 | ug/L | | | | 2024-11-13 | 7 | | |
| WELL 09 | SP 2116104-1 | ug/L | | | | 2021-11-10 | ND | | |
| Chromium | | ug/L | 100 | 50.0 | n/a | | | ND | ND - 14 |
| Well 07 | SP 2414768-1 | ug/L | | | | 2024-09-11 | ND | | |
| Well 08 | SP 2518170-1 | ug/L | | | | 2025-10-22 | ND | | |
| Well 09 | SP 2418729-1 | ug/L | | | | 2024-11-13 | 14 | | |
| Fluoride | | mg/L | | 2 | 1 | | | 2.7 | 0.3 - 4.7 |
| Well 07 | SP 2521185-1 | mg/L | | | | 2025-12-10 | 2.4 | | |
| Well 07 | SP 2515369-1 | mg/L | | | | 2025-09-10 | 1.8 | | |
| Well 07 | SP 2510004-1 | mg/L | | | | 2025-06-11 | 3.8 | | |
| Well 07 | SP 2503830-1 | mg/L | | | | 2025-03-12 | 3.3 | | |
| WELL 07 | SP 2320480-1 | mg/L | | | | 2023-12-13 | 4.3 | | |
| WELL 07 | SP 2315544-1 | mg/L | | | | 2023-09-13 | 4.5 | | |
| WELL 07 | SP 2309981-1 | mg/L | | | | 2023-06-14 | 4.6 | | |
| WELL 07 | SP 2303417-1 | mg/L | | | | 2023-03-08 | 4.7 | | |
| Well 08 | SP 2518170-1 | mg/L | | | | 2025-10-22 | 0.7 | | |
| WELL 08 | SP 2216421-1 | mg/L | | | | 2022-10-12 | 0.7 | | |
| Well 09 | SP 2418729-1 | mg/L | | | | 2024-11-13 | 0.7 | | |
| WELL 09 | SP 2116104-1 | mg/L | | | | 2021-11-10 | 0.3 | | |
| Nitrate as N | | mg/L | | 10 | 10 | | | 3.1 | ND - 7.7 |
| WELL 07 | SP 2518176-1 | mg/L | | | | 2025-10-22 | ND | | |
| Well 07 | SP 2515369-1 | mg/L | | | | 2025-09-10 | 4.4 | | |
| WELL 07 | SP 2511581-1 | mg/L | | | | 2025-07-09 | 1.7 | | |
| WELL 07 | SP 2505594-1 | mg/L | | | | 2025-04-09 | 1.5 | | |
| WELL 07 | SP 2500328-1 | mg/L | | | | 2025-01-08 | 1.2 | | |
| Well 08 | SP 2518170-1 | mg/L | | | | 2025-10-22 | 0.8 | | |
| WELL 08 | SP 2511581-2 | mg/L | | | | 2025-07-09 | 0.9 | | |
| WELL 08 | SP 2505594-2 | mg/L | | | | 2025-04-09 | 1.4 | | |
| WELL 08 | SP 2500328-2 | mg/L | | | | 2025-01-08 | 1.4 | | |
| Well 09 | SP 2518181-1 | mg/L | | | | 2025-10-22 | 7.1 | | |
| WELL 09 | SP 2518176-2 | mg/L | | | | 2025-10-22 | 7.1 | | |

| | | | | | | | | | |
|-------------------------------|--------------|-------|----|----|------|------------|------|-------|-------------|
| Well 09 | SP 2511582-1 | mg/L | | | | 2025-07-09 | 6.4 | | |
| Well 09 | SP 2505593-1 | mg/L | | | | 2025-04-09 | 7.7 | | |
| Well 09 | SP 2500329-1 | mg/L | | | | 2025-01-08 | 1.1 | | |
| Nitrate + Nitrite as N | | mg/L | | 10 | 10 | | | 1.8 | 0.6 - 6.0 |
| Well 07 | SP 2414768-1 | mg/L | | | | 2024-09-11 | 1.0 | | |
| WELL 07 | SP 2112482-1 | mg/L | | | | 2021-09-08 | 0.6 | | |
| Well 08 | SP 2518170-1 | mg/L | | | | 2025-10-22 | 0.8 | | |
| WELL 08 | SP 2216421-1 | mg/L | | | | 2022-10-12 | 1.1 | | |
| Well 09 | SP 2418729-1 | mg/L | | | | 2024-11-13 | 1.1 | | |
| WELL 09 | SP 2116104-1 | mg/L | | | | 2021-11-10 | 6.0 | | |
| Selenium | | ug/L | 50 | 50 | 30 | | | 6 | ND - 11 |
| Well 07 | SP 2414768-1 | ug/L | | | | 2024-09-11 | ND | | |
| WELL 07 | SP 2112482-1 | ug/L | | | | 2021-09-08 | ND | | |
| Well 08 | SP 2518170-1 | ug/L | | | | 2025-10-22 | 8 | | |
| WELL 08 | SP 2216421-1 | ug/L | | | | 2022-10-12 | 11 | | |
| Well 09 | SP 2418729-1 | ug/L | | | | 2024-11-13 | 11 | | |
| WELL 09 | SP 2116104-1 | ug/L | | | | 2021-11-10 | 6 | | |
| Gross Alpha | | pCi/L | | 15 | (0) | | | 8.19 | 2.69 - 13.4 |
| Well 07 | SP 2503827-2 | pCi/L | | | | 2025-03-12 | 5.58 | | |
| WELL 07 | SP 1708964-1 | pCi/L | | | | 2017-07-26 | 2.69 | | |
| WELL 08 | SP 2216421-1 | pCi/L | | | | 2022-10-12 | 10.8 | | |
| Well 08 - PENDING | SP 2503827-3 | pCi/L | | | | 2025-03-12 | 11.1 | | |
| Well 09 | SP 2503827-1 | pCi/L | | | | 2025-03-12 | 13.4 | | |
| WELL 09 | SP 2203737-1 | pCi/L | | | | 2022-03-09 | 5.55 | | |
| Uranium | | pCi/L | | 20 | 0.43 | | | 4.699 | ND - 11.8 |
| Well 07 | SP 2503827-2 | pCi/L | | | | 2025-03-12 | 3.24 | | |
| WELL 07 | SP 1708964-1 | pCi/L | | | | 2017-07-26 | ND | | |
| Well 08 | SP 2518170-1 | pCi/L | | | | 2025-10-22 | 4.02 | | |
| WELL 08 | SP 2216421-1 | pCi/L | | | | 2022-10-12 | 4.18 | | |
| Well 08 - PENDING | SP 2503827-3 | pCi/L | | | | 2025-03-12 | 5.46 | | |
| Well 09 | SP 2503827-1 | pCi/L | | | | 2025-03-12 | 11.8 | | |
| WELL 09 | SP 2203737-1 | pCi/L | | | | 2022-03-09 | 4.19 | | |

| SECONDARY DRINKING WATER STANDARDS (SDWS) | | | | | | | | | |
|---|--------------|----------|------|--------|-----|------------|--------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Chloride | | mg/L | | 500 | n/a | | | 62 | 41 - 86 |
| Well 07 | SP 2414768-1 | mg/L | | | | 2024-09-11 | 47 | | |
| WELL 07 | SP 2112482-1 | mg/L | | | | 2021-09-08 | 41 | | |
| Well 08 | SP 2518170-1 | mg/L | | | | 2025-10-22 | 62 | | |
| WELL 08 | SP 2216421-1 | mg/L | | | | 2022-10-12 | 71 | | |
| Well 09 | SP 2418729-1 | mg/L | | | | 2024-11-13 | 67 | | |
| WELL 09 | SP 2116104-1 | mg/L | | | | 2021-11-10 | 86 | | |
| Iron | | ug/L | | 300 | n/a | | | 13 | ND - 40 |
| Well 07 | SP 2414768-1 | ug/L | | | | 2024-09-11 | ND | | |
| Well 08 | SP 2518170-1 | ug/L | | | | 2025-10-22 | ND | | |
| Well 09 | SP 2418729-1 | ug/L | | | | 2024-11-13 | 40 | | |
| Manganese | | ug/L | | 50 | n/a | | | 14.0 | ND - 40 |
| Well 07 | SP 2414768-1 | ug/L | | | | 2024-09-11 | 1.9 | | |
| WELL 07 | SP 2112482-1 | ug/L | | | | 2021-09-08 | ND | | |
| Well 08 | SP 2518170-1 | ug/L | | | | 2025-10-22 | 6.0 | | |
| WELL 08 | SP 2216421-1 | ug/L | | | | 2022-10-12 | 20 | | |
| Well 09 | SP 2418729-1 | ug/L | | | | 2024-11-13 | 10 | | |
| WELL 09 | SP 2400540-1 | ug/L | | | | 2024-01-10 | 40 | | |
| WELL 09 | SP 2400280-1 | ug/L | | | | 2024-01-05 | 20 | | |
| Specific Conductance | | umhos/cm | | 1600 | n/a | | | 596 | 539 - 721 |
| Well 07 | SP 2414768-1 | umhos/cm | | | | 2024-09-11 | 548 | | |
| WELL 07 | SP 2112482-1 | umhos/cm | | | | 2021-09-08 | 539 | | |
| Well 08 | SP 2518170-1 | umhos/cm | | | | 2025-10-22 | 577 | | |
| WELL 08 | SP 2216421-1 | umhos/cm | | | | 2022-10-12 | 604 | | |
| Well 09 | SP 2418729-1 | umhos/cm | | | | 2024-11-13 | 588 | | |

| | | | | | | | | | |
|-------------------------------|--------------|----------|--|------|-----|------------|------|------|-------------|
| WELL 09 | SP 2116104-1 | umhos/cm | | | | 2021-11-10 | 721 | | |
| Sulfate | | mg/L | | 500 | n/a | | | 34.7 | 31.0 - 37.2 |
| Well 07 | SP 2414768-1 | mg/L | | | | 2024-09-11 | 32.7 | | |
| WELL 07 | SP 2112482-1 | mg/L | | | | 2021-09-08 | 31.0 | | |
| Well 08 | SP 2518170-1 | mg/L | | | | 2025-10-22 | 35.9 | | |
| WELL 08 | SP 2216421-1 | mg/L | | | | 2022-10-12 | 34.2 | | |
| Well 09 | SP 2418729-1 | mg/L | | | | 2024-11-13 | 37.2 | | |
| WELL 09 | SP 2116104-1 | mg/L | | | | 2021-11-10 | 37.0 | | |
| Total Dissolved Solids | | mg/L | | 1000 | n/a | | | 355 | 330 - 390 |
| Well 07 | SP 2414768-1 | mg/L | | | | 2024-09-11 | 330 | | |
| WELL 07 | SP 2112482-1 | mg/L | | | | 2021-09-08 | 360 | | |
| Well 08 | SP 2518170-1 | mg/L | | | | 2025-10-22 | 360 | | |
| WELL 08 | SP 2216421-1 | mg/L | | | | 2022-10-12 | 340 | | |
| Well 09 | SP 2418729-1 | mg/L | | | | 2024-11-13 | 350 | | |
| WELL 09 | SP 2116104-1 | mg/L | | | | 2021-11-10 | 390 | | |
| Turbidity | | NTU | | 5 | n/a | | | 0.13 | ND - 0.30 |
| Well 07 | SP 2414768-1 | NTU | | | | 2024-09-11 | 0.15 | | |
| WELL 07 | SP 2112482-1 | NTU | | | | 2021-09-08 | ND | | |
| Well 08 | SP 2518170-1 | NTU | | | | 2025-10-22 | 0.15 | | |
| WELL 08 | SP 2216421-1 | NTU | | | | 2022-10-12 | 0.2 | | |
| Well 09 | SP 2418729-1 | NTU | | | | 2024-11-13 | 0.30 | | |
| WELL 09 | SP 2116104-1 | NTU | | | | 2021-11-10 | ND | | |

| UNREGULATED CONTAMINANTS | | | | | | | | | |
|--------------------------|--------------|-------|------|--------|-----|------------|--------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Boron | | mg/L | | NS | n/a | | | 1.0 | 0.2 - 2.3 |
| Well 07 | SP 2414768-1 | mg/L | | | | 2024-09-11 | 2.1 | | |
| WELL 07 | SP 2112482-1 | mg/L | | | | 2021-09-08 | 2.3 | | |
| Well 08 | SP 2518170-1 | mg/L | | | | 2025-10-22 | 0.5 | | |
| WELL 08 | SP 2216421-1 | mg/L | | | | 2022-10-12 | 0.4 | | |
| Well 09 | SP 2418729-1 | mg/L | | | | 2024-11-13 | 0.5 | | |
| WELL 09 | SP 2116104-1 | mg/L | | | | 2021-11-10 | 0.2 | | |
| Vanadium | | ug/L | | NS | n/a | | | 4 | 2 - 6 |
| Well 07 | SP 2414768-1 | ug/L | | | | 2024-09-11 | 2 | | |
| Well 08 | SP 2518170-1 | ug/L | | | | 2025-10-22 | 4 | | |
| Well 09 | SP 2418729-1 | ug/L | | | | 2024-11-13 | 6 | | |
| Manganese | | ug/L | | NS | n/a | | | 14.0 | ND - 40 |
| Well 07 | SP 2414768-1 | ug/L | | | | 2024-09-11 | 1.9 | | |
| WELL 07 | SP 2112482-1 | ug/L | | | | 2021-09-08 | ND | | |
| Well 08 | SP 2518170-1 | ug/L | | | | 2025-10-22 | 6.0 | | |
| WELL 08 | SP 2216421-1 | ug/L | | | | 2022-10-12 | 20 | | |
| Well 09 | SP 2418729-1 | ug/L | | | | 2024-11-13 | 10 | | |
| WELL 09 | SP 2400540-1 | ug/L | | | | 2024-01-10 | 40 | | |
| WELL 09 | SP 2400280-1 | ug/L | | | | 2024-01-05 | 20 | | |

| ADDITIONAL DETECTIONS | | | | | | | | | |
|-----------------------|--------------|-------|------|--------|-----|------------|--------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Calcium | | mg/L | | | n/a | | | 25 | 8 - 55 |
| Well 07 | SP 2414768-1 | mg/L | | | | 2024-09-11 | 10 | | |
| WELL 07 | SP 2112482-1 | mg/L | | | | 2021-09-08 | 8 | | |
| Well 08 | SP 2518170-1 | mg/L | | | | 2025-10-22 | 22 | | |
| WELL 08 | SP 2216421-1 | mg/L | | | | 2022-10-12 | 26 | | |
| Well 09 | SP 2418729-1 | mg/L | | | | 2024-11-13 | 27 | | |
| WELL 09 | SP 2116104-1 | mg/L | | | | 2021-11-10 | 55 | | |
| Magnesium | | mg/L | | | n/a | | | 8 | 3 - 16 |
| Well 07 | SP 2414768-1 | mg/L | | | | 2024-09-11 | 3 | | |
| WELL 07 | SP 2112482-1 | mg/L | | | | 2021-09-08 | 3 | | |
| Well 08 | SP 2518170-1 | mg/L | | | | 2025-10-22 | 7 | | |

North Trails Mutual Water Co.

CCR Login Linkage - 2025

| FGL Code | Lab ID | Date_Sampled | Method | Description | Property |
|-----------------|--------------|--------------|-----------------|------------------------|-----------------------------------|
| CA1907014_LCR | SP 2409544-5 | 2024-06-11 | Metals, Total | 11540 Durango Lane | NORTH TRAILS MUTUAL WATER COMPANY |
| | SP 2409544-3 | 2024-06-11 | Metals, Total | 11705 Laramie Wy. | NORTH TRAILS MUTUAL WATER COMPANY |
| | SP 2409544-1 | 2024-06-11 | Metals, Total | 11710 Chisholm Ct. | NORTH TRAILS MUTUAL WATER COMPANY |
| | SP 2409544-4 | 2024-06-11 | Metals, Total | 11720 Laramie Wy. | NORTH TRAILS MUTUAL WATER COMPANY |
| | SP 2409544-2 | 2024-06-11 | Metals, Total | 11735 Chisholm Ct. | NORTH TRAILS MUTUAL WATER COMPANY |
| 33361 Pewter Ro | SP 2511708-3 | 2025-07-11 | Coliform | 33361 Pewter Road | BacT Repeats 7-11-25 |
| 33423 Domino Hi | SP 2511708-4 | 2025-07-11 | Coliform | 33423 Domino Hill Road | BacT Repeats 7-11-25 |
| 33495 Overland | SP 2500330-1 | 2025-01-08 | Coliform | 33495 Overland Trail | Bacti Monitoring |
| | SP 2502467-1 | 2025-02-18 | Coliform | 33495 Overland Trail | Bacti Monitoring |
| | SP 2503829-1 | 2025-03-12 | Coliform | 33495 Overland Trail | Bacti Monitoring |
| | SP 2505592-1 | 2025-04-09 | Coliform | 33495 Overland Trail | Bacti Monitoring |
| | SP 2508024-1 | 2025-05-14 | Coliform | 33495 Overland Trail | Bacti Monitoring |
| | SP 2510003-1 | 2025-06-11 | Coliform | 33495 Overland Trail | Bacti Monitoring |
| | SP 2511580-1 | 2025-07-09 | Coliform | 33495 Overland Trail | Bacti Monitoring |
| | SP 2511708-1 | 2025-07-11 | Coliform | 33495 Overland Trail | BacT Repeats 7-11-25 |
| | SP 2511708-1 | 2025-07-11 | Field Test | 33495 Overland Trail | BacT Repeats 7-11-25 |
| | SP 2513802-1 | 2025-08-14 | Coliform | 33495 Overland Trail | Bacteriological Monitoring |
| | SP 2515370-1 | 2025-09-10 | Coliform | 33495 Overland Trail | Bacti Monitoring |
| | SP 2517147-1 | 2025-10-08 | Coliform | 33495 Overland Trail | Bacti Monitoring |
| | SP 2519367-1 | 2025-11-12 | Coliform | 33495 Overland Trail | Bacti Monitoring |
| | SP 2521184-1 | 2025-12-10 | Coliform | 33495 Overland Trail | Bacti Monitoring |
| NO3-ss02 | SP 2511708-2 | 2025-07-11 | Coliform | Water Tank | Monthly Nitrate Monitoring |
| WELL 07 | SP 1708964-1 | 2017-07-26 | Radio Chemistry | WELL 07 | NORTH TRAILS MUTUAL WATER CO |
| | SP 2112482-1 | 2021-09-08 | General Mineral | WELL 07 | Water Quality - Well 7 |
| | SP 2112482-1 | 2021-09-08 | Metals, Total | WELL 07 | Water Quality - Well 7 |
| | SP 2112482-1 | 2021-09-08 | Wet Chemistry | WELL 07 | Water Quality - Well 7 |
| | SP 2214746-1 | 2022-09-14 | | WELL 07 | Water Quality - Well 7 |
| | SP 2303417-1 | 2023-03-08 | Wet Chemistry | WELL 07 | Water Quality - Well 7 |
| | SP 2303417-1 | 2023-03-08 | Metals, Total | WELL 07 | Water Quality - Well 7 |
| | SP 2309981-1 | 2023-06-14 | Wet Chemistry | WELL 07 | Water Quality - Well 7 |
| | SP 2309981-1 | 2023-06-14 | Metals, Total | WELL 07 | Water Quality - Well 7 |
| | SP 2315544-1 | 2023-09-13 | Metals, Total | WELL 07 | Water Quality - Well 7 |
| | SP 2315544-1 | 2023-09-13 | Wet Chemistry | WELL 07 | Water Quality - Well 7 |
| | SP 2320480-1 | 2023-12-13 | Wet Chemistry | WELL 07 | Water Quality - Well 7 |
| | SP 2320480-1 | 2023-12-13 | Metals, Total | WELL 07 | Water Quality - Well 7 |
| | SP 2414768-1 | 2024-09-11 | Wet Chemistry | Well 07 | Water Quality - Well 7 |
| | SP 2414768-1 | 2024-09-11 | General Mineral | Well 07 | Water Quality - Well 7 |
| | SP 2414768-1 | 2024-09-11 | Metals, Total | Well 07 | Water Quality - Well 7 |
| | SP 2500328-1 | 2025-01-08 | Wet Chemistry | WELL 07 | Nitrate Monitoring |
| | SP 2503830-1 | 2025-03-12 | Wet Chemistry | Well 07 | Water Quality - Well 7 |
| | SP 2503830-1 | 2025-03-12 | Metals, Total | Well 07 | Water Quality - Well 7 |
| | SP 2503827-2 | 2025-03-12 | Radio Chemistry | Well 07 | Radio Monitoring |
| | SP 2503827-2 | 2025-03-12 | Metals, Total | Well 07 | Radio Monitoring |
| | SP 2505594-1 | 2025-04-09 | Wet Chemistry | WELL 07 | Nitrate Monitoring |
| | SP 2510004-1 | 2025-06-11 | Wet Chemistry | Well 07 | Water Quality - Well 7 |
| | SP 2510004-1 | 2025-06-11 | Metals, Total | Well 07 | Water Quality - Well 7 |
| | SP 2511581-1 | 2025-07-09 | Wet Chemistry | WELL 07 | NORTH TRAILS MUTUAL WATER CO |
| | SP 2515369-1 | 2025-09-10 | Metals, Total | Well 07 | Water Quality - Well 7 |
| | SP 2515369-1 | 2025-09-10 | Wet Chemistry | Well 07 | Water Quality - Well 7 |
| | SP 2518176-1 | 2025-10-22 | Wet Chemistry | WELL 07 | Nitrate Monitoring |
| | SP 2521185-1 | 2025-12-10 | Wet Chemistry | Well 07 | Water Quality - Well 7 |
| | SP 2521185-1 | 2025-12-10 | Metals, Total | Well 07 | Water Quality - Well 7 |

| | | | | | |
|-----------------|--------------|------------|-----------------|-------------------|------------------------------|
| WELL 08 | SP 1807934-1 | 2018-06-18 | | WELL 08 | Water Quality - Well 8 |
| | SP 2216421-1 | 2022-10-12 | Wet Chemistry | WELL 08 | Water Quality - Well 8 |
| | SP 2216421-1 | 2022-10-12 | Radio Chemistry | WELL 08 | Water Quality - Well 8 |
| | SP 2216421-1 | 2022-10-12 | | WELL 08 | Water Quality - Well 8 |
| | SP 2216421-1 | 2022-10-12 | General Mineral | WELL 08 | Water Quality - Well 8 |
| | SP 2216421-1 | 2022-10-12 | Metals, Total | WELL 08 | Water Quality - Well 8 |
| | SP 2500328-2 | 2025-01-08 | Wet Chemistry | WELL 08 | Nitrate Monitoring |
| WELL DISTRIBUTI | SP 2505594-2 | 2025-04-09 | Wet Chemistry | WELL 08 | Nitrate Monitoring |
| WELL 08 | SP 2511581-2 | 2025-07-09 | Wet Chemistry | WELL 08 | NORTH TRAILS MUTUAL WATER CO |
| | SP 2518170-1 | 2025-10-22 | General Mineral | Well 08 | Water Quality - Well 8 |
| | SP 2518170-1 | 2025-10-22 | Metals, Total | Well 08 | Water Quality - Well 8 |
| | SP 2518170-1 | 2025-10-22 | Wet Chemistry | Well 08 | Water Quality - Well 8 |
| | SP 2503827-3 | 2025-03-12 | Metals, Total | Well 08 - PENDING | Radio Monitoring |
| | SP 2503827-3 | 2025-03-12 | Radio Chemistry | Well 08 - PENDING | Radio Monitoring |
| WELL 09 | SP 2116104-1 | 2021-11-10 | General Mineral | WELL 09 | Water Quality - Well 9 |
| | SP 2116104-1 | 2021-11-10 | Metals, Total | WELL 09 | Water Quality - Well 9 |
| | SP 2116104-1 | 2021-11-10 | Wet Chemistry | WELL 09 | Water Quality - Well 9 |
| | SP 2203737-1 | 2022-03-09 | Metals, Total | WELL 09 | Radio Monitoring |
| | SP 2203737-1 | 2022-03-09 | Radio Chemistry | WELL 09 | Radio Monitoring |
| | SP 2400280-1 | 2024-01-05 | Metals, Total | WELL 09 | Manganese Well 09 |
| | SP 2400540-1 | 2024-01-10 | Metals, Total | WELL 09 | North Trails Mutual Water Co |
| | SP 2418729-1 | 2024-11-13 | Metals, Total | Well 09 | Water Quality - Well 9 |
| | SP 2418729-1 | 2024-11-13 | | Well 09 | Water Quality - Well 9 |
| | SP 2418729-1 | 2024-11-13 | Wet Chemistry | Well 09 | Water Quality - Well 9 |
| | SP 2418729-1 | 2024-11-13 | General Mineral | Well 09 | Water Quality - Well 9 |
| | SP 2500329-1 | 2025-01-08 | Wet Chemistry | Well 09 | Water Quality - Well 9 |
| | SP 2503827-1 | 2025-03-12 | Radio Chemistry | Well 09 | Radio Monitoring |
| | SP 2503827-1 | 2025-03-12 | Metals, Total | Well 09 | Radio Monitoring |
| | SP 2505593-1 | 2025-04-09 | Wet Chemistry | Well 09 | Water Quality - Well 9 |
| | SP 2511582-1 | 2025-07-09 | Wet Chemistry | Well 09 | Water Quality - Well 9 |
| | SP 2518181-1 | 2025-10-22 | Wet Chemistry | Well 09 | Water Quality - Well 9 |
| | SP 2518176-2 | 2025-10-22 | Wet Chemistry | WELL 09 | Nitrate Monitoring |