A young girl with long, dark hair and bangs is smiling and holding a clear glass of water. She is wearing a grey t-shirt. The background is white, and the right side of the image features a large, abstract graphic with overlapping blue and teal geometric shapes.

City of Alhambra 2019 Water Quality Report

A Message from Alhambra Utilities Department

Dear Customer:

This report summarizes the results of thousands of analyses conducted on your drinking water during 2019. At the City of Alhambra, a team of professionals work around the clock to make sure your tap water meets or exceeds all U.S. Environmental Protection Agency (USEPA) and State Water Resources Control Board - Department of Drinking Water (SWRCB-DDW) standards. We encourage landlords, business owners, and schools to share this report with "non-billed" water users. In addition, a paper copy of this report is also available at the Alhambra Public Library, Alhambra City Hall and Utilities Department Customer Service Center.

IMPORTANT FOR THE IMMUNO-COMPROMISED

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk with infections. These people should seek advice about drinking water from their health care providers. The USEPA/Center for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

NITRATE

Nitrate in drinking water at levels above 10mg/L is a health risk for infants of less than six months of age. Such nitrate level in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant woman and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

LEAD

Elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Alhambra is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or <http://www-w.epa.gov/lead>.

SOURCE WATER ASSESSMENT

The City of Alhambra Utilities Department has conducted Drinking Water Sources Assessments for its ground water sources. The latest assessment was completed in April 2009. Sources are considered most vulnerable to the following activities associated with contaminants detected in the water supply: auto repair shops, sewer collection systems, dry cleaners, irrigated crops, leaking underground storage tanks, high density housing and historic dump and landfill sites. A summary of the assessment can be obtained by contacting Michael Thai, Environmental Compliance Specialist, at (626) 570-3259.

ALHAMBRA WATER SUPPLY INFORMATION

The City of Alhambra maintains approximately 18,300 service connections and provides approximately 83,000 customers with quality drinking water that meets or surpasses all State and Federal drinking water standards. The City's main source of water (70%) comes from local groundwater from Main San Gabriel Water Basin. An additional source of water (30%) comes from a service connection with the Metropolitan Water District (MWD). The MWD water is surface water from Colorado River and State Water Project which is treated at the Weymouth Treatment Plant within the City of La Verne and transported via transmission main to the City of Alhambra.

COMPREHENSIVE WATER QUALITY MONITORING

Alhambra Utilities Department works diligently to ensure that your water complies with all state and federal drinking water standards. This is a comprehensive effort that includes monitoring and testing for many types of contaminants that may be present in source water (i.e., water before treatment), including:

- Microbials, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganics, such as salts and metals, that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemicals, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, or that may come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

Primary Drinking Water Standards set limits for substances in water that may be harmful to humans if consumed in excess. They include MCLs and MRDLs for contaminants that affect health along with their monitoring, reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards deal with aesthetic qualities such as taste and odor which relate to consumer acceptance rather than health factors.

DEFINITIONS

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

ABBREVIATIONS

CaCO₃: Calcium Carbonate

mg/L: Milligrams per liter (which is equal to parts per million).

µg/L: Micrograms per liter (which is equal to parts per billion).

ppm: Parts per million (which is equal to milligrams per liter).

ppb: Parts per billion (which is equal to micrograms per liter).

µmhos/cm: Micromhos/centimeter.

pCi/L= Pico Curies per Liter.

NTU: Nephelometric turbidity units.

ND: The substance could not be found at the minimum amount that can be detected.

NR: Not Required (no laboratory testing is required)

NA: Not Applicable.

NL: Notification Level (if the contaminant is detected at this level, then certain requirements and recommendations apply).

MWD: Metropolitan Water District

NA: Not Applicable.

City of Alhambra 2019 - Water Quality Table

CONSTITUENT AND (UNIT)	PHG (MCLG) or [MRDLG]	MCL or [MRDL]	DLR	Groundwater City of Alhambra Wells		Surface Water MWD - Weymouth Plant		Typical Source of Contaminants
				Range	Average	Range	Average	
PRIMARY STANDARDS- MANDATORY HEALTH-RELATED STANDARDS								
CLARITY (COMBINED FILTER EFFLUENT TURBIDITY) (A)								
Highest single measurement of the treated surface water (NTU)	N/A	TT	N/A	NR	NR	Highest	0.04	Soil runoff
Lowest percent of all monthly readings less than 0.3 NTU (%)	N/A	TT	N/A	NR	NR	% ≤ 0.3	100%	Soil runoff
MICROBIOLOGICAL CONTAMINANTS								
Total Coliform Bacteria (% positive in a month) (B)	(0)	5%	N/A	-	1%	-	0.2%	Naturally present in the environment
Fecal Coliform or E. coli (% positive in a month)	(0)	0%	N/A	-	0%	-	0%	Human and animal fecal waste
DISINFECTION BY-PRODUCTS AND DISINFECTION RESIDUALS (C)								
Total Trihalomethanes [TTHM], ppb	N/A	80	1	13 - 37	29.3	9.7 - 30	17	By-product of drinking water disinfection.
Haloacetic Acids [HAA5], (ppb)	N/A	60	1	1.1 - 14	9.4	ND - 6.7	2.8	By-product of drinking water disinfection.
Chlorine Residual, (ppm)	4	4	N/A	ND - 3.8	1.5	0.5 - 2.9	2.4	Drinking water disinfectant added for treatment.
ORGANIC CHEMICALS								
Trichloroethylene [TCE], (ppb)	1.7	5	0.5	ND - 2.4	0.7	ND	ND	Discharge from metal degreasing sites and other factories
Tetrachloroethylene (PCE), (ppb)	0.06	5	0.5	ND - 1.1	<0.5	ND	ND	Discharge from factories, dry cleaners, and auto shops (metal degreaser)
INORGANIC CHEMICALS								
Aluminum, (ppb) (D)	600	1000	50	ND	<50	ND-100	122	Erosion of natural deposits
Fluoride, (ppm)	1	2	0.1	0.43 - 0.87	0.60	0.60 - 0.90	0.70	Erosion of natural deposits; Water additive that promotes strong teeth
Nitrate [as Nitrogen-N], (ppm)	10	10	0.4	1.9 - 7.8	4.3	0.4	0.4	Runoff and leaching from fertilizer use
RADIOLOGICALS (E)								
Gross Alpha Activity, (pCi/L)	0	15	3	ND - 7.4	<3	ND	ND	Erosion of natural deposits
Uranium, (pCi/L)	0.43	20	1	1.1 - 7.9	3.8	ND	ND	Erosion of natural deposits
SECONDARY STANDARDS, AESTHETIC NON HEALTH-RELATED STANDARDS								
Aluminum, (ppb) (D)	600	200	50	ND	<50	ND-110	122	Erosion of natural deposits
Turbidity, (NTU)	N/A	5	0.1	ND - 1.8	0.22	ND	ND	Solution of finely divided subsurface clay and silt
Color, (Units)	N/A	15	N/A	ND	ND	ND - 1	ND	Naturally-occurring materials
Odor-Threshold Odor Number (TON)	N/A	3	1	1	1	1	1	Naturally-occurring organic materials
Chloride, (ppm)	N/A	500	N/A	16 - 60	34	46-55	50	Runoff / leaching from natural deposits
Iron, (ppb)	N/A	300	100	ND - 190	<100	243	243	Corrosion; leaching from natural deposits; industrial wastes.
Sulfate, (ppm)	N/A	500	0.5	25 - 92	51	65 - 81	73	Runoff / leaching from natural deposits; industrial wastes
Specific Conductance, (µS/cm)	N/A	1600	N/A	380 - 800	569	435 - 503	469	Substances that form ions, when in water
Total Dissolved Solids [TDS], (ppm)	N/A	1000	N/A	220 - 510	359	244 - 289	266	Runoff and leaching from natural deposits
UNREGULATED CONSTITUENTS REQUIRING MONITORING AT ENTRY POINTS INTO THE DISTRIBUTION SYSTEM								
Boron, (ppb)	N/A	NL= 1000	100	NR	NR	120	120	Runoff / leaching from natural deposits; industrial wastes
Chlorate, (ppb)	N/A	NL= 800	20	ND - 300	140	42	42	By-product of drinking water chlorination; industrial processes
Chromium Hexavalent, (ppb)	0.02	N/A	N/A	3.1 - 8.3	5.9	ND	ND	Industrial discharge or erosion of natural deposits
Perfluorohexanoic Acid, [PFHxA] (ppt)	N/A	N/A	2	NR	NR	2.5 - 2.6	2.5	Industrial chemical factory discharges, runoff from landfills; used in fire-retarding
1,4-Dioxane, (ppb)	N/A	NL= 1	N/A	ND	ND	NR	NR	Industrial waste discharge
Manganese (ppb)	N/A	SMCL = 50	20	ND - 1.8	1.0	ND	ND	Leaching from natural deposits
Molybdenum, Total (ppb)	N/A	N/A	N/A	2.5 - 9.2	5.0	NR	NR	Runoff / leaching from natural deposits
Strontium, Total (ppb)	N/A	N/A	2	230 - 1100	610	ND	ND	Runoff / leaching from natural deposits
Vanadium, Total (ppb)	N/A	NL= 50	N/A	ND - 9.8	5.0	ND	ND	Runoff / leaching from natural deposits
UNREGULATED CONSTITUENTS REQUIRING MONITORING IN THE DISTRIBUTION SYSTEM								
Haloacetic Acids - HAA5 (ppb)	N/A	N/A	N/A	3.6 - 9.0	6.1	NR	NR	Byproduct of drinking water disinfection
Haloacetic Acids - HAA6Br (ppb)	N/A	N/A	N/A	4.4 - 11.6	6.9	NR	NR	Byproduct of drinking water disinfection
Haloacetic Acids - HAA9 (ppb)	N/A	N/A	N/A	6.5 - 15.3	10.8	NR	NR	Byproduct of drinking water disinfection
WATER CHARACTERISTICS: NO MCL OR MRDL, BUT STATE OR FEDERAL MONITORING IS REQUIRED								
Calcium, (ppm)	N/A	N/A	0.1	30.1 - 85.2	57.5	23 - 27	25	Runoff / leaching from natural deposits
Magnesium, (ppm)	N/A	N/A	0.01	ND - 22.7	2.5	11 - 12	12	Runoff / leaching from natural deposits
pH, (Units)	N/A	N/A	N/A	7.0 - 7.9	7.6	8.5	8.5	N/A
Potassium, (ppm)	N/A	N/A	0.2	1.2 - 3.0	2.0	2.2 - 2.7	2.4	Salt present in the water, naturally-occurring
Sodium, (ppm)	N/A	N/A	1	25 - 50	36	46 - 54	50	Salt present in the water, naturally-occurring
Total Alkalinity [as CaCO3], (ppm)	N/A	N/A	1	140 - 250	171	67 - 70	68	Runoff / leaching from natural deposits; carbonate, bicarbonate and hydroxide
Total Hardness [as CaCO3], (ppm)	N/A	N/A	1	104 - 270	210	101 - 116	108	Runoff / leaching from natural deposits, sun of polyvalent cations, magnesium and calcium
Total Organic Carbon [TOC], (ppm)	N/A	TT	0.3	N/A	N/A	1.7 - 2.6	2.4	Various natural and man-made sources; precursor for formation of disinfection byproducts
LEAD AND COPPER TESTING AT RESIDENTIAL TAPS								
LEAD/COPPER	PHG	Action Level (AL)	90th Percentile Result				Typical Source of contaminants	
Lead, (ppb) (F)	0.2	15	1.4				Corrosion of household plumbing system	
Copper, (ppm) (F)	0.3	1.3	0.50				Corrosion of household plumbing system	

Footnotes:

- (A) Turbidity is a measure of the cloudiness of the water and is a good indicator of the effectiveness of surface water filtration. To meet the Primary Standard, the turbidity level of the filtered water shall be less than or equal to 0.3 NTU in 95% of the measurements taken each month, and shall not exceed 1 NTU for any single measurement. High turbidity level can hinder the effectiveness of disinfectants.
- (B) The result is the highest percentage of positive samples collected in a month during 2019. Coliforms are bacteria used as an indicator that if present, other potentially harmful organisms may be present. According to the State Water Resources Control Board, Division of Drinking Water (DDW), no more than 5.0% of the monthly samples may be Total Coliform-positive. Total Coliforms were detected in one sample collected in the distribution system in May 2019. However, all follow-up confirmation samples were negative for Total Coliforms and Fecal/E. Coli bacteria. A routine sample and a repeat sample that are Total Coliform positive and where one of these is also Fecal/E. Coli positive constitutes an MCL violation. Therefore, the MCL was not violated in 2019.
- (C) The distribution system is tested quarterly for disinfection byproducts. The "Average" result is the highest locational running annual averages (LRAA) of the four quarters for TTHM and HAA5 in 2019. The Twenty-three (23) locations are tested weekly for chlorine residual. The "Average" result is the highest monthly average for chlorine residual in 2019. "Range" is the maximum and minimum of the individual results.
- (D) Aluminum has both Primary (health-related) and Secondary (aesthetic) Standards.
- (E) Not all sources were sampled for radioactivity in 2019; sources were sampled between 2011-2019. The most recent results are included.
- (F) The most recent monitoring of Lead and Copper at thirty (30) residences was completed in 2018. None exceed the action level for lead and copper. The next round of monitoring is scheduled for 2021. In 2019, one (1) school submitted request to be sampled for lead.

Water Conservation

Water conservation remains the most responsible way to reduce our demand for water and conserve our water supply. Water supply is greatly affected by regional drought, growth in population, and climate change. The need to conserve water is critical, as we all play a role in water usage. However, there are many effective ways we can help save water in and around our home. With these simple changes in our daily routines, we can reduce our water footprint and protect this valuable resource for future generations. The City of Alhambra is currently under Water Shortage Plan I Voluntary Conservation, Chapter 15.25.080 of the Alhambra Municipal Code. For more information please visit: <http://www.cityofalhambra.org/resources/mandatory-water-restrictions>.



Saving Water Indoors

- Regularly check and repair water leaks around the home.
- Install water efficient showerheads, toilets, and faucet aerators.
- Wash only full loads, whether using the dishwasher or laundry machine.
- Turn off the faucet while brushing your teeth or shaving.
- Recycle indoor water to use on plants.

Saving Water Outdoors

- Water the lawn in the early morning or evening to maximize the amount of water reaching the plant roots, while minimizing evaporation.
- Adjust sprinklers so only the lawn is watered and not the house or sidewalk.
- Collect rainfall for irrigation using a rain barrel or other screened containers.
- Apply mulch around trees and plants to preserve soil moisture.
- Add a shut-off nozzle to your garden hose.

Reduce Your Water Bill – Rebates with San Gabriel Valley Municipal Water District

As a resident of Alhambra, the San Gabriel Valley Municipal Water District offers financial incentives to help you purchase water-saving appliances and fixtures. Not only will you be able to reduce your water bill, but you will also be conserving more water to reduce demand to our water supply. The following available rebates include:

- Up to \$35 per rain barrel or \$350 per cistern
- Up to \$85 for a water efficient washing machine
- Up to \$80 for weather based irrigation controller or soil moisture sensor system
- Up to \$40 for high-efficiency toilet
- Up to \$2 per nozzle (minimum 30) for rotating sprinkler nozzles

For more information, please call (855) 512-1221 or visit www.sgvnwd.org

Rain Barrels

Utilizing rain barrels is a great way to reduce storm-water runoff and to conserve more water for outdoor water usage. The City of Alhambra hosts rainwater harvesting classes to help teach the community about the importance of rainwater harvesting and the many benefits of a rain barrel. Each service address is eligible for up to four (4) rain barrels for \$35 per rain barrel with the San Gabriel Valley Municipal Water District.

For more information, please call (626) 300-1543.



State-Required Treatment Processes to Remove Viruses, Including COVID-19

The City of Alhambra's comprehensive and safe drinking water standards require a multi-step treatment process that includes disinfection. This process removes and kills viruses, including coronaviruses such as COVID-19, as well as bacteria and other pathogens.

The State Water Board's Division of Drinking Water establishes and enforces drinking water standards that ensure the delivery of safe and potable water. Treatment facilities must comply with stringent

performance measures to ensure treatment processes are continuously operating at peak performance.


The treatment process must destroy at least 99.99% of viruses. The limited number that possibly might pass through are quickly inactivated in the disinfection process. COVID-19 is transmitted person to person, not through drinking water, according to the Centers for Disease Control and Prevention. All public water systems in California are routinely monitored for bacteria to ensure that water delivered to customers is free of pathogens. The City of Alhambra works closely with the State Water Board to ensure the safety of water that flows through the city to our customers.

Safe Clean Water Program

The Safe Clean Water Program creates a comprehensive, regional plan to address how we capture rainwater and reduce reliance on imported water. Cities will receive funding for the program through revenue generated from Measure W; the parcel tax approved by Los Angeles County voters in November 2018. As the City of Alhambra begins to implement the Safe Clean Water Program, some goals of the plan include:

- Capture millions of gallons of water that could be recycled for irrigation and used to increase water supply.
- Help protect coastal waters and marine life from potential contaminants in stormwater runoff.
- Prepare the City for the effects of possible climate change, such as earthquakes, wildfires, and floods.
- Help protect public health by improving water quality and ensuring a healthier and greener living environment.

For more information please visit www.safecleanwaterla.org



111 South First Street
Alhambra, CA 91801



THIS NOTICE CONTAINS IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER.

City of Alhambra 2019 Water Quality Report will be available online on July 1, 2020. Please visit the following URL: <http://www.CityofAlhambra.org/resources/utility-department-reports> to learn more about your drinking water. If you would like a paper copy of the 2019 CCR mailed to your mailing address or would like to speak with someone about the report, please call (626) 570-3259.

Este informe contiene información muy importante sobre su agua potable. Favor de comunicarse con la Ciudad de Alhambra el Departamento de Utilidades a (626) 570-3259 para asistirlo en español.

本報告包含閣下飲用水嘅重要訊息。如需廣東話垂詢, 請聯絡
City of Alhambra, Utilities Department (626) 570-3259

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ
City of Alhambra, Utilities Department tại (626) 570-3259 để được trợ giúp bằng tiếng Việt.

Community Participation, regularly scheduled City Council meeting are held on the second and fourth Monday of each month, at 7:00pm at City Hall, located at 111 South First Street, Alhambra, California and are open to the public participation in decisions that may affect the quality of your water. A City Council agenda is available from the office of the City Clerk or via the website <http://www.cityofalhambra.org>. We welcome your participation in the meetings.

Water Quality Questions: (626) 570-3259

Stormwater Pollution Question: (626) 570-5036

Fats, Oils, and Grease (FOG) Question: (626) 570-5067

Utilities Customer Service Center: (626) 570-5061

Billing question, trash services, or any question regarding water or sewer service.

Water Service Emergencies: (626) 570-5124

(Dispatch) Leaks, 24 hours turn off / turn on service.

Illegal Dumping to Storm Drains or Someone Wasting Water? (626) 570-5061 or email us at waterwatcher@cityofalhambra.org

