


Certification Form
(to be submitted with a copy of the CCR)

(To certify electronic delivery of the CCR, use the certification form on the State Water Board's website at

http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	Southern CA Edison Santa Catalina System
Water System Number:	CA1910006

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/27/2024 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by:	Name:	Danny Lu	
	Signature:		
	Title:	Regulatory and Compliance Advisor	
	Phone Number:	(714) 222-0070	Date: 9/3/2024

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: _____

☐ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

- ☒ Posting the CCR on the Internet at www.sce.com/sites/default/files/custom-files/PDF_Files/2023_Catalina%20Water%20System%20CCR%201.pdf _____
- ☒ Mailing the CCR to postal patrons within the service area (attach zip codes used)
- ☐ Advertising the availability of the CCR in news media (attach copy of press release)
- ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
- ☐ Posted the CCR in public places (attach a list of locations)

- ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- ☐ Delivery to community organizations (attach a list of organizations)
- ☐ Other (attach a list of other methods used)
- ☐ *For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following address: www._____
- ☒ *For investor-owned utilities:* Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience for use to meet the certification requirement of the California Code of Regulations, section 64483(c).

Zip Code Used

90704

Important Information Regarding Your Drinking Water:

What happened?

1. Secondary water standards are based on aesthetics factors, such as taste, odor, and color, and are not considered to present a risk to human health. During 2023 specific conductance, iron, and total dissolved solids (secondary water standards) were measured in the upper ranges of the "consumer acceptance contaminant level ranges" also known as secondary maximum contaminant level (SMCL) at Howland's Landing Well 03R.
 - Howland's Landing Well 03R is a bedrock well with high mineral content, which may elevate levels of specific conductance, iron, and total dissolved solids during times of low water usage and drought. Iron is treated at Howlands Landing Well 3R, and is below the SMCL. SCE routinely monitors specific conductance at Howland's Landing Well 03R to ensure proper actions are taken when levels are elevated above acceptable ranges.
2. State Notification levels (NL) are non-regulatory health-based advisory levels established by State Water Resource Control Board for chemicals for which maximum contaminant levels (MCL) have not been established. In 2023 boron was detected above the NL at Quarry Seawater Well 1, Quarry Seawater Well 2 and Treated Water Tank 2.
 - Boron is a naturally occurring element found in rocks, soil and water. SCE will closely monitor boron level by increasing sampling frequency to ensure proper actions are taken if levels continue to increase.
3. Catalina Island's drinking water is tested routinely to ensure public health. The most recent water quality testing results comply with State and Federal drinking water standards. Although this is not an emergency, you have a right to know that we did not fully monitor or properly report some sampling events between 2016 and 2023 to the State Water Board. A Public Notice has been distributed with further details. SCE personnel are working with the State to resolve these issues and additional internal controls are being implemented to ensure compliance.

What should I do?

You do not need to boil your water or take other corrective actions. You do not need to use an alternate (e.g., bottled) water supply. If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Si habla Español: Este documento contiene información muy importante sobre su agua potable. Tradúzcalo ó converse con alguien que lo entienda bien.

2023 Consumer Confidence Report

Southern California Edison Santa Catalina Island Water System



[Background](#)

Southern California Edison Company (SCE) is providing you with this Consumer Confidence Report for our operations on Catalina Island. This report is required annually for drinking water systems by the State Water Resources Control Board (State Water Board) Division of Drinking Water (DDW). This report was developed to provide you details about where your drinking water comes from, what it contains, and how it compares to California water quality standards.

SCE is responsible for providing a safe and reliable supply of drinking water and performs more than 8,000 tests for over 360 drinking water contaminants each year. SCE continued testing for regulated and non-regulated contaminants in 2023, with some pollutants being monitored every three and nine years as prescribed by the State.

The tests conducted during 2023 indicate that the drinking water provided to you meets all regulatory requirements with exception of those mentioned in the "What happened" section.

If you have any questions about this report, want to discuss the quality of your water, or are looking for public participation opportunities, please contact John Martin, SCE Catalina Production Manager at (310) 510-4372. We are committed to providing you information and welcome your comments.

Water Supply Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive materials, and pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- (1) Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (2) Inorganic contaminants, such as salts and metal, that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (3) Pesticides and herbicides that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- (4) Organic chemical contaminants, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- (5) Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink U.S. Protection Environmental Agency (U.S. EPA) and the State Water Resources Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottle water that provide the same protection for public health.

The groundwater system primarily consist of wells located in Middle Ranch. As part of our continued management of the drinking water system, an assessment of the drinking water sources for the Catalina Island Water System was updated in December 2019. The source water assessment indicates that fresh groundwater sources are considered most vulnerable to the following influences: grazing animals; weathering effects on facilities; and drought. The seawater well watershed contains few contaminant sources and most will not significantly affect the quality of ocean water pumped.

Copies of the assessments are available at SWRCB DDW, Central District Office, 500 North Central Avenue, Suite 500, Glendale, CA 91203 or Southern California Edison, Catalina Water System, #1 Peppy Beach Road, Avalon, CA 90704.

You may request a copy from the DDW District Engineer at (818) 551-2004 or the SCE local office at (310) 510-4312.

Information on Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing systems. SCE is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at (800) 426-4791 or at: <http://www.epa.gov/lead>.

References

- ¹ The State allows SCE to monitor for some contaminants **every three years** because the concentrations of these contaminants do not change frequently. In cases where no samples were required in 2023, the most recent results have been included.
- ² As of 2015, compliance is determined on a locational running annual average (LRAA). Range listed shows the max and min of all monitoring locations and the average value listed represents the highest determined LRAA. Some people who drink water containing TTHMS in excess of the MCL over many years may experience liver, kidney, or central nervous system problems, and may have an increased risk of getting cancer.
- ³ There are no PHG, MCLG, or mandatory standard health effects language for the constituents because secondary MCLs are set on the basis of aesthetics.
- ⁴ The notification level for manganese is used to protect consumers from neurobiological effects. High levels of manganese in people have been shown to result in effects of the nervous system.
- ⁵ Iron and Manganese are treated for at Howland's Landing Well 3R, reported results are post-treatment.
- ⁶ Turbidity is a measure of the cloudiness of the water. It is being monitored because it is a good indicator of the effectiveness of the filtration system.
- ⁷ Unregulated contaminant monitoring helps U.S. EPA and the State Water Resources Control Board to determine where certain contaminants occurs and whether the contaminants need to be regulated.
- ⁸ The State allows us to monitor for some contaminants **every nine years** because the concentrations of these contaminants do not change frequently. The most recent full set of radiological samples were collected in 2020 with the exception of Sweetwater Canyon Well 01 which was sampled for Uranium and Radium 226/228 in 2018.
- ⁹ Lead and Copper Rule (LCR) samples are currently taken from 26 residences every three years. The most recent September 2023 sampling event was within the 90% and **was in compliance with LCR requirements**. Results are displayed in the Lead and Copper Data table.
- ¹⁰ The Max Level of Detected is above the maximum "Range of Detection" because of the fourth quarter result from 2023.
- ¹¹ The Notification Level (NL) for Boron = 1000 ppb or 1 ppm
- * Value exceeds MCL

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the USEPA.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standard (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements and water treatment requirements.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Secondary Maximum Contaminant Level (SMCL): The level for contaminants that is based on aesthetics and are not considered to present a risk to human health at the SMCL.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

cfu/ml – colony forming units per milliliter

ppb - parts per billion or micrograms per liter

N/A - not applicable

ppm - parts per million or milligrams per liter

ND - not detectable at testing limit

ppt- parts per trillion or nanograms per liter

NTU – Nephelometric Turbidity Unit

µS/cm – micro Siemens per centimeter

pCi/L – picocuries per liter

Unregulated contaminant monitoring helps the US Environmental Protection Agency (USEPA) and the SWRCB

Total Coliform Bacteria					
MCL / [MRDL]		Months in Violation		Total Positive	
For A Water System Collecting Fewer Than 40 Samples per Month: One Positive monthly sample is Allowed		0 - Detection = Positive sample with positive repeat sample.		4 Total Positive for the year	
Resampled Locations / Result		Max # Detects (in one month)		Repeat Samples	
4 Resampled / Absent		0 - with positive repeat sample		4/06/23, 8/17/23,10/19/23 & 11/07/23	
Source of Contamination					
Naturally present in the environment: Used as indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system.					
Lead and Copper Data ¹					
Contaminant	Date	90 th Percentile	Sites Exceeding AL / No. of Samples	AL	PHG
		Level Detected			
Lead (ppb)	Sept' 23	1.5	1	15	0.2
Source of Contamination: Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits					
Copper (ppm)	Sept' 23	0.21	0	1.3	0.3
Source of Contamination: Corrosion of plumbing systems; erosion of natural deposits; leaching of wood preservatives					

Be Water Wise!

SCE is requesting residents to practice water conservation measures due to the finite amount of water on Catalina Island and the arid state of the land. Do not leave water running when washing dishes or brushing your teeth, install a low-flow showerhead or faucet aerators, and fix leaky faucets and pipes. SCE provides low-flow showerheads and garden hose nozzles at no charge. Please visit SCE at #1 Pebbly Beach Road, Avalon, CA 90704 to obtain these items.



EPA Resources

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at (800) 426-4791 or by visiting www.epa.gov/ccr.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections.

These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

SCE Monitoring

SCE is required to test for a number of different contaminants in the Catalina Island Water System, with the timing of the sampling varying based on the state's requirements. In order to ensure that drinking water is safe to drink, USEPA and the State Water Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. California Department of Public Health regulations also establish limits for contaminants in bottled water that must provide the same level of protection for public health.

This Consumer Confidence Report (CCR) reflect changes in the drinking water regulatory requirements of the Federal Revised Total Coliforms Rules, effective since April 1st, 2016, to the existing state Total Coliform Rule. The revised rule ensure the integrity of the drinking water distribution system against the presence of microbials (i.e., total coliform and E. coli bacteria) anticipating better public health protection through identification and problem-solving. The state Revised Total Coliform Rule become effective July 1st, 2021.

Drinking water contaminants detected during tests in 2023 are listed in the table within this brochure as well as an explanation of terms and abbreviations. The presence of the listed contaminants in water does not necessarily mean that the water poses a health risk and that all contaminants detected are below regulatory levels established by State Water Board.

Sincerely,

John Martin, SCE Catalina Production Manager

2023 Santa Catalina Island Drinking Water Quality						
Contaminant	Sample Date	Average of Levels De- tected	Range of Detections	MCL [MRDL]	PHG / (MCLG) [MRDLG]	Typical Source of Contaminant/Additional Information
Contaminants with a Primary Drinking Water Standard						
Arsenic, Total (ppb) ¹	4/4/2023-12/29/2023	2.0	0.61 - 6.9	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium, Total (ppm) ¹	12/20/2023 -12/29/2023	0.13	0.054 – 0.26	1	2	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Chlorine, Total Residual (ppm)	1/4/2023-12/28/2023	1.3	0.20 - 69*	[4]	[4]	Drinking water disinfectant added for treatment
Fluoride (ppm) ¹	12/20/2023 -12/29/2023	0.30	0.24 – 0.39	2	1	Erosion of natural deposits; discharge from fertilizer and aluminum factories
Nitrate as N (ppm)	12/20/2023 -12/29/2023	0.30	0.24 - 0.40	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate and Nitrite as N (ppm) ¹	11/18/20 – 12/15/20	0.58	0.27 – 1.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Total Organic Carbon (TOC) (ppm)	2/22/2023 -12/19/2023	0.44	0.32 - 1.0	TT	N/A	Various natural and man-made sources
Heterotrophic Plate Count (cfu/ml)	1/4/2023 -12/28/2023	130	2.0 - 740	TT	N/A	Naturally present in the environment. Inadequately treated water may contain disease-causing organisms. (All SCE water has chlorine residual so testing for HPC is not required.)
Total Trihalomethanes (TTHMs) (ppb) ²	1/25/2022 - 12/21/2023	59 ¹⁰	31 - 96*	80	N/A	Byproduct of drinking water disinfection. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience liver, kidney, or central nervous system problems, and may have an increased risk of getting cancer.
Haloacetic Acids (HAA5) (ppb) ²	2/28/2022 -11/28/2023	32	4.8 - 35	60	N/A	Byproduct of drinking water disinfection
Contaminants with a Secondary Drinking Water Standard ³						
Chloride, Total (ppm)	2/22/2023 - 12/29/2023	270	77 - 440	500	N/A	Runoff/leaching from natural deposits; seawater influence
Copper, Total (ppm)	12/20/2023 - 12/29/2023	0.003	0.0010 - 0.0044	1	N/A	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Iron (ppb) ⁵	2/22/2023 - 12/29/2023	888*	210 – 1500*	300	N/A	Leaching from natural deposits; industrial wastes
Manganese (ppb) ^{4,5}	2/22/2023 - 12/29/2023	19	1.2 - 46	50	N/A	Leaching from natural deposits
Specific Conductance (µS/cm)	2/22/2023 - 12/29/2023	1500	760 - 1900*	1,600	N/A	Form ions when in water; seawater influence.
Sulfate as SO4 (ppm)	12/20/2023 - 12/29/2023	52	26 - 70	500	N/A	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	2/22/2023 - 12/29/2023	850	420 - 1100*	1,000	N/A	Runoff/leaching from natural deposits
Turbidity (NTU) ⁶	1/4/2023 - 12/29/2023	0.76	0.10 - 10*	5	N/A	Microbiological Contaminant: Soil runoff. Turbidity is a measure of water cloudiness; a good indicator of water quality. High turbidity can hinder disinfection.
Zinc (ppm) ¹	12/20/2023 - 12/29/2023	0.011	ND - 0.011	5	N/A	Runoff/leaching from natural deposits; industrial wastes
Unregulated Contaminants, State Regulated, & Assessment Monitoring ⁷						
Alkalinity as CaCO ₃ (ppm) ¹	12/20/2023 - 12/29/2023	320	230 – 440	N/A	N/A	Erosion of natural deposits
Bicarbonate Alkalinity as HCO ₃ (ppm) ¹	12/20/2023 - 12/29/2023	390	280 - 540	N/A	N/A	Erosion of natural deposits
Boron (ppm) ¹¹	2/22/2023-12/29/2023	0.97	0.098 - 4.8	N/A	N/A	Erosion of natural deposits
Bromodichloromethane (ppb)	2/22/2023 - 12/29/2023	2.3	0.86 - 6.7	N/A	0.06	Disinfection Byproducts
Bromoform (ppb)	2/22/2023 - 12/29/2023	29	1.6 - 73	N/A	0.5	Disinfection Byproducts
Calcium (ppm) ¹	12/20/2023 - 12/29/2023	70	59 - 103	N/A	N/A	Erosion of natural deposits
Chloroform (ppb)	12/20/2023 - 12/29/2023	1.2	0.51 - 3.0	N/A	0.4	Disinfection Byproducts
Dibromoacetic Acid (ppb)	2/22/2023 - 11/28/2023	24	4.8 - 35	N/A	N/A	Disinfection Byproducts
Dibromochloromethane (ppb)	2/22/2023 - 12/29/2023	12	1.1 - 31	N/A	0.1	Disinfection Byproducts
Dichloroacetic Acid (ppb)	2/22/2023 - 12/21/2023	2.4	1.0 - 3.7	N/A	N/A	Disinfection Byproducts
Hardness (ppm) ¹	12/20/2023 - 12/29/2023	370	250 - 510	N/A	N/A	Naturally occurring cations (characteristically magnesium and calcium)
Hexavalent Chromium (ppb)	12/20/2023 - 12/29/2023	0.25	0.022 - 0.48	N/A	0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis and textile manufacturing facilities; erosion of natural deposits
Magnesium (ppm) ¹	12/20/2023 - 12/29/2023	47	26 - 69	N/A	N/A	Erosion of natural deposits
Monobromoacetic Acid (ppb)	2/22/2023 - 12/21/2023	2.7	1.0 - 3.5	N/A	N/A	Disinfection Byproducts
pH (pH units) ¹	12/20/2023 - 12/29/2023	7.3	7.2– 7.5	6.5 – 8.5	N/A	Not Applicable
Sodium (ppm) ¹	12/20/2023 - 12/29/2023	86	56 - 120	N/A	N/A	Refers to the salt present in the water and is generally naturally occurring
Radiological Data ⁸						
Gross Alpha (pCi/L)	11/18,12/12, 12/13,12/14, & 12/15/2020 ; 12/13/2022.	4.2	1.8 - 9.1	15	N/A	Decay of natural and man-made deposits
Combined Radium 228/226 (pCi/L)	11/18,12/12, 12/13,12/14, & 12/15/2020; 12/13/22	0.26	0.26 - 1.1	5	--	Erosion of natural deposits
Uranium (pCi/L)	11/18,12/12, 12/13,12/14, & 12/15/2020; 12/13/22	0.5	0.17 – 1.3	20	0.43	Erosion of natural deposits