



Quality. Service. Value.®

WATER QUALITY REPORT 2021

EAST LOS ANGELES DISTRICT

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

● **TABLE OF CONTENTS**

WELCOME
YOUR WATER
2021 RESULTS
MORE INFO

TABLE OF CONTENTS



Welcome

From the Manager

Your Water System

Your Water System

The Water Quality Lab

Cross-Connection Control

DWSAPP

2021 Test Results

Fluoride

Water Hardness

Possible Contaminants

About Lead

PFOA and PFOS

Key Definitions

Water Quality Table

More Information

Online Resources

TABLE OF CONTENTS

- **WELCOME**
- YOUR WATER
- 2021 RESULTS
- MORE INFO

WELCOME

Since 1926, California Water Service (Cal Water) has been committed to providing a reliable supply of safe, clean water to our customers and communities. With the coronavirus pandemic, access to high-quality water became particularly top of mind. Throughout the pandemic and beyond, our commitment to our customers has remained as strong as ever.

In this system in 2021, we conducted 68,494 tests on 5,079 water samples for 239 constituents. We are pleased to confirm that we met every primary and secondary federal and state water quality standard last year.

Our promise to provide quality, service, and value means more than just treatment and testing. It means having expert professionals available to assist with routine services in a safe and efficient manner. It means having personnel available to handle emergencies 24 hours per day. It means maintaining and upgrading the infrastructure needed to transport water through a network of pumps, tanks, and pipes to your tap. It also means that, even with costs increasing across the country, we do everything we can to operate as efficiently as possible to keep your water affordable.

I encourage you to review this annual water quality report, also called your Consumer Confidence Report, as it details any constituents detected in your water supply in 2021 and shows how your water compares to federal and state standards. It also provides information on current water quality issues and steps we are taking to protect your health and safety.

If you have any questions, we are here to assist you. You can reach us by phone or email at our local Customer Center, or online at www.calwater.com. You can also get water service news on our web site, and via our Facebook, Twitter, and Instagram pages. If you're an account holder, you can find updates in your monthly bill and should keep your contact information up to date by visiting ccu.calwater.com to ensure you receive important emergency and other information.

Sincerely,
Jim Crawford, District Manager, East Los Angeles District

[East Los Angeles District | 2000 South Tubeway Avenue, Commerce, CA 90040 | (323) 722-8601]



ACTION ITEMS

There were no significant issues in your water system in 2021, and we have no recommended action items for our customers in this area.

YOUR WATER SYSTEM



YOUR WATER

Cal Water has provided high-quality water utility services in the East Los Angeles area since 1928. In addition to the customers in our East Los Angeles system, we serve customers through an operating contract with the City of Commerce.

To meet our customers' needs, we use a combination of local groundwater and purchased water from the Metropolitan Water District of Southern California (MWD), which is obtained from the Colorado River and the State Water Project in northern California. The East Los Angeles water system currently includes 272 miles of pipeline, 11 active wells, 29 booster pumps, 16 storage tanks, and three MWD connections.

Our company-wide water quality assurance program includes vigilant monitoring throughout our systems and testing at our state-of-the-art laboratory. Additionally, we proactively maintain and upgrade our facilities to ensure a reliable, high-quality supply. In 2021, we installed two surge tanks, two booster pumps, a new backup power generator, and 11,000 feet of water main. We also replaced a turbidity analyzer, a production flow meter, multiple booster pumps and motors, and 23 critical mainline valves.

If you have any questions, suggestions, or concerns, please contact our local Customer Center, either by phone at (323) 722-8601 or through the Contact Us link at www.calwater.com.

CHLORAMINES

Chloramines are most commonly formed when ammonia is added to chlorine. They are used as a disinfectant to treat your drinking water, and provide long-lasting disinfection as water moves through pipes to consumers.

WATER RESOURCE SUSTAINABILITY

Cal Water helps our customers conserve water by offering programs and incentives to reduce indoor and outdoor water use, develop more efficient habits, and educate the next generation about the importance of managing water resources sustainably. We also continue to invest diligently in our infrastructure to reduce the amount of water lost to pipeline leaks and in 2021 completed an updated assessment of the impacts of climate change on water supply and demand. As we experience a worsening drought this year, it's important that we make saving water every day a way of life. Using water wisely will ensure that we have enough water in dry years and for generations to come.

Visit www.calwater.com/conservation for details.

THE WATER QUALITY LAB

Water professionals collect samples from throughout the water system for testing at our newly upgraded, state-of-the-art water quality laboratory, which is certified each year through the stringent Environmental Laboratory Accreditation Program (ELAP).

Scientists, chemists, and microbiologists test the water for 326 constituents with equipment so sensitive it can detect levels as low as one part per trillion. In order to maintain the ELAP certification, all of our scientists must pass blind-study proficiency tests for every water quality test performed. Water quality test results are entered into our Laboratory Information Management System (LIMS), a sophisticated software program that enables us to react quickly to changes in water quality and analyze water quality trends in order to plan effectively for future needs.

CROSS-CONNECTION CONTROL

To ensure that the high-quality water we deliver is not compromised in the distribution system, Cal Water has a robust cross-connection control program in place. Cross-connection control is critical to ensuring that activities on customers' properties do not affect the public water supply. Our cross-connection control specialists ensure that all of the existing backflow prevention assemblies are tested annually, assess all connections, and enforce and manage the installation of new commercial and residential assemblies.

Backflow can occur when certain pressure conditions exist either in our distribution system or within the customer's plumbing, so our customers are our first line of defense. A minor home improvement project—without the proper protections—can create a potentially hazardous situation, so careful adherence to plumbing codes and standards will ensure the community's water supply remains safe. Please be sure to utilize the advice or services of a qualified plumbing professional.

Many water-use activities involve substances that, if allowed to enter the distribution system, would be aesthetically displeasing or could even present health concerns. Some common cross-connections are:

- Garden hoses connected to a hose bib without a simple hose-type vacuum breaker (available at a home improvement store)

- Improperly installed toilet tank fill valves that do not have the required air gap between the valve or refill tube
- Landscape irrigation systems that do not have the proper backflow prevention assembly installed on the supply line

The list of materials that could potentially contaminate the water system is vast. According to the United States Environmental Protection Agency (EPA), a wide variety of substances have contaminated drinking water systems throughout the country as a result of poor cross-connection control. Examples include:

- Antifreeze from a heating system
- Lawn chemicals from a garden hose or sprinkler head
- Blue water from a toilet tank
- Carbonated water from a soda dispenser

Customers must ensure that all plumbing is in conformance with local plumbing codes. Additionally, state law requires certain types of facilities to install and maintain backflow prevention assemblies at the water meter. Cal Water's cross-connection control staff will determine whether you need to install a backflow prevention assembly based on water uses at your location.



By the end of 2003, Cal Water had submitted to the Division of Drinking Water (DDW) a Drinking Water Source Assessment and Protection Program (DWSAPP) report for each water source in the water system. The DWSAPP report identifies possible sources of contamination to aid in prioritizing cleanup and pollution prevention efforts. All reports are available for viewing or copying at our Customer Center.

The water sources in the East Los Angeles system are considered most vulnerable to contamination from:

- Gas stations
- Confirmed leaks
- Known contaminant plumes
- Chemical/petroleum storage
- Metal fabrication
- Plastic producers

We encourage customers to join us in our efforts to prevent water pollution and protect our most precious natural resource.

FLUORIDE

State law requires Cal Water to add fluoride to drinking water if public funding is available to pay for it, and it is a practice endorsed by the American Medical Association and the American Dental Association to prevent tooth decay. In this area, local water is blended with purchased water that has fluoride in it. Show the table in this report to your dentist to see if he or she recommends giving your children fluoride supplements.



More information about fluoridation, oral health, and related issues can be found on the **DDW web site**.

For general information on water fluoridation, visit us online at **www.calwater.com**.

WATER HARDNESS

Hardness is a measure of the magnesium, calcium, and carbonate minerals in the water. Water is considered soft if its hardness is less than 75 parts per million (ppm), moderately hard at 75 to 150 ppm, hard between 150 and 300 ppm, and very hard at 300 ppm or higher.

Hard water is generally not a health concern, but it can have an impact on how well soap lathers and is significant for some industrial and manufacturing processes. Hard water may also lead to mineral buildup in pipes or water heaters.

Some people with hard water opt to buy a water softener for aesthetic reasons; however, some water softeners add salt to the water, which can cause problems at wastewater treatment plants. Additionally, people on low-sodium diets should be aware that some water softeners increase the sodium content of the water.

For more information on water hardness, visit **www.calwater.com/video/hardness**.

TABLE OF CONTENTS

WELCOME

YOUR WATER

● 2021 RESULTS

MORE INFO

POSSIBLE CONTAMINANTS

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants.

The presence of contaminants does not necessarily indicate that water poses a health risk.

More information about contaminants and potential health effects can be obtained by calling the EPA Safe Drinking Water Hotline at (800) 426-4791.

The sources of drinking water (both tap and bottled) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity.

CONTAMINANTS THAT MAY BE PRESENT IN SOURCE WATER INCLUDE:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.

Radioactive contaminants, which can be naturally occurring or the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA and DDW prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised people, such as those with cancer undergoing chemotherapy, those who have undergone organ transplants, and those with HIV/AIDS or other immune system disorders; some elderly people; and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. EPA and Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline.

As the issue of lead in water continues to be top of mind for many Americans, Cal Water wants to assure you about the quality of your water. We are compliant with health and safety codes mandating use of lead-free materials in water system replacements, repairs, and new installations. We have no known lead service lines in our systems. We test and treat (if necessary) water sources to ensure that the water delivered to customer meters meets all water quality standards and is not corrosive toward plumbing materials.

The water we deliver to your home meets lead standards. However, if present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing (for example, lead solder used to join copper plumbing, and brass and other lead-containing fixtures).

Cal Water is responsible for providing high-quality drinking water to our customers' meters, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested by a certified lab. More information about lead in drinking water can be found on the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

In your system, results from our lead monitoring program, conducted in accordance with the Lead and Copper Rule, were below the action level for the presence of lead.

Testing for Lead in Schools

The State of California required that all public schools built before 2010 test for lead in their drinking water by July 1, 2019. We are committed to supporting our school districts' efforts to protect students and ensure that the drinking water at their school sites are below lead limits. We worked with all school districts in our service area that serve kindergarten through 12th grade to develop sampling plans, test samples, and conduct follow-up monitoring, if needed, for corrective actions.

For more information, please see our [Testing for Lead in Schools](#) web page. For specific information regarding local school data, see the [state web portal](#).

Lead and Copper Rule

The Lead and Copper Rule requires us to test water inside a representative number of homes that have plumbing most likely to contain lead and/or lead solder to determine the presence of lead and copper or any action level exceedance. An action level is the concentration of a contaminant which, when exceeded,

triggers corrective actions before it becomes a health concern. If action levels are exceeded, either at a customer's home or system-wide, we work with the customer to investigate the issue and/or implement corrosion control treatment to reduce lead levels.

Lead Service Line Inventory (LSLI)

Protecting our customers' health and safety is our highest priority. As part of this commitment, we have been working to identify and replace any old customer water service lines and fittings that may contain lead. California Senate Bill (SB) 1398 required all water utilities in California to develop an inventory of all distribution service line materials, and submit a list of known service lines to the state by 2018. A list of unknown service lines that may contain lead, along with a plan for replacement, was due to the state by July 1, 2020. Known lines must be replaced as soon as possible.

More information regarding LSLI and specific data for each water system can be found on [the state web site](#).

PFOA AND PFOS

PFOA and PFOS are manmade compounds used prevalently in firefighting foams and to make carpets, clothing, fabrics for furniture, paper packaging for food, cookware, and other items resistant to water, grease, fire, or stains. They are also used in a number of industrial processes. They are part of a larger group of chemicals referred to as per- and poly-fluoroalkyl substances (PFAS).

In early 2020, DDW announced lower response levels for PFOA and PFOS (10 ppt for PFOA, and 40 ppt for PFOS) from the previous level of 70 ppt combined. The notification levels (5.1 ppt for PFOA, and 6.5 ppt for PFOS) were not changed.

Knowing that these are constituents of emerging concern, Cal water had already identified and tested water sources that would be more likely to have these compounds present by 2019. With the updated response levels, we voluntarily conducted additional testing for these constituents in all of our water systems.

Studies indicate that long-term exposure to PFOA and PFOS over certain levels could have adverse health effects, including developmental effects to fetuses during pregnancy or infants; cancer; or impacts on liver, immunity, thyroid, and other functions. Potential health impacts related to PFAS compounds are still being studied, and research is still evolving on this issue.

Although there is no Maximum Contaminant Level (MCL) set for these substances, we have proactively monitored sources and will continue to do so. Even though it is not required by the state, we believe it is the right thing to do. When an MCL is established by DDW for these compounds, we will continue to ensure our water sources are in compliance with any set standard.

While we are doing our part to treat the water and meet the standards the public health experts have set, it's important that our population as a whole focuses on being good stewards of the environment and takes steps to prevent impacting the water supply.

Additionally, Cal Water has filed a lawsuit against a group of companies that manufactured and sold firefighting foam products that released the PFOA and PFOS into the environment, to ensure the responsible parties bear the costs of treating for these chemicals, not our customers. We are also encouraging the EPA to establish a consistent, science-based standard as quickly as feasible, and strongly support state legislation prohibiting the sale and use of certain products that contain PFAS and requiring the certification of accurate testing methods for PFAS.

More information on PFOA and PFOS is available on the [DDW web site](#).

KEY DEFINITIONS

IN COMPLIANCE: Does not exceed any applicable MCL, SMCL, or action level, as determined by DDW. For some compounds, compliance is determined by averaging the results for one source over a one-year period.

LEVEL 1 ASSESSMENT: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

LEVEL 2 ASSESSMENT: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

MAXIMUM CONTAMINANT LEVEL (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs (SMCLs) are set to protect the odor, taste, and appearance of drinking water.

MAXIMUM CONTAMINANT LEVEL GOAL (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MAXIMUM RESIDUAL DISINFECTANT LEVEL GOAL (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NOTIFICATION LEVEL (NL) AND RESPONSE LEVEL (RL): Health-based advisory levels for unregulated contaminants in drinking water. They are used by DDW to provide guidance to drinking water systems.

PRIMARY DRINKING WATER STANDARDS (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

PUBLIC HEALTH GOAL (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

REGULATORY ACTION LEVEL (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

TREATMENT TECHNIQUE (TT): A required process intended to reduce the level of a contaminant in drinking water.

VARIANCES AND EXEMPTIONS: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

STANDARD ABBREVIATIONS

AL	Action level	Max	Maximum
Min	Minimum	N/A	Not applicable
NL	Notification level	NTU	Nephelometric turbidity unit
ND	Constituent not detected		
pCi/L	Picocuries per liter (a measure of radiation)		
ppb	Parts per billion or micrograms per liter (µg/L)		
ppm	Parts per million or milligrams per liter (mg/L)		
ppq	Parts per quadrillion or picogram per liter (pg/L)		
ppt	Parts per trillion or nanograms per liter (ng/L)		
µS/cm	Microsiemens/centimeter		

Cal Water tests your water for a large number of both regulated and unregulated contaminants. This table lists only those contaminants that were detected.

In the table, water quality test results are divided into four major sections: “Primary Drinking Water Standards,” “Secondary Drinking Water Standards,” “State-Monitored Contaminants with Notification Levels,” and “Unregulated Compounds.” Primary standards protect public health by limiting the levels of certain constituents in drinking water. Secondary standards are set for substances that don’t impact health but could affect the water’s taste, odor, or appearance. Some unregulated substances (hardness and sodium, for example) are included for your information. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

Our testing equipment is so sensitive, it can detect constituents as small as 1 part per trillion. That is equivalent to 1 inch over 15 million miles

SUBSTANCE SOURCES

CF	Discharge from industrial chemical factories	OC	Runoff from orchards; glass and electronics production waste
DI	Byproduct of drinking water disinfection	OD	Discharges of oil-drilling waste and from metal refineries
DK	Decay of natural and manmade deposits	OM	Naturally occurring organic materials
DS	Drinking water disinfectant added for treatment	PR	Inorganic chemical used in solid rocket propellant, fireworks, explosives, flares, matches, and a variety of industries; usually gets into drinking water as a result of environmental contamination from historic aerospace or other industrial operations that used or use, store, or dispose of perchlorate and its salts
EN	Naturally present in the environment	RU	Runoff/leaching from natural deposits
ER	Erosion of natural deposits	RS	Residue from some surface water treatment processes
FD	Discharge from factories, dry cleaners, and auto shops (metal degreaser)	SO	Soil runoff
FE	Human and animal waste	SW	Seawater influence
FL	Water additive that promotes strong teeth; discharge from fertilizer and aluminum factories	VA	Various natural and manmade sources
FR	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage	WD	Leaching from wood preservatives
IC	Internal corrosion of household plumbing systems	UR	Unregulated constituents with no source listed and that do not have standardized “source of substance” language
IM	Discharge from industrial manufacturers		
IO	Substances that form ions when in water		
IW	Industrial waste		
MD	Discharge from metal-degreasing sites and other factories		

Primary Drinking Water Standards

Microbiological	Year Tested	Unit	MCL	PHG (MCLG)	In Compliance	Distribution System-Wide				Source
						Highest Monthly				
Total coliform ¹	2021	Positive samples	5%	(0)	Yes	0%				EN
Fecal coliform and E. coli	2021	Positive samples	1 ²	(0)	Yes	0				FE
Radiological	Year Tested	Unit	MCL	PHG (MCLG)	In Compliance	Groundwater		Central Basin MWD ³		Source
						Range	Average	Range	Average	
Gross alpha particle activity	2016–2021	pCi/L	15	(0)	Yes	ND–5.5	ND	ND–4	ND	ER
Gross beta particle activity	2016–2021	pCi/L	50	(0)	Yes	ND	ND	ND–7	ND	DK
Radium 228	2014–2021	pCi/L	N/A	0.019	N/A	ND	ND	ND–1	ND	ER
Uranium	2014–2021	pCi/L	20	0.43 (0)	Yes	ND–3.0	1.4	ND–3	1	ER

¹ This report reflects changes in drinking water regulatory requirements during 2021. These revisions add the requirements of the federal Revised Total Coliform Rule, effective since April 1, 2016, to the existing state Total Coliform Rule. The revised rule maintains the purpose to protect public health by ensuring the integrity of the drinking water distribution system and monitoring for the presence of microbials (i.e., total coliform and E. coli bacteria). The EPA anticipates greater public health protection as the rule requires water systems that are vulnerable to microbial contamination to identify and fix problems. Water systems that exceed a specified frequency of total coliform occurrences are required to conduct an assessment to determine if any sanitary defects exist. If found, these must be corrected by the water system. The state Revised Total Coliform Rule became effective July 1, 2021.

² This means a routine sample and a repeat sample are total coliform-positive, and one of these is also E. coli-positive.

³ Part of the system’s water supply is purchased from Metropolitan Water District of Southern California (MWD) via the Central Basin Municipal Water District (Central Basin MWD).

Inorganic Chemicals	Year Tested	Unit	MCL	PHG (MCLG)	In Compliance	Groundwater		Central Basin MWD		Source
						Range	Average	Range	Average	
Arsenic ¹	2019–2021	ppb	10	0.004 (0)	Yes	ND–5.3	ND	ND	ND	ER, OC
Barium	2019–2021	ppm	1	2 (2)	Yes	ND–0.15	ND	ND–0.1	ND	ER, OD
Fluoride ²	2021	ppm	2	1 (4.0)	Yes	0.27–0.74	0.43	0.62–0.73	0.68	ER, FL
Nitrate as N ³	2021	ppm	10	10 (10)	Yes	ND–7.2	3.5	ND	ND	ER, FR
Perchlorate	2021	ppb	6	1	Yes	ND–2.4	ND	ND	ND	PR
Lead and Copper	Year Tested	Unit	AL	PHG (MCLG)	In Compliance	Distribution System-Wide		Source		
						90 th Percentile	Samples > AL			
Copper	2020	ppm	1.3	0.3	Yes	0.15	0 of 51	IC, ER, WD		
Lead	2020	ppb	15	0.2	Yes	ND	0 of 51	IC, IM, ER		
Schools that requested lead sampling in 2021: 0										
Volatile Organic Chemicals	Year Tested	Unit	MCL	PHG (MCLG)	In Compliance	Groundwater		Central Basin MWD		Source
						Range	Average	Range	Average	
1,1-Dichloroethylene	2021	ppb	6	10 (7)	Yes	ND–2.4	ND	ND	ND	CF
Tetrachloroethylene (PCE)	2021	ppb	5	0.06 (0)	Yes	ND–1.2	ND	ND	ND	FD
Trichloroethylene (TCE)	2021	ppb	5	1.7 (0)	Yes	ND–1.3	ND	ND	ND	MD

¹ While your drinking water meets the federal and state standards for arsenic, it does contain low levels of arsenic. The arsenic standards balance the current understanding of arsenic’s possible health effects against the costs of removing arsenic from drinking water. The EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects, such as skin damage and circulatory problems.

² Fluoride is added to Central Basin MWD water supply. MWD treats its water by adding fluoride to the naturally occurring level in order to help prevent dental caries in consumers. The fluoride levels in the treated water are maintained within a range of 0.6–1.2 ppm, as required by DDW.

³ The average nitrate level was 3.5 ppm, with a maximum level of 7.2 ppm. We are closely monitoring the nitrate levels. Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant’s blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 ppm may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant or you are pregnant, you should seek advice from your health care provider.

Disinfection Byproducts	Year Tested	Unit	MCL	PHG (MCLG)	In Compliance	Distribution System-Wide		Source
						Range	Highest Annual Average	
Haloacetic acids	2021	ppb	60	N/A	Yes	ND–9.1	5.1	DI
Total trihalomethanes	2021	ppb	80	N/A	Yes	ND–34	27	DI
Disinfectants	Year Tested	Unit	MRDL	MRDLG	In Compliance	Distribution System-Wide		Source
						Range	Average	
Total chlorine	2021	ppm	4	4	Yes	0.26–2.9	2.0	DS
Surface Water—Turbidity and TOC	Year Tested	Unit	MCL	PHG (MCLG)	In Compliance	Central Basin MWD		Source
						Highest Level	% ≤ 0.3	
Turbidity ¹	2021	NTU	TT	N/A	Yes	0.06	100.0	SO
Surface Water—Turbidity and TOC	Year Tested	Unit	MCL	PHG (MCLG)	In Compliance	Range	Highest RAA	Source
						Total organic carbon ²	2021	ppm

¹ For surface water systems, the treatment technique dictates that the turbidity level of the filtered water be less than or equal to 0.3 NTU in 95% of measurements taken each month and not exceed 1 NTU at any time. Turbidity is a measurement of cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.

² TOC has no health effects; however, TOC provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes and haloacetic acids. The treatment technique dictates that a removal ratio of 1 or higher must be achieved. Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects such as liver, kidney, or nervous system problems, and may lead to an increased risk of cancer. Concerns regarding disinfection byproducts are based upon exposure over many years.

Secondary Drinking Water Standards

Chemical	Year Tested	Unit	SMCL	PHG (MCLG)	In Compliance	Groundwater		Central Basin MWD		Source
						Range	Average	Range	Average	
Aluminum ¹	2019–2021	ppb	200	600	Yes	ND	ND	ND–240	118	ER, RS
Chloride	2019–2021	ppm	500	N/A	Yes	34–140	86	65–97	88	RL, SW
Color	2019–2021	UNITS	15	N/A	Yes	ND–5.0	ND	ND	ND	OM
Specific conductance	2019–2021	US	1600	N/A	Yes	560–990	825	519–965	827	SW, IO
Manganese ²	2019–2021	ppb	50	N/A	Yes	ND–150	ND	ND	ND	RL
Odor	2017–2021	T.O.N.	3	N/A	Yes	ND–2.0	ND	ND	ND	OM
Sulfate	2019–2021	ppm	500	N/A	Yes	74–110	96	61–221	166	RL, IW
Total dissolved solids	2019–2021	ppm	1000	N/A	Yes	350–580	500	298–609	500	RL
Turbidity (groundwater)	2019–2021	NTU	5	N/A	Yes	ND–0.51	0.21	0.15	0.15	SO

¹ Compliance is based upon a four-quarter running annual average (RAA). The RAA for the surface water sources is less than the SMCL.

² Compliance is based upon a four-quarter RAA. The RAA for the groundwater source is non-detect (ND).

State Monitored Contaminants with Notification Levels

Chemical	Year Tested	Unit	NL	PHG (MCLG)	In Compliance	Groundwater		Central Basin MWD		Source
						Range	Average	Range	Average	
1,4-Dioxane ¹	2017–2021	ppb	1	N/A	Yes	ND–5.8	3.5	N/A	N/A	UR
Boron	2016–2021	ppm	1	N/A	Yes	0.11–0.24	0.18	0.13–0.18	0.15	UR
Chromium (hexavalent)	2014–2021	ppb	N/A	0.02	N/A	ND–2.4	1.0	ND	ND	UR
Dichlorodifluoromethane (Freon 12)	2019–2021	ppb	1000	N/A	Yes	ND–0.62	ND	ND	ND	UR
N-Nitrosodimethylamine (NDMA)	2020–2021	ppt	10	3	Yes	ND	ND	ND–3.0	ND	UR
Perfluorooctanoic acid (PFOA) ²	2021	ppt	5.1	N/A	Yes	ND–5.5	ND	ND	ND	UR
Perfluorooctanesulfonic acid (PFOS) ²	2021	ppt	6.5	N/A	Yes	ND–31	ND	ND	ND	UR
Vanadium	2018–2021	ppb	50	N/A	Yes	ND–4.7	ND	ND	ND	UR

Unregulated Contaminant Monitoring Rule (UCMR)

Chemical	Year Tested	Unit	MCL	PHG (MCLG)	In Compliance	Groundwater		Central Basin MWD		Source
						Range	Average	Range	Average	
Haloacetic acids	2020	ppb	60	N/A	N/A	ND–8.6	2.9	6.7–14	9.3	UR
Brominated haloacetic acids	2020	ppb	N/A	N/A	N/A	ND–7.5	2.8	5.6–12	8.6	UR
Haloacetic acids and brominated haloacetic acids	2020	ppb	N/A	N/A	N/A	ND–14	5.3	11–24	17	UR

¹ Some groundwater wells contain 1,4-dioxane at levels greater than the NL established by DDW. An NL is defined as a health-based advisory level for an unregulated contaminant in drinking water. DDW uses it to provide guidance to drinking water systems. DDW recommends taking a well out of service if the concentrations in the well exceed 35 times the NL. Based on laboratory studies, some people who consume water containing 1,4-dioxane that contains this constituent over many years may experience liver or kidney problems and may have a heightened cancer risk.

² PFAS include both perfluorooctanoic acid (PFOA) and perfluorooctanesulfonic acid (PFOS). There is no MCL or SMCL for PFOS/PFOA; however, there are established NLs and RLs. The NL for PFOA is 5.1 ppt and for PFOS is 6.5 ppt, with RLs of 10 ppt and 40 ppt, respectively. NLs are non-regulatory, health-based advisory levels established for constituents that may be candidates for MCLs in the future. Studies indicate that long-term exposure to PFOS/PFOA over certain levels could have adverse health effects; in laboratory studies, PFOS exposure resulted in immune suppression and cancer, while PFOA exposure resulted in increased liver weight and cancer. Cal Water proactively tested all of our active sources for PFOS and PFOA. We continue to work closely with DDW and EPA to conduct extensive monitoring.

Unregulated Compounds

Chemical	Year Tested	Unit	MCL	PHG (MCLG)	In Compliance	Groundwater		Central Basin MWD		Source
						Range	Average	Range	Average	
Alkalinity (total)	2019–2021	ppm	N/A	N/A	N/A	160–210	186	86–128	114	UR
Calcium	2016–2021	ppm	N/A	N/A	N/A	59–97	78	27–70	77	UR
Hardness (total)	2016–2021	ppm	N/A	N/A	N/A	210–340	269	110–276	223	UR
Potassium	2016–2021	ppm	N/A	N/A	N/A	2.3–3.4	2.8	2.6–4.7	3.9	UR
Magnesium	2016–2021	ppm	N/A	N/A	N/A	11–25	19	12–26	21	UR
Sodium	2016–2021	ppm	N/A	N/A	N/A	31–88	67	61–101	85	UR
Perfluorohexanoic acid (PFHxA)	2020–2021	ppt	N/A	N/A	N/A	ND–4.0	ND	ND	ND	UR
Perfluorhexanesulfonic acid (PFHxS)	2020–2021	ppt	N/A	N/A	N/A	ND–6.6	ND	ND	ND	UR
pH	2017–2021	STD U	N/A	N/A	N/A	7.0–8.7	7.6	8.4–8.4	8.4	UR

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether our drinking water meets health standards. During the first quarter of 2020, we did not monitor for radionuclides in two new wells; therefore, we were unable to complete the four consecutive quarterly samples by the end of 2020. Every sample analyzed for radionuclides since, however, has meet primary drinking water standards. Additionally, we did not complete the initial monitoring requirements at the two wells for a portion of synthetic organic chemicals by the end of 2020; however, no synthetic organic chemicals have been detected in subsequent samples.

TABLE OF CONTENTS

WELCOME

YOUR WATER

2021 RESULTS

● **MORE INFO**

Thanks for taking the time
to learn more about
your water quality!

Even more information awaits you at www.calwater.com.

Visit our web site to get information about your account, water-use history,
water rates, and water system.

You will also find water-saving tips and news about
water conservation programs and rebates available in your area.



Quality. Service. Value.®



THANK YOU.

- ▶ Conservation resources
- ▶ Lead in water
- ▶ Water treatment and disinfection
- ▶ Protecting the water supply