

2017 Consumer Confidence Report

Water System Name: Paradise Ranch MHP

Report Date: May 2017

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2017 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Groundwater and Water purchased from NCWD and VWC

Name & general location of source(s): Paradise Ranch MHP Wells 9,10,14,17,18,19,20 and NCWD Hydrant at the corner of Lake Hughes Rd and N. Castaic Rd, and the VWC Hydrant at the corner of The Old Road and Villa Canyon Rd

Drinking Water Source Assessment information: Assessment was done using the Default Groundwater System Method. A source water assessment was conducted for Paradise Ranch MHP Well 9,10 and 14 in July 2001. A source water assessment was done for Wells 19 and 20 in August 2017. A source water assessment is being done for Wells 17 and 18 but is not yet complete. For a summary of Source Assessment see last page of this report

Time and place of regularly scheduled board meetings for public participation: N/A

For more information, contact: Robert Cole Phone: (661) 257-2728

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (μ g/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a mo.) <u>1</u>	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	8/2017	10	1.8	0	15	0.2		Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	8/2017	10	0.45	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2017	80	69-92	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2017	155	120-220	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Total Trihalomethanes (ppm)	8/2017	0.0	0.0	0.08	0	Byproduct of drinking water disinfection
Haloacetic acids (ppm)	8/2017	0.0	0.0	0.06	0	Byproduct of drinking water disinfection
Fluoride (ppm)	2017	0.2075	0.14-0.26	4.0	1.0	Leaching from natural deposits
Nitrate (ppm)	2017	0.62	0.43-1.1	10	10	Runoff/Leaching from fertilizer use, leaching from septic tanks and sewage, erosion of natural deposits
Copper (ppm)	2017	0.033	0.011-0.057	1.3	0.3	Corrosion of household plumbing systems, erosion of natural deposits
Lead (ppb)	2017	4.5	<1.0-41	15	0.2	Corrosion of household plumbing systems, erosion of natural deposits

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	2017	91	68-110	500	n/a	Runoff/Leaching from natural deposits. Seawater influence
Total Dissolved Solids TDS (ppm)	2017	400	350-480	1000	n/a	Runoff/Leaching from natural deposits
Sulfate (ppm)	2017	73	60-99	500	n/a	Runoff Leaching from natural deposits. Industrial wastes
pH (pH units)	2017	7.85	7.53-8.08	6.5 to 8.5	n/a	
Specific Conductance (Umhos/cm)	2017	649	560-761	1600	n/a	Substances that form ions when in water. Seawater influence
Odor Threshold odor number	2017	.42	No obvious odor-20	3	n/a	Naturally occurring organic materials
Color (Color units)	2017	4.9	1.0-20	15	n/a	Naturally occurring organic material
Iron (ppb)	2017	132	<50-790	300	n/a	Leaching from natural deposits. Industrial wastes
Manganese (ppb)	2017	3.83	<10-13	50	n/a	Leaching from natural deposits

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Boron (ppb)	2017	390	290-510	1000	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an

					increased risk of developmental effects, based on studies in laboratory animals
--	--	--	--	--	---

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Paradise Ranch MHP is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4701) or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language

For Water Systems Providing Groundwater as a Source of Drinking Water

TABLE 7 – SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLES					
Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0	Monthly for 2017	0	(0)	Human and animal fecal waste

2017 Consumer Confidence Report

Drinking Water Source Assessment Information

Assessment Info

A source water assessment was conducted for WELL 09, WELL 10, and WELL 14 of the PARADISE RANCH MHP water system in July, 2001. A source water assessment was conducted for WELL 19 and WELL 20 of the PARADISE RANCH MHP water system in August 2017. A source water assessment has not yet been completed for WELL 17 or Well 18 of the PARADISE RANCH MHP water system.

Well 09 – is considered most vulnerable to the following activities associated with contaminants detected in the water supply:
Surface water – streams/lakes/rivers

Well 10– is considered most vulnerable to the following activities associated with contaminants detected in the water supply:
Chemical/petroleum pipelines
Wells – Agricultural/Irrigation
Wastewater treatment plants
Surface water – streams/lakes/rivers

Well 10 – is considered most vulnerable to the following activities not associated with any detected contaminants:
Sewer collection systems

Well 14 – is considered most vulnerable to the following activities associated with any detected contaminants:
Surface water – streams/lakes/rivers

Well 17 – This info is not available, as this water system does not have a completed assessment on file.

Well 18 – This info is not available, as this water system does not have a completed assessment on file.

Well 19---is considered most vulnerable to the following activities associated with any detected contaminants:
Surface water---streams/lakes/rivers

Well 20---is considered most vulnerable to the following activities associated with any detected contaminants:
Surface water---streams/lakes/rivers

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water Field Office or the Water system, to find out when the Assessment is scheduled to be done.

The source is not active. It may be out of service, or new and not yet in service

The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Info

A copy of the complete assessment may be viewed at:
Department of Health Services, Drinking Water Field Office
500 N. Central Ave.
Suite 500
Glendale, CA 91203

You may request a summary of the Assessment to be sent to you by contacting:
Vera Melynk-Vecchio
District Engineer
213 – 580 – 5723
213 – 580 – 5711 (fax)