

CITY OF PARAMOUNT

2
0
2
5


CONSUMER CONFIDENCE REPORT



Since 1991, California water utilities have been providing information on water served to its consumers. This report, prepared in May 2026, is a snapshot of the tap water quality that we provided last year. Included are details that outline state and federal limits, where your water comes from, how it is tested and what is in it. We strive to keep you informed about the quality of your water, and to provide a reliable and economic supply that meets all regulatory requirements.

WHERE DOES MY TAP WATER COME FROM?

Your tap water comes from 2 sources: groundwater and surface water. We pump groundwater from local, deep wells. We also use Metropolitan Water District of Southern California's (MWD) surface water from both the Colorado River and the State Water Project in northern California. These water sources supply our service area shown on the adjacent map. The quality of our groundwater and MWD's surface water supplies is presented in this report.



HOW DO I READ THE WATER QUALITY TABLE?

Although we test for over 100 substances, regulations require us to report only those found in your water. The first column of the water quality table lists substances detected in your water. The next columns list the average concentration and range of concentrations found in your drinking water. Following are columns that list the Maximum Contaminant Level (MCL) and Public Health Goal (PHG) or Maximum Contaminant Level Goal (MCLG), if appropriate. The last column describes the likely sources of these substances in drinking water.

To review the quality of your drinking water, compare the highest concentration and the MCL. Check for substances greater than the MCL. Exceedance of a primary MCL does not usually constitute an immediate health threat. Rather, it requires testing the source water more frequently for a short duration.

If test results show that the water continues to exceed the MCL, the water must be treated to remove the substance, or the source must be removed from service.

HOW IS MY DRINKING WATER TESTED?

Your drinking water is tested regularly for unsafe levels of chemicals, radioactivity and bacteria at the source and in the distribution system. We test weekly, monthly, quarterly, annually or less often depending on the substance. State and federal laws allow us to test some substances less than once per year because their levels do not change frequently. All water quality tests are conducted by specially trained technicians in state-certified laboratories.

WHAT ARE DRINKING WATER STANDARDS?

The U.S Environmental Protection Agency (USEPA) limits the amount of certain substances allowed in tap water. In California, the State Water Resources Control Board (State Water Board) regulates tap water quality by enforcing limits that are at least as stringent as the Federal EPA's (USEPA). Historically, California limits are more stringent than the Federal ones.

There are two types of these limits, known as standards. Primary standards protect you from substances that could potentially affect your health. Secondary standards regulate substances that affect the aesthetic qualities of water. Regulations set a Maximum Contaminant Level (MCL) for each of the primary and secondary standards. The MCL is the highest level of a substance that is allowed in your drinking water.

Public Health Goals (PHGs) are set by the California Environmental Protection Agency. PHGs provide more information on the quality of drinking water to customers, and are similar to their federal counterparts, Maximum Contaminant Level Goals (MCLGs). PHGs and MCLGs are advisory levels that are non-enforceable. Both PHGs and MCLGs are concentrations of a substance below which there are no known or expected health risks.



WHY DO I SEE SO MUCH COVERAGE IN THE NEWS ABOUT THE QUALITY OF TAP WATER?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells.

As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, including viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.



Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791). You can also get more information on tap water by logging on to these helpful web sites:

- www.epa.gov/ground-water-and-drinking-water/safe-drinking-water-information (USEPA's web site)
- www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/Chemicalcontaminants.html (State Water Board web site)

If present, elevated levels of lead can cause serious health problem, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Paramount is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.



SHOULD I TAKE ADDITIONAL PRECAUTIONS?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The USEPA/Centers for Disease Control guidelines on appropriate means to lessen the risk of infection of *Cryptosporidium* and other microbial contaminants are available from the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

SOURCE WATER ASSESSMENT

MWD completed an assessment of its Colorado River and State Water Project supplies in 2002. Colorado River supplies are considered most vulnerable to recreation, urban/storm water runoff, increasing urbanization in the watershed, and wastewater. State Water Project supplies are considered most vulnerable to urban/storm water runoff, wildlife, agriculture, recreation and wastewater. A copy of the assessment can be obtained by contacting MWD at (213) 217-6000.

The City of Paramount conducted an assessment of its groundwater supplies in 2003. Groundwater supplies are considered most vulnerable to chemical/petroleum processing/storage, metal plating/finishing/fabricating, dry cleaners, automobile gas stations, automobile body shops, automobile repair shops, junk/scrap/salvage yards, and plastics/synthetics producers.

A copy of the Source Water Assessment is available by contacting the Paramount Public Works Department at publicworksdept@paramountcity.gov, or by calling (562) 220-2020.

HOW CAN I PARTICIPATE IN DECISIONS ON WATER ISSUES THAT AFFECT ME?

The public is welcome to attend Public Works Commission meetings located at Paramount City Hall, 16400 Colorado Avenue, Paramount, CA 90723. Meetings are held on the 1st Thursday of each month at 6:00 p.m.

HOW DO I CONTACT MY WATER AGENCY IF I HAVE ANY QUESTIONS ABOUT WATER QUALITY?

If you have specific questions about your tap water quality, please contact David Arellano at (562) 220-2020.



SOME HELPFUL WATER CONSERVATION TIPS

- Fix leaky faucets in your home – save up to 20 gallons every day for every leak stopped
- Save between 15 and 50 gallons each time by only washing full loads of laundry
- Adjust your sprinklers so that water lands on your lawn/garden, not the sidewalk/driveway – save 500 gallons per month
- Use organic mulch around plants to reduce evaporation – save hundreds of gallons a year
- Use a water-efficient showerhead. They are inexpensive, easy to install, and can save you up to 750 gallons a month.




Visit www.epa.gov/watersense for more details.

Visit us at www.paramountcity.gov



On behalf of the City of Paramount’s Water Divison, we appreciate you taking the time to review the 2025 Consumer Confidence Report (CCR). Our Water Division works hard every day to deliver safe, clean, and reliable water, while maintaining 130 miles of water lines, upgrading smart meters, and improving infrastructure to better serve you. Thank you for your trust and support!

En nombre de la División de Agua de la Ciudad de Paramount, agradecemos su tiempo para revisar el Informe de Confianza del Consumidor (CCR) de 2025. Nuestra División de Agua trabaja arduamente todos los días para brindar agua segura, limpia y confiable, manteniendo 210 kilómetros de tuberías, modernizando medidores inteligentes y mejorando la infraestructura para brindarle un mejor servicio. ¡Gracias por su confianza y apoyo!



-CITY OF PARAMOUNT WATER DIVISION

CITY OF PARAMOUNT

CONSUMER CONFIDENCE REPORT

2025

Results are from the most recent testing performed in accordance with state and federal drinking water regulations. The State allows monitoring for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative, are more than one year old.

Los resultados provienen de las pruebas más recientes realizadas de acuerdo con las regulaciones estatales y federales sobre agua potable. El Estado permite el monitoreo de algunos contaminantes menos de una vez al año porque las concentraciones de estos contaminantes no cambian con frecuencia. Algunos de los datos, aunque representativos, tienen más de un año.



PRIMARY STANDARDS MONITORED AT THE SOURCE-MANDATED FOR PUBLIC HEALTH							
ORGANIC CHEMICALS (µg/l)	GROUNDWATER		MWD'S SURFACE WATER		PRIMARY MCL	MCLG or PHG	MAJOR SOURCES IN DRINKING WATER
	AVERAGE	RANGE	AVERAGE	RANGE			
	(a)	(a)	(a)	(a)			
INORGANICS Sampled from 2023 to 2025 (b)							
Aluminum (mg/l)	ND	ND	0.08	ND - 0.10	1	0.6 (c)	Erosion of natural deposits; residue from surface water treatment processes
Arsenic (µg/l) (k)	6.9	ND - 13	ND	ND	10	0.004	Erosion of natural deposits; glass/electronics production wastes; runoff
Barium (mg/l)	0.16	0.15 - 0.17	0.12	ND	1	2 (c)	Oil drilling waste and metal refinery discharge; erosion of natural deposits
Fluoride (mg/l) (l)	0.34	0.28 - 0.39	0.70	0.2 - 0.8	2.0	1 (c)	Erosion of natural deposits, water additive that promotes strong teeth
Hexavalent Chromium (ug/l) (n)	0.1	ND - 0.2	ND	ND	10	0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate (mg/l as N)	0.3	ND - 0.48	ND	ND	10	10 (c)	Runoff and leaching from fertilizer use/septic tanks/sewage, natural erosion
RADIOLOGICAL - (pCi/l) (Sampled from 2022 -2025) (b)							
Gross Alpha	0.35	ND - 1.7	ND	ND - 5	15 (e)	0	Erosion of natural deposits
Gross Beta	NA	NA	ND	ND - 6	50 (e)	0	Decay of natural and man-made deposits
Radium 226	ND	ND	ND	ND	5 (d)	0.05	Erosion of natural deposits
Radium 228	0.38	ND - 1.91	ND	ND		0.019	Erosion of natural deposits
Uranium	1.38	0.91 - 1.7	0.5	ND - 3.0	20 (e)	0.5 (c)	Erosion of natural deposits

PRIMARY STANDARDS MONITORED IN THE DISTRIBUTION SYSTEM - MANDATED FOR PUBLIC HEALTH					
MICROBIALS	DISTRIBUTION SYSTEM		PRIMARY MCL	MCLG or PHG	
	AVERAGE	RANGE			
	% POSITIVE	% POSITIVE			
Total Coliform Bacteria	0.0%	0.0%	5%	0%	Naturally present in the environment
Fecal Coliform and <i>E.Coli</i> Bacteria	0.0%	0.0%	0%	0%	Human and animal fecal waste
No. of Acute Violations	0	0	-	-	
MICROBIALS	DISTRIBUTION SYSTEM		TT	-	Soil runoff. Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of water quality.
	AVERAGE	RANGE			
Turbidity (NTU)	0.7	0.19 - 2.04			
DISINFECTION BY-PRODUCTS AND DISINFECTANT RESIDUALS (f)	DISTRIBUTION SYSTEM		PRIMARY MCL	MCLG or PHG	
	AVERAGE	RANGE			
Trihalomethanes-TTHMS (µg/l)	26.8	1.6 - 29.0	80	-	By-product of drinking water chlorination
Haloacetic Acids (µg/l)	6.7	0.0 - 3.9	60	-	By-product of drinking water disinfection
Total Chlorine Residual (mg/l)	1.19	0.11 - 2.20	4.0 (g)	4.0 (h)	Drinking water disinfectant added for treatment
AT THE TAP PHYSICAL CONSTITUENTS 31 sites sampled in 2025	DISTRIBUTION SYSTEM		PRIMARY MCL	MCLG or PHG	
	90%	# OF SITES ABOVE THE AL			
Copper (mg/l)	0.05 (i)	0	1.3 AL	0.17 (c)	Internal corrosion of household plumbing, erosion of natural deposits
Lead (µg/l)	0.0004 (i)	0	15 AL	2 (c)	Internal corrosion of household plumbing, industrial manufacturer discharges

SECONDARY STANDARDS MONITORED AT THE SOURCE-FOR AESTHETIC PURPOSES						
Sampled from 2023 to 2025	GROUNDWATER		MWD'S SURFACE WATER		SECONDARY MCL	MCLG or PHG
	AVERAGE	RANGE	AVERAGE	RANGE		
Aggressiveness Index (corrosivity)	12.1	11.5 - 12.4	12.4	12.3 - 12.5	Non-corrosive	-
Aluminum (µg/l) (j)	ND	ND	77	ND - 100	200	600 (c)
Chloride (mg/l)	32	27.0 - 37.0	92	84 - 99	500	-
Color (color units)	1	ND - 3.0	1.0	1.0	15	-
Specific Conductance (uS/cm)	583.3	520 - 620	870	754 - 987	1,600	-
Iron (ug/l)	46.4	ND - 240	ND	ND	300	-
Manganese (µg/l) (k)	6.6	ND - 48	ND	ND	50	-
Odor (threshold odor number)	ND	ND	0.0	0.0	3	-
Sulfate (mg/l)	76.3	71.0 - 80.0	179	139 - 218	500	-
Total Dissolved Solids (mg/l)	386.7	330 - 460	540.5	456 - 625	1,000	-
Turbidity (NTU)	0.35	0.15 - 0.70	ND	ND	5	-

SECONDARY STANDARDS MONITORED IN THE DISTRIBUTION SYSTEM-FOR AESTHETIC PURPOSES					
GENERAL PHYSICAL CONSTITUENTS	DISTRIBUTION SYSTEM		SECONDARY MCL	MCLG or PHG	
	AVERAGE	RANGE			
Color (color units)	<5	<5	15	-	Naturally-occurring organic materials
Odor (threshold odor number)	1	1	3	-	Naturally-occurring organic materials

ADDITIONAL CHEMICALS OF INTEREST				
Sampled from 2023 to 2025	GROUNDWATER		MWD'S SURFACE WATER	
	AVERAGE	RANGE	AVERAGE	RANGE
Alkalinity (mg/l)	216.7	210 - 220	109	93 - 124
Boron (µg/l)	NA	NA	130	130.0
Calcium (mg/l)	67.2	59.5 - 74.1	56.0	43 - 70
1,4-Dioxane (ug/l) (m)	1.7	1.3 - 1.9	NA	NA
Magnesium (mg/l)	10.0	6.9 - 11.8	22	19 - 25
N-Nitrosodimethylamine (ng/l)	NA	NA	ND	ND - 2.8
pH (standard unit)	7.5	6.9 - 7.9	8.3	8.2 - 8.3
Potassium (mg/l)	3.1	2.6 - 3.4	4.4	3.8 - 5.0
Sodium (mg/l)	37.7	34 - 42	88.5	78 - 100
Total Hardness (mg/l)	209.3	177 - 234	235	189 - 280
Total Organic Carbon (mg/l)	0.4	0.4	2.5	1.6 - 2.8
PERFLUOROOCTANE SULFONIC ACID (PFOS) (ng/l) NL=6.5 ng/l Minimum Reporting Level (MRL)=0.004 ug/l	2.87	ND - 7.7	ND	ND

FOOTNOTES
(a) Over 50 regulated and unregulated organic chemicals were analyzed. None were detected at or above the reporting limit in groundwater or surface water sources.
(b) Indicates dates sampled for groundwater sources only.
(c) California Public Health Goal (PHG). Other advisory levels listed in this column are federal Maximum Contaminant Level Goals (MCLGs).
(d) Combined Radium 226 + Radium 228 has a Maximum Contaminant Level (MCL) of 5 pCi/L.
(e) MCL compliance based on 4 consecutive quarters of sampling.
(f) Running annual average used to calculate average, range, and MCL compliance.
(g) Maximum Residual Disinfectant Level (MRDL)
(h) Maximum Residual Disinfectant Level Goal (MRDLG)
(i) 90th percentile from the most recent sampling at selected customer taps.
(j) Aluminum has primary and secondary standards.
(k) While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The US Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems. For this well system, the filtration treatment technique is used to remove arsenic and manganese from the water prior to distribution. Water after treatment is in compliance and below the MCL.
(l) Starting June 1, 2015, the fluoride levels at the MWD treatment plants were adjusted to achieve an optimal fluoride level of 0.7 ppm and a control range od 0.6 ppm to 1.2 ppm to comply with the existing State's Water Fluoridation Standards. Fluoride feed systems were temporarily out of service during treatment plant shutdowns and/or maintenance work in 2023 resulting in occasional fluoride levels below 0.7 mg/L. MWD was in compliance with all provisions of the State's fluoridation requirements.
(m) The Notification Level of 1 ug/l for 1,4-Dioxane was exceeded in one well in 2025. This well was monitored but was out of service. Some people who use water containing 1,4-dioxane in excess of the Notification Level over many years may experience liver or kidney problems and may have an increased risk of getting cancer, based on studies in laboratory animals.
(n) Hexavalent Chromium (CR-6) was detected in two wells in 2025. Pursuant to the Detection Limits for Purposes of Reporting (DLRs), the DLR for Hexavalent Chromium is 0.0001 mg/L or 0.1 ug/L. Paramount monitored for Hexavalent Chromium and has not exceeded the annual running average of 10 ug/l.

ABBREVIATIONS
<= less than
mg/l = milligrams per liter or parts per million (equivalent to 1 drop in 42 gallons)
NTU = nephelometric turbidity units
SI = saturation index
NA = constituent not analyzed
pCi/l = picoCuries per liter (a measure of radiation)
uS/cm = microSiemens per centimeter
ND = constituent not detected at the testing limit
ng/l = nanograms per liter or parts per trillion (equivalent to 1 drop in 42,000,000 gallons)
µg/l = micrograms per liter or parts per billion (equivalent to 1 drop in 42,000 gallons)

DEFINITIONS
Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.
Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Notification Level (NL): The level at which notification of the public water system governing body is required. A health-based advisory level for an unregulated contaminant.
Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.
Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Primary Drinking Water Standard (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Secondary Drinking Water Standard (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Variances and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

UNREGULATED CONTAMINANT MONITORING REGULATION (UCMR-5)
The Safe Drinking Water Act requires the Environmental Protection Agency (EPA) to identify unregulated contaminants for potential regulations. Every five years, EPA identifies a list of unregulated contaminants to be monitored for by the nation's water utilities over a three year period. This is occurring in 2023-2025 with the fifth UCMR (UCMR-5). In 2025, the City of Paramount began monitoring for a total of 30 chemical contaminants from its wells along with a corresponding sampling from the distribution system reflecting water from each well. Once EPA has obtained this occurrence data nationally, they are required to determine if there is a meaningful opportunity for increased health protection of drinking water by regulating these contaminants. The findings from this monitoring are reported in this year's Consumer Confidence Report.

FIFTH UNREGULATED CONTAMINANT MONITORING REGULATION (UCMR 5)				
Monitored in 2025				
CHEMICALS PARAMETERS	AVERAGE ug/l	RANGE ug/l	Minimum Reporting Level (ug/l)	USE OR ENVIRONMENTAL SOURCE
Lithium (ug/l)	20.6	ND - 56	9.0 ug/l	Naturally-occurring metal that may concentrate in brine waters; lithium salts are used as pharmaceuticals, used in electrochemical cells, batteries, and in organic syntheses.

CIUDAD DE PARAMOUNT

2025

INFORME CONFIANZA DE CONSUMIDOR




Desde 1991, las agencias proveedoras de recursos hidráulicos de California han emitido información sobre el agua que se provee al consumidor. Este informe, elaborado en mayo 2026, es un resumen de la calidad del agua del grifo que proporcionamos el año pasado. Incluimos detalles sobre el origen del agua que toma, cómo se analiza, que contiene, y cómo se compara con los límites estatales y federales. Nos esforzamos por mantenerle informado sobre la calidad de su agua, y proveerle un abastecimiento confiable y económico que cumpla con todos los requisitos.

¿DE DÓNDE PROVIENE EL AGUA QUE TOMO?

Su agua de la llave proviene de 2 fuentes: de las aguas naturales (subterránea) y de aguas superficiales (de los ríos). Bombeamos aguas naturales de profundos pozos locales. También usamos agua superficial de la

agencia Metropolitan Water District del Sur de California (MWD) importada del Río Colorado y del proyecto State Water Project del Norte de California. Estas dos fuentes de agua nos abastecen en las áreas de servicio que se muestran en el mapa adjunto. Este reporte informa sobre la calidad de nuestra agua subterránea y el abastecimiento del agua superficial del MWD.



El plomo y el cobre, por ejemplo, son regulados, por cierto nivel de acción. Si cualquier sustancia química sobrepasa el nivel de acción, se dará la necesidad de un proceso de tratamiento para rebajar los niveles en el agua de beber. Los abastecedores de agua deben cumplir con los Niveles Contaminantes Máximos para asegurar la calidad del agua.

Las Metas para la Salud Pública (MSP [o PHGs, en inglés]) son establecidas por la agencia estatal de California-EPA. Las PHGs proveen más información con respecto a la calidad del agua, y son similares a los reglamentos federales nombrados Metas para Los Niveles de Contaminante Máximos (MNCM [o MCLGs, en inglés]). Las PHGs y MCLGs son metas a nivel recomendable. Las PHG y MCLG son ambas definidas como los niveles de contaminantes en el agua potable por debajo de los niveles donde no se esperan riesgos a la salud y no enforzables. Ambos niveles PHG y MCLG son concentraciones de una sustancia en las que no hay riesgos a la salud aún conocidos.

¿CÓMO SE ANALIZA MI AGUA POTABLE?

El agua que toma se analiza regularmente para asegurarnos de que no halla niveles altos de sustancias químicas, de radioactividad o de bacteria en el sistema de distribución y en las tomas de servicios. Estos análisis se llevan a cabo semanal, mensual, trimestral, y anualmente o con más frecuencia, dependiendo de la sustancia analizada. Bajo las leyes estatales y federales, se nos permite analizar algunas sustancias menos frecuentemente que los periodos anuales porque los resultados no cambian.



¿CUALES SON LOS ESTÁNDARES DEL AGUA POTABLE?

La Agencia de Protección Ambiental estadounidense (USEPA) limita la cantidad de ciertas sustancias permitidas en el agua del grifo. En California, la Junta de Control de Recursos Hídricos del Estado (State Water Board) regula la calidad del agua de beber siguiendo normas que sean al menos tan estrictas como las normas federales. Históricamente, los límites de California son más rigurosos que los Federales.

Hay dos tipos de límites conocidos como estándares. Los estándares primarios lo protegen de sustancias que potencialmente podrían afectar su salud. Las normas establecen los Niveles Contaminantes Máximos (MCL, en inglés) que se permite del contaminante primario o secundario en el agua de beber. Los abastecedores de agua deben asegurarse de que la calidad de esta cumpla con los Niveles Contaminantes Máximos (o MCLs, en inglés). No todas las sustancias tienen un Nivel Contaminante Máximo.

¿CÓMO INTERPRETO MI INFORME DE CALIDAD DEL AGUA?

Aunque analizamos más de 100 sustancias, las normas nos requieren que reportemos solo aquellas que se encuentran en el agua. La primer columna en la tabla de la calidad de agua muestra la lista de las sustancias detectadas en el agua. La siguiente columna muestra la lista de la concentracion promedio y el rango de concentraciones que se hallan encontrado en el agua que usted toma. En seguida están las listas de el MCL, el PHG y el MCLG, si estos son apropiados. La última columna describe las probables fuentes y origen de las sustancias detectadas en el agua potable.

Para revisar la calidad de su agua de beber, compare los valores por encima del promedio, mínimos y máximos y el Nivel Contaminante Máximo. Revise todos los químicos que se encuentran por encima del Nivel Contaminante Máximo. Si los químicos sobrepasan el Nivel Contaminante Máximo no significa que sea detrimental a la salud de inmediato. Más bien, se requiere que se realizen análisis más frecuentemente en el abastecimiento del agua por un corto periodo. Si los resultados muestran sobrepasar el MCL, el agua debe ser tratada para remover esa sustancia, o el abastecimiento de esta debe decomisionarse.

¿PORQUÉ HAY TANTA PUBLICIDAD SOBRE LA CALIDAD DEL AGUA POTABLE?

Las fuentes del agua potable (de ambas agua de la llave y agua embotellada) incluye ríos, lagos, arroyos, lagunas, embalses, manantiales, y pozos. Al pasar el agua por la superficie de los suelos o por la tierra, se disuelven minerales que ocurren al natural, y en algunas ocasiones, material radioactivo, al igual que pueden levantar sustancias generadas por la presencia de animales o por actividades humanas.

Entre los contaminantes que pueden existir en las fuentes de agua se incluyen:

- Contaminantes microbiales como los virus y la bacteria, los que pueden venir de las plantas de tratamiento de aguas negras, de los sistemas sépticos, de las operaciones de jardinería, y de la vida salvaje.

- Contaminantes inorgánicos, como las sales y los metales, los cuales pueden ocurrir naturalmente o como resultado del desagüe pluvial, industrial, o de alcantarillado, producción de gas natural y petróleo, minas y agricultura.

- Pesticidas y herbicidas, los cuales pueden venir de varias fuentes tales como la agricultura, del desagüe pluvial, y de usos residenciales.

- Contaminantes de otras sustancias químicas orgánicas, incluyendo químicos orgánicos volátiles y sintéticos que son productos de procesos industriales y de la producción de petróleo, y que pueden provenir de las estaciones de gasolina, desagües pluviales urbanos, y agricultura aplicación y de sistemas sépticos.

- Contaminantes radioactivos, los cuales pueden ocurrir naturalmente o que pueden ser resultados de las actividades de la producción de gas natural y minería.

A fin de asegurar que el agua de la llave es segura para beber, la Agencia de Protección Ambiental de Los Estados Unidos (USEPA) y el Tablero de Control de Recursos de Echar agua Estatal (Bordo Estatal) prescriben regulaciones que limitan la cantidad de ciertos contaminantes en el agua proporcionada por sistemas de agua públicas. Las regulaciones de la Administración de Alimentos y Medicamentos de Estados Unidos y la ley de California también establecen límites para los contaminantes en el agua embotellada que brindan la misma protección para la salud pública.

Toda el agua potable, incluyendo el agua embotellada, puede contener cantidades pequeñas de ciertos contaminantes. La presencia de contaminantes no necesariamente indica que haya algún riesgo de salud. Para más información acerca de contaminantes y riesgos a la salud favor de llamar a la USEPA encargada de proteger el agua potable al teléfono (1-800-426-4791). Usted puede obtener más información sobre el agua potable al conectarse al Internet en los siguientes domicilios:

www.epa.gov/ground-water-and-drinking-water/safe-drinking-water-information
(el sitio Web del USEPA)

www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/Chemicalcontaminants.html
(sitio Web de Bordo Estatal)



Si presente, los niveles elevados del plomo pueden causar el problema de salud serio, sobre todo para mujeres embarazadas y niños. El plomo en el agua potable es principalmente de materiales y componentes asociados con líneas de servicios y a casafontanería. La Cuidad de Paramount es responsable de proporcionar el agua potable de alta calidad, pero no puede controlar la variedad de materiales usados en la fontanería de componentes. Cuando su agua ha estado sentándose durante varias horas, usted puede minimizar el potencial para la exposición de plomo limpiando con agua su grifo durante 30 segundos a 2 minutos antes de usar el agua para beber o cocinarse. Si usted está preocupado por el plomo en su agua, usted puede desear hacer probar su agua. La información en el plomo en el agua potable, probando métodos, y pasos que usted puede tomar para minimizar la exposición está disponible de la Línea directa de Agua Potable Segura o en www.epa.gov/safewater/lead.



¿DEBERÍA TOMAR OTRAS PRECAUCIONES?

Algunas personas pueden ser más vulnerables a los contaminantes en el agua potable que el público en general. Las personas que tienen problemas inmunológicos, o sea esas personas que estén en tratamiento por medio de quimoterapia cancerosa; personas que tienen órganos transplantados, o personas con SIDA o desordenes inmunológicos, personas de edad avanzada, y los bebés que son particularmente suseptibles a ciertas infecciones. Estas personas deben de consultar a sus proveedores de salud médica. Las guías de la USEPA/Centros de Control de Enfermedades aconsejan cómo disminuir los riesgos para prevenir la infección de Cryptosporidium y otros contaminantes microbiales están disponibles por teléfono de la USEPA encargada de proteger el agua potable al teléfono (1-800-426-4791).

VALORACIÓN DE SU ABASTECIMIENTO DE AGUA

MWD terminó un gravamen de sus fuentes del proyecto del agua del río y del estado de Colorado en 2002. Las fuentes del río de Colorado se consideran las más vulnerables a la reconstrucción, salida urbana/de la precipitación excesiva, aumentando la urbanización en la línea divisoria de las aguas, y las aguas residuales. Las fuentes del proyecto del agua del estado se consideran las más vulnerables a salida, a fauna, a agricultura, a reconstrucción y a las aguas residuales urbanas/de la precipitación excesiva. Una copia del gravamen se puede obtener por MWD que entra en contacto con en (213) 217-6000.

La ciudad de Paramount condujo un gravamen de sus fuentes de la agua subterránea en 2003. Grlas fuentes del oundwater se consideran las más vulnerables al proceso/almacenaje, galjanoplastia de metal/el acabar/el fabricar, tintoreros, gasolineras del automóvil, tiendas de cuerpo del automóvil, talleres de reparaciones del automóvil, yardas de la chatarra/del desecho/del salvamento, y plásticos/productores del producto químico/del petróleo de los sintéticos. Una copia de la Evaluación de la fuente de agua está disponible comunicándose con el Departamento de Obras Públicas de Paramount en publicworksdept@paramountcity.gov o llamando al (562) 220-2020.

¿CÓMO PUEDO PARTICIPAR EN LAS DECISIONES SOBRE ASUNTOS ACERCA DEL AGUA QUE ME PUEDAN AFECTAR ?

El público es agradable asistir a las reuniones de la Comisión de las obras públicas situadas en la ciudad pasillo, avenida de 16400 Colorado, Paramount, CA de Paramount 90723. Las reuniones se celebran en el primer jueves de cada mes en 6:00 P.M.

¿CÓMO ME PONGO EN CONTACTO CON MI AGENCIA DEL AGUA SI TENGO PREGUNTAS SOBRE LA CALIDAD DEL AGUA?

Si tiene preguntas específicas sobre la calidad del agua del grifo, por favor comuníquese con David Arellano al (562) 220-2020.

ALGUNAS EXTREMIDADES PROVECHOSAS DE LA CONSERVACIÓN DEL AGUA

- Arreglar los grifos que gotean en su hogar - excepto hasta 20 galones cada día por cada detenido de fugas
- Guardar entre 15 y 50 galones por cada vez que el lavado sólo cargas completas de ropa
- Ajuste sus regaderas de modo que el agua caiga en su césped / jardín, no la acera / calzada - excepto 500 galones por mes
- Utilice pajote orgánico alrededor de las plantas para reducir la evaporación - guardar cientos de galones por año
- Usar un cabezal de ducha eficiente de agua. Ellos son baratos, fáciles para instalar, y pueden salvarle hasta 750 galones por mes.

Visite www.espanol.epa.gov/watersense para obtener más información.

Visítenos en
www.paramountcity.gov

