

2019 Consumer Confidence Report

Water System Name: **MD-24 Teaford Meadows #2000552**

Report Date: 5-13-2020

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2019 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse [Madera County MD-24 Teaford Meadows] a [200 W. 4th St. Madera CA, 93637] para asistirlo en español.

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 [Madera County MD-24 Teaford Meadows]以获得中文的帮助:[200 W. 4th St. Madera CA, 93637][559-675-7811]

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa [Madera County MD-24 Teaford Meadows] o tumawag sa [559-675-7811] para matulungan sa wikang Tagalog.

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ [Madera County MD-24 Teaford Meadows] tại [200 W. 4th St. Madera CA, 93637] để được hỗ trợ giúp bằng tiếng Việt.

Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau [Madera County MD-24 Teaford Meadows] ntawm [200 W. 4th St. Madera CA, 93637] rau kev pab hauv lus Askiv.

Type of water source(s) in use: *Two wells drawing from deposits in fractured rocks*

Name & general location of source(s): *The wells, known as well#2 and well#4 are located within the District*

Drinking Water Source Assessment information: *A source water assessment was conducted for the Teaford wells in July 2002. While few contaminants were noted due to the remote location of the wells, the assessment identified other wells in the area as having the potential for outside contamination. Your system is already subject to a quarterly “**DO NOT DRINK ADVISORY**” due to the presence of naturally occurring contaminants. A copy of the complete assessment may be viewed at the Madera County Environmental Health Department or by requesting a summary of the assessment from Environmental Health at (559) 675-7823.*

Time and place of regularly scheduled board meetings for public participation: *Meetings are normally held twice per month on Tuesday at 9:00a.m. at the Board of Supervisors Chamber on 200 W 4th Street in Madera. Since the schedule varies call 675-7700 to confirm the meeting date or visit the County website, www.madera-county.com/supervisors to check the schedule and preview the agenda.*

For more information, contact: *Madera County Special Districts*

Phone: (559) 675-7811

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

Water Conservation Tips for Consumers

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- *Take short showers – a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath. Use a water-efficient showerhead. They are inexpensive, easy to install, and can save you up to 750 gallons a month.*
- *Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month*
- *Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.*
- *Fix leaking toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing or replacing it with a new, more efficient model can save up to 1,000 gallons a month.*
- *Water plants only when necessary Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.*

Teach your kids about water conservation to ensure a future generation that uses water wisely. For more information, visit www.epa.gov/watersense.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

| Microbiological Contaminants (complete if bacteria detected) | Highest No. of Detections | No. of Months in Violation | MCL | MCLG | Typical Source of Bacteria |
|---|------------------------------|-------------------------------|--|------|--------------------------------------|
| Total Coliform Bacteria (state Total Coliform Rule) | (In a mo.) 0 | 0 | 1 positive monthly sample | 0 | Naturally present in the environment |
| Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule) | (In the year) 0 | 0 | A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive | 0 | Human and animal fecal waste |
| <i>E. coli</i> (federal Revised Total Coliform Rule) | (In the year) 0 | 0 | (a) | 0 | Human and animal fecal waste |

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

| Lead and Copper (complete if lead or copper detected in the last sample set) | Sample Date | No. of Samples Collected | 90 th Percentile Level Detected | No. Sites Exceeding AL | AL | PHG | No. of Schools Requesting Lead Sampling | Typical Source of Contaminant |
|---|-------------|--------------------------|--|------------------------|-----|-----|---|---|
| Lead (ppb) | 8/2017 | 5 | 1.35 | 0 | 15 | 0.2 | Not applicable | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits |
| Copper (ppm) | 8/2017 | 5 | .104 | 0 | 1.3 | 0.3 | Not applicable | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
|--|----------------|-------------------|------------------------|------|---------------|--|
| Sodium (ppm) | 12/4/2017 | 21 | 19-23 | none | none | Salt present in the water and is generally naturally occurring |
| Hardness (ppm) | 12/4/2017 | 160 | 150-170 | none | none | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant |
|--|----------------|-------------------|------------------------|---------------|--------------------------|---|
| Arsenic (ppb) | 2019 | 45.7* | 9.5- 76 | 10 | .004 | Erosion of natural deposits; runoff from orchards; glass and electronics production waste |
| Flouride (ppm) | 12/4/2017 | .315 | .28-.35 | 2 | 1 | Erosion from natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| Combined Radium 226 & 228 (pCi/L) | 2015 | 1.8 | 1.8 | 5 | 0 | Erosion of natural deposits |
| Uranium (pCi/L) | 2018 | 8 | 8 | 20 | 0 | Erosion of natural deposits |
| Gross Alpha (pCi/L) | 2017 | 5.55 | 5.3-5.8 | 15 | 0 | Erosion of natural deposits |
| Nickel (ppb) | 3/26/14 | 44.2 | 1.0-87 | 100 | 12 | Erosion of natural deposits, discharge from metal factories |

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
|--|----------------|-------------------|------------------------|------|---------------|--|
| Color (Units) | 12/4/2017 | 2.5 | ND-5.0 | 15 | N/A | Naturally occurring organic materials |
| Chloride (ppm) | 12/4/2017 | 17.5 | 14-21 | 500 | N/A | Runoff/leaching from natural deposits; sea water influence |
| Turbidity (NTU) | 12/4/2017 | 1.29 | .18-2.4 | 5.0 | N/A | Soil runoff |
| Total Dissolved Solids (ppm) | 12/4/2017 | 275 | 260-290 | 1000 | N/A | Runoff / leaching from natural deposits |
| Specific Conductance (uS/cm) | 12/4/2017 | 410 | 390-430 | 1600 | N/A | Substances that form ions when in water; sea water influence |
| Iron (ppb) | 2019 | 180 | 180 | 300 | N/A | Leaching from natural deposits; industrial waste |
| Manganese (ppb) | 2019 | 71* | 46- 100 | 50 | N/A | Leaching from natural deposits |
| Sulfate (ppm) | 12/4/2017 | 8 | 7.5-8.5 | 500 | N/A | Runoff/ leaching from natural deposits; industrial wastes |

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More

information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [*Madera County MD-24*] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [**OPTIONAL:** If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

| VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT | | | | |
|---|---|-------------------------|---|--|
| Violation | Explanation | Duration | Actions Taken to Correct the Violation | Health Effects Language |
| Arsenic | Naturally occurring ground water | The year of 2019 | Design a treatment facility, Drilled a test well | Some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems, and may have an increased risk of getting cancer. |
| Manganese | Naturally occurring ground water | The year of 2019 | Design a treatment facility, Drilled a test well | The notification level for manganese is used to protect consumers from neurological effects. High levels of manganese in people have been shown to result in effects of the nervous system. |