

2025 Consumer Confidence Report

Water System Information

Water System Name: **WHISPERING PINES MHP**

Report Date: 5/31/2026

Type of Water Source(s) in Use: 2- Ground water wells

Name and General Location of Source(s): Well 4: Primary well, located on-site in roadway entrance
Well 5: Companion well located in RV area

Drinking Water Source Assessment Information: See last page.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: NA

For More Information, Contact: Eric Shearer - WS Operator @ 559.676.8773 or
Mike Boland – Business OPS @ 559.855.6259
Zachary Hamman at: (209) 793-1145

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2025, and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Whispering Pines a 559.676.8773 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Whispering Pines 以获得中文的帮助: 31511 Ridgewood Way- North Fork, CA 93643 -- 559.676-8773.

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa 31511 Ridgewood Way – North Fork, CA 93643 o tumawag sa 559.676.8773 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Whispering Pines tại 559.676.8773 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Whispering Pines ntawm 559.676.8773 rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variations and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(In the year) 0	0	0	0	Human and animal fecal waste
<i>Total Coliforms</i>	1	1	(b)	0	May be naturally present in the environment

(b) On 10/8/2025 our water system was required to complete a level 1 assessment due to a Coliform positive on repeat samples. As part of the assessment the potential problem was identified and corrected.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	7/17/24	5	0.0006	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	7/17/24	5	0.129	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Well 4, Well 5

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	4/16/24	17	16 - 18	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	4/16/24	120	110 - 130	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium,

						and are usually naturally occurring
--	--	--	--	--	--	-------------------------------------

Table 4. Detection of Contaminants with a Primary Drinking Water Standard well 4, well 5

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Nitrate (ppm)	7/24/25	2.2	1.4-2.9	10	10	Runoff & leaching from fertilizer use; leaching from septic tanks & sewage; erosion of natural deposits
Gross Alpha (pCi/L)	2018, 2024	2.99	2.5 – 3.48	15	(0)	Erosion of natural deposits
Chromium (µg/L)	4/2024	1.55	1.5 – 1.6	50	(100)	Discharge from steel & pulp mills & chrome plating; erosion of natural deposits
Barium (ppm)	4/2024	0.0312	0.0073-0.055	1	2	Discharge of oil drilling wastes & from metal refineries; erosion of natural deposits
Chromium, Hex (ug/L)	5/12/25	0.085	0.073-0.097	10	0.02	Erosion of natural deposits; transformation of naturally occurring trivalent chromium to hexavalent chromium by natural processes and human activities such as discharges from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities.

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard well 4, well 5

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMC L	PHG (MCLG)	Typical Source of Contaminant
Aluminum (ppb)	4/2024	10	-	200	-	Erosion of natural deposits; residual from some surface water treatment processes
Chloride (ppm)	4/2024	10.5	7.0 - 14	500	--	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	4/2024	5.15	4.5 – 5.8	500	--	Runoff/leaching from natural deposits; industrial wastes
Specific Conductance (µS/cm)	4/2024	340	330 - 350	1600	--	Substances that form ions when in water; seawater influence
Total Dissolved Solids TDS (ppm)	4/2024	230	230 - 230	1000	--	Runoff/leaching from natural deposits
Copper (ppm)	4/2024	0.0063	-	1.0	--	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Odor-Threshold (Units)	4/2024	1.0	1.0 – 1.0	3	--	Naturally-occurring organic materials
Zinc (ppm)	4/2024	0.0085	0.0069-0.010	5.0		Runoff/leaching from natural deposits; industrial wastes

Note: There are no PHGs, MCLGs, or mandatory standard health effects language for these constituents because secondary MCLs are set on the basis of aesthetic concerns.

Table 6. Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Perfluorohexanoic Acid (PFHXA) (ng/L)	8/18/25	3.5	2.9-4.1	N/A	N/A
Perfluorohexane Sulfonic Acid (PFHXS) (ng/L)	8/18/25	2.4	2.3-2.5	N/A	N/A
Perfluorobutanesulfonic Acid (PFBS) (ng/L)	8/18/25	7.3	4.8-9.7	N/A	N/A

Perfluorooctanoic Acid (PFOA) (ng/L)	8/18/25	4.7	4.6-4.8	N/A	N/A
Perfluorooctane Sulfonic Acid (PFOS) (ng/L)	8/18/25	2.1	N/A	N/A	N/A
Perfluoropentanoic acid (PFPeA) (ng/L)	8/18/25	2.4	1.8-3.0	N/A	N/A
Perfluoroheptanoic acid (PFHpA) (ng/L)	8/18/25	2.25	2.2-2.3	N/A	N/A

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Whispering Pines](#) is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

Drinking Water Source Assessment Information

On June 6, 2022 our water system had a compliance inspection by the LPA- Madera County Environmental Health Dept. Other inspections were performed in 2008, 2009, 2013, 2016, 2019, and 2020 including a Sanitary Survey in 2018 and in June 2022. The drinking water sources as described in the latest assessment are considered most vulnerable to the on-site sewage-septic system, possible cross connection, agricultural and storm drainage. All water quality testing has not shown any contamination from septic systems or drainage. For more information on system operation or monitoring, contact Madera County Environmental Health – water Division at 200 W.4th Street – Suite 3100 – Madera, CA 93637 ph 559.675.7823 or Operators.