

2019 Consumer Confidence Report

Water System Name: **Oakhurst/Sierra Lakes**Report Date: **6/5/2020**

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2019 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Hillview Water Co., Inc a 559-683-4322 para asistirlo en español.

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Hillview Water Co., Inc 以获得中文的帮助: 40312 Greenwood Way 559-683-4322

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Hillview Water Co., Inc 40312 Greenwood Way o tumawag sa 559-683-4322 para matulungan sa wikang Tagalog.

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Hillview Water Co., Inc tại 559-683-4322 để được hỗ trợ giúp bằng tiếng Việt.

Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Hillview Water Co., Inc] ntawm 559-683-4322 rau kev pab hauv lus Askiv.

Type of water source(s) in use: **Hard rock wells which draw from underground fractures.**Name & general location of source(s): **Sierra Lakes – Wells #1A, #3, #4, #5, #6, #7, #8 & #9; Oakhurst – Junction Wells #1 & #2; Forest Ridge – Ditton Wells #1, #2 & #3, Forest Ridge #4, #5, #6 & #7; Quail Meadows- Wells # 2, #3 & #4.**

Drinking Water Source Assessment information: **Done using the default Groundwater System Method on February 3, 2003. The following sources of information were used in the assessment: Water system and SWRCB files. The water systems completed the PCA's for this source. Procedures used to conduct the assessment: Water system and SWRCB files. The water systems completed the PCA's for this source. Procedures used to conduct the assessment include: PCA inventories, well data sheets, and GPS survey completed and conducted by Waterboards District staff. The source is considered most vulnerable to the following activities not associated with any detected contaminants: illegal activities /unauthorized dumping, sewer collection system, automobile – gas stations, septic systems – high density, septic systems – low density. A copy of the complete assessment may be viewed at the Hillview Water Company, Inc. 40312 Greenwood Way, Oakhurst, CA 93644. You may request a summary of the assessment be sent to you by contacting Jim Foster (559)683-4322, PO Box 2269, Oakhurst, CA 93644.**

Time and place of regularly scheduled board meetings for public participation: **Hillview Water Company, Inc does not Hold regularly scheduled meetings. The public is allowed to participate in all CPUC proceedings.**

For more information, contact: **Hillview Water Company, Inc. Phone: (559)683-4322**

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG):

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

! *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

! *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

! *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

! *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.

! *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4 and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a month) 1	0	1 positive monthly sample ^(a)	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year) 0	0	(b)	0	Human and animal fecal waste

(a) Two or more positive monthly samples is a violation of the MCL

(b) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requiring Lead Sampling	Typical Source of Contaminant
Lead (ppb)	7/15/19	10	0	0	15	0.2		Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	7/15/19	10	0.24	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	4/30/18 7/25/18 9/19/18	62	13 - 220	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	4/30/18 7/25/18 9/19/18	205	57 - 620	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG)	Typical Source of Contaminant

					IRDLGL	
Arsenic	January – December	2.7	ND – 8.5	10	.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes.
Chlorine	January – December	1.23	1.03 – 1.37	4.0	4.0	Drinking water disinfectant added for treatment.
Chromium (ppb)	12/11/19	ND	ND	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits.
Fluoride (ppm)	12/11/19	.32	D – 56	2	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Haloacetic Acids (five) (HAA5) (ppb)	6/18/19	ND	ND	60	NA	By-product of drinking water disinfection.
Nitrate (as Nitrogen) - ppm	January – December	.85	ND – 7.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks, sewage, erosion from natural deposit.
Tetrachloroethylene (PCE) (ppb)	Jan, Feb, Oct & Dec	.1	1.2	5	0.6	Discharge from factories, dry cleaners, and auto shops (metal degreaser)
Toluene (ppb)	Jan, Feb, Sept, Oct, Dec	ND	ND	150	150	Discharge from petroleum and chemical factories; underground gas tank leaks.
TTHM's (Total Trihalomethanes) (ppb)	6/18/19	1.8	1.8	80	NA	By-product of drinking water disinfection.
Uranium – pCi/L	January – December	6.7	1.13- 19.3	20	.43	Erosion of natural deposits.

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	4/30/18 7/25/18 9/19/18	24	5.5 – 710	500	NA	Runoff/leaching from natural deposits; seawater influence.
Color - units	4/30/18 7/25/18 9/19/18	3	0 - 50	15	N/A	Naturally-occurring organic materials.
Iron (ppb)	January – December	19	ND – 130	300	NA	Leaching from natural deposits
Manganese - ppb	January – December	11.8	ND – 36	50	NA	Leaching from natural deposits.
Specific Conductance (uS/cm)	12/11/19	376	170 – 3,000	1,600	NA	Substances that form ions when in water; seawater influence
Sulfate (ppm)	4/30/18 7/25/18 9/19/18	28.6	ND - 91	500	NA	Runoff/ leaching from natural deposits; Industrial wastes.
Total Dissolved Solids (TDS) - ppm	4/30/18 7/25/18 9/19/18	349	170 – 1,500	1000	NA	Runoff/ leaching from natural deposits
Turbidity (Units)	4/30/18 7/25/18 9/19/18	2	0.12 – 22	5	NA	Soil runoff.
Zinc (ppm)	4/30/18 7/25/18 9/19/18	77	ND – 1,500	5	NA	Runoff/leaching from natural deposits; industrial wastes.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hillview Water Company, Inc. is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for

drinking or cooking. If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.