

## 2021 Consumer Confidence Report

### Water System Information

Water System Name: **MPWD-Coulterville CSA-1**

Report Date: **5/26/2022**

Type of Water Source(s) in Use: **Groundwater**

Name and General Location of Source(s): **Well # 1**

Drinking Water Source Assessment Information: **A source water assessment was conducted in April 2003. The source is considered most vulnerable to the following activities not associated with any detected contaminants: sewer collection system, RV Parks, and Historic automobile gas stations.**

Time and Place of Regularly Scheduled Board Meetings for Public Participation: **Every Tuesday 9 am except the 5 Tuesday of a month at the Mariposa County Board of Supervisors office, 5100 Bullion Street, 2nd Floor Mariposa, CA 95338** [Contact: Mariposa County Public Works Department for more information on the advisory committee and for dates & times of meetings **209-966-5356**.

For More Information, Contact: **Mariposa County Public Works Department for more information on the advisory committee 209-966-5356**

### About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2021 and may include earlier monitoring data.

### Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse **[MPWD-Coulterville CSA 1] a [4639 Ben Hur Rd. Mariposa, CA 95338 [209-966-5356]** para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 [Enter Water System Name]以获得中文的帮助: **[MPWD-Coulterville CSA 1] a [4639 Ben Hur Rd. Mariposa, CA 95338 [209-966-5356]**].

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa **[MPWD-Coulterville CSA 1] a [4639 Ben Hur Rd. Mariposa, CA 95338]** o tumawag sa **[209-966-5356]** para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ **[MPWD-Coulterville CSA 1]** tại **[4639 Ben Hur Rd. Mariposa, CA 95338 (209)966-5356]** để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau **[MPWD-Coulterville CSA 1]** ntawm **[4639 Ben Hur Rd. Mariposa, CA 95338 (209)966-5356]** rau kev pab hauv lus Askiv.

## Terms Used in This Report

| Term   | Definition  |
|--|---|
| Level 1 Assessment                               | A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.   |
| Level 2 Assessment                               | A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions. |
| Maximum Contaminant Level (MCL)                  | The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.            |
| Maximum Contaminant Level Goal (MCLG)            | The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).  |
| Maximum Residual Disinfectant Level (MRDL)       | The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.   |
| Maximum Residual Disinfectant Level Goal (MRDLG) | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.  |
| Primary Drinking Water Standards (PDWS)          | MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.  |
| Public Health Goal (PHG)                         | The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.  |
| Regulatory Action Level (AL)                     | The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.  |
| Secondary Drinking Water Standards (SDWS)        | MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.   |
| Treatment Technique (TT)                         | A required process intended to reduce the level of a contaminant in drinking water.   |
| Variances and Exemptions                         | Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.  |
| ND   | Not detectable at testing limit.  |
| ppm  | parts per million or milligrams per liter (mg/L)  |
| ppb  | parts per billion or micrograms per liter (µg/L)  |

| Term  | Definition   |
|-------|--|
| ppt   | parts per trillion or nanograms per liter (ng/L)   |
| ppq   | parts per quadrillion or picogram per liter (pg/L) |
| pCi/L | picocuries per liter (a measure of radiation)      |

## Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

## Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

## About Your Drinking Water Quality

### Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

**Table 1. Sampling Results Showing the Detection of Coliform Bacteria**

Complete if bacteria are detected.

| Microbiological Contaminants | Highest No. of Detections | No. of Months in Violation | MCL | MCLG | Typical Source of Bacteria   |
|------------------------------|---------------------------|----------------------------|-----|------|------------------------------|
| <i>E. coli</i>               | (0)                       | [0]                        | (a) | 0    | Human and animal fecal waste |

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**Table 1.A. Compliance with Total Coliform MCL between January 1, 2021 and June 30, 2021 (inclusive)**

| Microbiological Contaminants      | Highest No. of Detections | No. of Months in Violation | MCL                           | MCLG | Typical Source of Bacteria           |
|-----------------------------------|---------------------------|----------------------------|-------------------------------|------|--------------------------------------|
| Total Coliform Bacteria           | (0)                       | [0]                        | 1 positive monthly sample (a) | 0    | Naturally present in the environment |
| Fecal Coliform and <i>E. coli</i> | (0)                       | [0]                        | 0                             | None | Human and animal fecal waste         |

(a) For systems collecting fewer than 40 samples per month: two or more positively monthly samples is a violation of the total coliform MCL

(b) For violation of the total coliform MCL, include potential adverse health effects, and actions taken by water system to address the violation: [Enter information]

**Table 2. Sampling Results Showing the Detection of Lead and Copper**

Complete if lead or copper is detected in the last sample set.

| Lead and Copper | Sample Date | No. of Samples Collected | 90 <sup>th</sup> Percentile Level Detected | No. Sites Exceeding AL | AL   | PHG | No. of Schools Requesting Lead Sampling | Typical Source of Contaminant   |
|-----------------|-------------|--------------------------|--|------------------------|------|-----|---|---|
| Lead (ppb)      | 9-23-2021   | 6                        | 1.4  | 0                      | 15   | 0.2 | [0]                                     | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits |
| Copper (ppb)    | 9-23-2021   | 6                        | 144  | 0                      | 1300 | 300 | Not applicable                          | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives               |

**Table 3. Sampling Results for Sodium and Hardness**

| <b>Chemical or Constituent (and reporting units)</b> | <b>Sample Date</b> | <b>Level Detected</b> | <b>Range of Detections</b> | <b>MCL</b> | <b>PHG (MCLG)</b> | <b>Typical Source of Contaminant</b>   |
|--|--------------------|-----------------------|----------------------------|------------|-------------------|--|
| Sodium (ppm)   | 7-26-2021          | 16                    |                            | None       | None              | Salt present in the water and is generally naturally occurring   |
| Hardness (ppm)                                       | 7-26/2021          | 320                   |                            | None       | None              | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

**Table 4. Detection of Contaminants with a Primary Drinking Water Standard**

| <b>Chemical or Constituent (and reporting units)</b> | <b>Sample Date</b> | <b>Level Detected</b> | <b>Range of Detections</b> | <b>MCL [MRDL]</b> | <b>PHG (MCLG) [MRDLG]</b> | <b>Typical Source of Contaminant</b>  |
|--|--------------------|-----------------------|----------------------------|-------------------|---------------------------|---|
| Arsenic (ppb)  | 2021               | 10.48                 | 5.4-13                     | 10                | 0.004                     | Erosion of natural deposits; runoff from orchards; glass and electronics production wastes                  |
| Chlorine (ppm)                                       | Monthly 2021       | 0.68                  | 0.2-1.3                    | 4.0               | 4.0                       | Drinking water disinfectant added for treatment   |
| Nitrate (as nitrogen, N) (ppm)                       | 2021               | 4.08                  | 2.1-6.8                    | 10                | 10                        | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits |
| Barium (ppb)   | 7/26/2021          | 42                    |                            | 1000              | 2000                      | Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits                     |
| Nickel (ppb)   | 7/26/2021          | 3.5                   |                            | 100               | 10                        | Erosion of natural deposits; discharge from metal factories   |
| TTHMs (Total Trihalomethanes) (ppb)                  | 8-31-2020          | 0.5                   |                            | 80                | N/A                       | Byproduct of drinking water disinfection  |
| Gross Alpha Particle Activity (pCi/L)                | 8-31-2020          | 1.58                  |                            | 15                | (0)                       | Erosion of natural deposits   |

**Table 5. Detection of Contaminants with a Secondary Drinking Water Standard**

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | SMCL | PHG (MCLG) | Typical Source of Contaminant                               |
|---|-------------|----------------|---------------------|------|------------|---|
| Chloride (ppm)                                | 7/26/2021   | 33             |                     | 500  |            | Runoff/leaching from natural deposits; seawater influence   |
| Specific Conductance (µS/cm)                  | 7/26/2021   | 630            |                     | 1600 |            | Substances that form ions when in water; seawater influence |
| Odor—Threshold (Units)                        | 7/26/2021   | 1              |                     | 3    |            | Naturally-occurring organic materials                       |
| Sulfate (ppm)                                 | 7/26/2021   | 34             |                     | 500  |            | Runoff/leaching from natural deposits; industrial wastes    |
| Total Dissolved Solids (TDS)                  | 7/26/2021   | 420            |                     | 1000 |            | Runoff/leaching from natural deposits                       |
| Turbidity (Units)                             | 7/26/2021   | 0.12           |                     | 5    |            | Soil runoff   |
| Zinc (ppb)                                    | 7/26/2021   | 190            |                     | 5000 |            | Runoff/leaching from natural deposits; industrial wastes    |

**Table 6. Detection of Unregulated Contaminants**

| Chemical or Constituent (and reporting units) | Sample Date  | Level Detected | Range of Detections | Notification Level | Health Effects |
|---|--------------|----------------|---------------------|--------------------|----------------|
| Not Required to Test                          | Not Required | Not Required   | Not Required        | Not Required       | Not Required   |

**Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. **(Coulterville CSA#1) via Mariposa County Public Works Department** is responsible for providing high quality drinking water

but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*:

**Some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems and may have an increased risk of getting cancer.**

**While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.**

**Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and/or flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the U.S. EPA Safe Drinking Water Hotline (1 800-426-4791).**

**Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.**

***Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity.***

***The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.***

**This Consumer Confidence Report (CCR) reflects changes in drinking water regulatory requirements during 2021. These revisions add the requirements of the federal Revised Total Coliform Rule, effective since April 1, 2016, to the existing state Total Coliform Rule. The revised rule maintains the purpose to protect public health by ensuring the integrity of the drinking water distribution system and monitoring for the presence of microbials (i.e., total coliform and E. coli bacteria). The U.S. EPA anticipates greater public health protection as the rule requires water systems that are vulnerable to microbial contamination to identify and fix**



problems. Water systems that exceed a specified frequency of total coliform occurrences are required to conduct an assessment to determine if any sanitary defects exist. If found, these must be corrected by the water system. The state Revised Total Coliform Rule became effective July 1, 2021.

### Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement

| Violation  | Explanation                                    | Duration      | Actions Taken to Correct Violation  | Health Effects Language  |
|--|--|---------------|---|--|
| Revised Total Coliform Rule Monitoring Reporting Violation | Failed to collect the required monthly samples | February 2022 | Immediately collect the required samples in March 2022 with test results of (ND) for March 2022 | We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During [February 2022], we [ <i>did not monitor or test</i> or <i>did not complete all monitoring or testing</i> ] for [ <i>Total Coliform</i> and therefore, cannot be sure of the quality of your drinking water during that time. |

### For Water Systems Providing Groundwater as a Source of Drinking Water

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples

| Microbiological Contaminants<br>(complete if fecal-indicator detected) | Total No. of<br>Detections | Sample<br>Dates | MCL<br>[MRDL] | PHG<br>(MCLG)<br>[MRDLG] | Typical Source of<br>Contaminant |
|--|----------------------------|-----------------|---------------|--------------------------|----------------------------------|
| <i>E. coli</i>   | (0)                        | 0               | 0             | (0)                      | Human and animal fecal waste     |
| Enterococci  | (0)                        | 0               | TT            | N/A                      | Human and animal fecal waste     |
| Coliphage  | (0)                        | 0               | TT            | N/A                      | Human and animal fecal waste     |

### Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT

**Special Notice of Fecal Indicator-Positive Groundwater Source Sample:** [None]

**Special Notice for Uncorrected Significant Deficiencies:** [[None]

**Table 9. Violation of Groundwater TT**

| Violation | Explanation | Duration | Actions Taken to<br>Correct Violation | Health Effects<br>Language |
|-----------|-------------|----------|---------------------------------------|----------------------------|
| None      | None        | None     | None                                  | None                       |

### Summary Information for Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

#### Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct **[NO Level 1 Assessments]**.

During the past year **[NO Level 2 Assessment]** were required to be completed for our water system.