



ROGINA WATER COMPANY
PUBLIC WATER SYSTEM NUMBER 2310002
MAY 1, 2020

2019 CONSUMER CONFIDENCE REPORT

General Manager: Mr. Daniel Rogina ~ Phone: (707) 462-4056

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2019.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Rogina Water Company Drinking Water Source Information:

- Type of Water Source in Use:** Groundwater
Name & Location of Sources: Well 02, Deep well, adjacent to the Russian River
 Well 04, Deep well, adjacent to the Russian River
 Well 05, Deep well, adjacent to the Russian River
 Well 06, Deep well, adjacent to the Russian River
 Well 07, Deep well, adjacent to the Russian River



Contact Information

For further information, please contact:
 Mr. Daniel Rogina
 (707) 462-4056

Drinking Water Source Assessment Information:

An assessment of the drinking water sources for Rogina Water Company determined that all wells are located in an unconfined aquifer adjacent to the Russian River. This location lies between a commercial gravel mining operation and vineyard. The sources are considered most vulnerable to the presence of sand and gravel mining activities. A copy of the complete assessment is available at the Rogina Water Company office, or at the California State Water Board, Division of Drinking Water, 50 D St, Rm 200, Santa Rosa, CA 95404. Their phone number is (707) 576-2145.

General Drinking Water Source Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.

Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Definitions of Terms Used in This Report

Maximum Contaminant Level (MCL):

The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG):

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG):

The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL):

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG):

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect

the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS):

MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT):

A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL):

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions:

Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: Not detectable at testing limit.

ppm: parts per million or milligrams per liter (mg/L).

ppb: parts per billion or micrograms per liter (µg/L).

pCi/L: picocuries per liter (a measure of radiation).

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline @ 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline @: (1-800-426-4791).

Important Notice Regarding Lead for Community Water Systems

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Rogina Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline: <http://www.epa.gov/safewater/lead>.

Summary Information for Violation of a MCL,MRDL, AL, TT, or Monitoring and Reporting Requirement: **None.**

Tables 1, 2, 3, 4 AND 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1—SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

** Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report*

Microbiological Contaminants	Highest # of Detections	# of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment

TABLE 2—SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

In 2019 We Received Zero Requests to Sample for Lead and Copper at Schools Serviced by Rogina Water Company

Lead and Copper	No. of Samples Collected (2017)	90th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Copper (ppm)	20	0.77	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3—SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2018-2019	13.32	9.0-28.0	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2018-2019	113.6	101-121	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Chlorine (ppm)	2019	0.32	0.28-0.33	[MRDL= 4.0 (as Cl ₂)]	[MRDLG= 4 (as Cl ₂)]	Drinking water disinfectant added for treatment
Gross Alpha (PCi/L)	2013-2016	0.32	ND-1.6	15	(0)	Erosion of natural deposits
Radium 228 (pCi/L)	2013	0.34	0.13-0.54	5	.019	Erosion of natural deposits
Radium 226 (pCi/L)	2010	0.26	-	5	.05	Erosion of natural deposits
TTHM[Total Trihalo-methanes](ppb) -Bromodichloromethane -Chloroform (Trichloromethane) -Dibromochloromethane	2019 2019 2019 2019	7.41 2.35 3.48 1.58	- - - -	80	n/a	By-product of drinking water disinfection
HAA5's [Haloaceticacids (5)] (ppb) -Trichloroacetic Acid	2019 2019	1.5 1.5	- -	60	n/a	By-product of drinking water disinfection
Barium (ppm)	2018-2019	0.046	ND-0.13	1	2	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (ppm)	2018-2019	0.024	ND-0.12	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Aluminum (ppm)	2018-2019	0.032	ND-0.09	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes

TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG	Typical Source of Contaminant
Chloride (ppm)	2018-2019	5.32	4.1-7.0	500	-	Runoff/leaching from natural deposits; seawater influence
Color	2018-2019	1.4	ND-7	15	-	Naturally-occurring organic materials
Specific Conductance (uMho)	2018-2019	266	220-310	1,600	-	Substances that form ions when in water; seawater influence
Sulfate (ppm)	2018-2019	10.02	6.8-14	500	-	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (TDS) (ppm)	2018-2019	146	120-180	1000	-	Runoff/leaching from natural deposits
Turbidity (units)	2018-2019	1.42	0.13-6.3	5	-	Soil Runoff
Manganese (ppb)	2018-2019	15	ND-75	50	-	Leaching from natural deposits
Aluminum (ppb)	2018-2019	31.8	ND-88	200	-	Erosion of natural deposits; residue from some surface water treatment processes

