

2025 Consumer Confidence Report

Water System Information

Water System Name: **Esalen #2701295**

Report Date: 6/10/26

Type of Water Source(s) in Use: Surface Water

Name and General Location of Source(s): Porter Springs Creek

Drinking Water Source Assessment Information: Most of the sampling results listed in Tables 3, 4, and 5 within this report are from untreated surface water. All of the untreated surface water then passes through a Treatment Plant before being delivered to the customer.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: N/A

For More Information, Contact: Carmel Lahaina Utility Services, Inc. (831) 659-3595

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2025, and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Esalen #2701295 a Carmel Lahaina Utility Services, Inc. (831) 659-3595 para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Esalen #2701295 以获得中文的帮助: Carmel Lahaina Utility Services, Inc. (831) 659-3595

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Esalen #2701295 o tumawag sa Carmel Lahaina Utility Services, Inc. (831) 659-3595 para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Esalen #2701295 tại Carmel Lahaina Utility Services, Inc. (831) 659-3595 để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Esalen #2701295 ntawm Carmel Lahaina Utility Services, Inc. (831) 659-3595 rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Term	Definition
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per billion or micrograms per liter (µg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(In the year 2025) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Complete if lead or copper is detected in the last sample set.

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	Range of Results	AL	PHG	Typical Source of Contaminant
Lead (ppb)	2025	5	8	0	ND-14.8	15	0.2	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	2025	5	0.025	0	ND-0.027	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2024	9	9	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2024	188	188	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent	Reporting Unit	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Arsenic	ppb	2024	ND	ND	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium (Previously reported as ppm. Changed unit to ppb.)	ppb	2024	9	9	1000	2000	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium	ppb	2024	ND	ND	50	100	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride	ppm	2024	0.11	0.11	2	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead	ppb	2024	ND	ND	AL=15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Nitrate as N	ppm	2025	0.03	ND-0.10	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium	ppb	2024	ND	ND	50	50	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)

Table 4. Detection of Contaminants with a Primary Drinking Water Standard (Cont'd)

Chemical or Constituent	Reporting Unit	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Haloacetic Acids	ppb	2025	ND	ND	60	N/A	By-product of drinking water chlorination
TTHMs (Total Trihalomethanes)	ppb	2025	6	6	80	N/A	By-product of drinking water chlorination
Trichloropropane (1,2,3-TCP)	ppb	2025	ND	ND	5 ppt	N/A	Discharge from industrial and agricultural chemical factories; leaching from hazardous waste sites; used as cleaning and maintenance solvent, paint and varnish remover, and cleaning and degreasing agent; byproduct during the production of other compounds and pesticides.

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent	Reporting Unit	Sample Date	Level Detected	Range of Detections	SMCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Color	Units	2024	5	5	15	N/A	Naturally-occurring organic materials
Copper	ppm	2024	ND	ND	1	N/A	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Iron	ppb	2024	ND	ND	300	N/A	Leaching from natural deposits; industrial wastes
Manganese	ppb	2024	ND	ND	50	N/A	Leaching from natural deposits
Odor-Threshold	Units	2024	ND	ND	3		Naturally-occurring organic materials
Turbidity	Units	2024	0.15	.015	5	N/A	Soil runoff
Zinc	ppm	2024	ND	ND	5	N/A	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (TDS)	ppm	2024	226	226	1000	N/A	Runoff/leaching from natural deposits

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard (Cont'd)

Chemical or Constituent	Reporting Unit	Sample Date	Level Detected	Range of Detections	SMCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Specific Conductance	µS/cm	2024	400	400	1600	N/A	Substances that form ions when in water; seawater influence
Chloride	ppm	2024	8	8	500	N/A	Runoff/leaching from natural deposits; seawater influence
Sulfate	ppm	2024	23	23	500	N/A	Runoff/leaching from natural deposits; industrial wastes

*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Esalen #2701295 is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Carmel Lahaina Utility Services, Inc. at (831) 659-3595. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

A lead service line inventory has been prepared in 2024. If you would like to access the report, hard copy information is available in the water system office.

For Water Systems Providing Groundwater as a Source of Drinking Water

Table 6. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year) 3	2025	0	(0)	Human and animal fecal waste
Enterococci	(In the year) 0	2025	TT	N/A	Human and animal fecal waste
Coliphage	(In the year) 0	2025	TT	N/A	Human and animal fecal waste

Table 7. Violation of Groundwater TT

Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
E. coli	On 4/9/25, Porter Springs, a groundwater source, had a positive result of 3 for E. coli.	A subsequent test was taken on 5/28/25 with a negative result for E. coli.	All sources (groundwater and surface water) are treated through a surface water treatment plant that removes fecal and total coliforms.	Human and animal fecal waste
E. coli	On 10/22/25, Porter Springs, a groundwater source, had a positive result of 3 for E. coli.	A subsequent test was taken on 12/17/25 with a negative result for E. coli.	All sources (groundwater and surface water) are treated through a surface water treatment plant that removes fecal and total coliforms.	Human and animal fecal waste
E. coli	On 11/12/25, Porter Springs, a groundwater source, had a positive result of 1 for E. coli.	A subsequent test was taken on 12/17/25 with a negative result for E. coli.	All sources (groundwater and surface water) are treated through a surface water treatment plant that removes fecal and total coliforms.	Human and animal fecal waste

For Systems Providing Surface Water as a Source of Drinking Water**Table 8. Sampling Results Showing Treatment of Surface Water Sources**

Treatment Technique ^(a) (Type of approved filtration technology used)	[Enter Treatment Technique]
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	<p>Turbidity of the filtered water must:</p> <p>1 – Be less than or equal to <u>0.1</u> NTU in 95% of measurements in a month.</p> <p>2 – Not exceed <u>1.0</u> NTU for more than eight consecutive hours.</p> <p>3 – Not exceed <u>5.0</u> NTU at any time.</p>
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	100%
Highest single turbidity measurement during the year	0.611
Number of violations of any surface water treatment requirements	0

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements**Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation**

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found zero coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct 0 (zero) Level 1 assessment(s). Zero Level 1 assessment(s) were completed. In addition, we were required to take 0 (zero) corrective actions and we completed 0 (zero) of these actions.

During the past year 0 (zero) Level 2 assessments were required to be completed for our water system 0 (zero) Level 2 assessments were completed. In addition, we were required to take 0 (zero) corrective actions and we completed 0 (zero) of these actions.

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

We were not required to complete a Level 2 assessment because we never found *E. coli* in our water system. In addition, we were required to take 0 (zero) corrective actions and we completed 0 (zero) of these actions.