

2020 Consumer Confidence Report

Water System Information

Water System Name: Monterey Mushrooms WS

Report Date: May 17 2021

Type of Water Source(s) in Use: Ground Water: Wells

Name and General Location of Source(s): Well #5 Potable Source. Well #4 Standby. Well#3 Irrigation. Well #2 Irrigation

Drinking Water Source Assessment Information: [Enter Drinking Water Source Assessment Information]

Time and Place of Regularly Scheduled Board Meetings for Public Participation: [Enter Time and Place of Regularly Scheduled Board Meetings for Public Participation]

For More Information, Contact: [Enter Water System's Contact Name and Phone Number]

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2020 and may include earlier monitoring data.

Importance of This Report Statement in Five Non-English Languages (Spanish, Mandarin, Tagalog, Vietnamese, and Hmong)

Language in Spanish: Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse [Enter Water System's Name] a [Enter Water System's Address or Phone Number] para asistirlo en español.

Language in Mandarin: 这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 [Enter Water System Name] 以获得中文的帮助: [Enter Water System's Address][Enter Water System's Phone Number].

Language in Tagalog: Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa [Enter Water System's Name and Address] o tumawag sa [Enter Water System's Phone Number] para matulungan sa wikang Tagalog.

Language in Vietnamese: Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ [Enter Water System's Name] tại [Enter Water System's Address or Phone Number] để được hỗ trợ giúp bằng tiếng Việt.

Language in Hmong: Tsaab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau [Enter Water System's Name] ntawm [Enter Water System's Address or Phone Number] rau kev pab hauv lus Askiv.

Terms Used in This Report

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Primary Drinking Water Standards (PDWS)	MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Secondary Drinking Water Standards (SDWS)	MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.
ND	Not detectable at testing limit.
ppm	parts per million or milligrams per liter (mg/L)
ppb	parts per million or milligrams per liter (mg/L)
ppt	parts per trillion or nanograms per liter (ng/L)
ppq	parts per quadrillion or picogram per liter (pg/L)
pCi/L	picocuries per liter (a measure of radiation)

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, 5, 6, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Complete if bacteria are detected.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (State Total Coliform Rule)	0	0	1 positive monthly sample ^(a)	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (State Total Coliform Rule)	0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive	None	Human and animal fecal waste
<i>E. coli</i> (Federal Revised Total Coliform Rule)	0	0	(b)	0	Human and animal fecal waste

(a) Two or more positive monthly samples is a violation of the MCL

(b) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.**Table 2. Sampling Results Showing the Detection of Lead and Copper**Complete if lead or copper is detected in the last sample set. **See attached CA Drinking Water Watch.**

Lead and Copper	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	[Enter Date]	[Enter No.]	[Enter No.]	[Enter No.]	15	0.2	[Enter No.]	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	[Enter Date]	[Enter No.]	[Enter No.]	[Enter No.]	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness. See Attached Monitoring Schedule

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	[Enter Date]	[Enter No.]	[Enter Range]	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	[Enter Date]	[Enter No.]	[Enter Range]	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard. See Attached Monitoring Schedule

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
[Enter Contaminant]	[Enter Date]	[Enter No.]	[Enter Range]	[Enter No.]	[Enter No.]	[Enter Source]
[Enter Contaminant]	[Enter Date]	[Enter No.]	[Enter Range]	[Enter No.]	[Enter No.]	[Enter Source]
[Enter Contaminant]	[Enter Date]	[Enter No.]	[Enter Range]	[Enter No.]	[Enter No.]	[Enter Source]

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard. See Attached Monitoring Schedule

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
[Enter Contaminant]	[Enter Date]	[Enter No.]	[Enter Range]	[Enter No.]	[Enter No.]	[Enter Source]
[Enter Contaminant]	[Enter Date]	[Enter No.]	[Enter Range]	[Enter No.]	[Enter No.]	[Enter Source]
[Enter Contaminant]	[Enter Date]	[Enter No.]	[Enter Range]	[Enter No.]	[Enter No.]	[Enter Source]

Table 6. Detection of Unregulated Contaminants. See Attached Monitoring Schedule

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
[Enter Contaminant]	[Enter Date]	[Enter No.]	[Enter Range]	[Enter No.]	[Enter Language]
[Enter Contaminant]	[Enter Date]	[Enter No.]	[Enter Range]	[Enter No.]	[Enter Language]
[Enter Contaminant]	[Enter Date]	[Enter No.]	[Enter Range]	[Enter No.]	[Enter Language]

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Enter Water System's Name] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

Additional Special Language for Nitrate, Arsenic, Lead, Radon, and *Cryptosporidium*: [Enter Additional Information Described in Instructions for SWS CCR Document]

Federal Revised Total Coliform Rule (RTCR): [Enter Additional Information Described in Instructions for SWS CCR Document]

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

Table 7. Violation of a MCL, MRDL, AL, TT or Monitoring Reporting Requirement. No Violations

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
[Enter Violation Type]	[Enter Violation Explanation]	[Enter Duration]	[Enter Actions Taken]	[Enter Language]
[Enter Violation Type]	[Enter Violation Explanation]	[Enter Duration]	Enter Actions Taken	[Enter Language]

For Water Systems Providing Groundwater as a Source of Drinking Water

Table 8. Sampling Results Showing Fecal Indicator-Positive Groundwater Source Samples. None Detected

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year) [Enter No.]	[Enter Dates]	0	(0)	Human and animal fecal waste
Enterococci	(In the year) [Enter No.]	[Enter Dates]	TT	N/A	Human and animal fecal waste
Coliphage	(In the year) [Enter No.]	[Enter Dates]	TT	N/A	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Groundwater Source Samples, Uncorrected Significant Deficiencies, or Violation of a Groundwater TT. N/A

Special Notice of Fecal Indicator-Positive Groundwater Source Sample: [Enter Special Notice of Fecal Indicator-Positive Groundwater Source Sample]

Special Notice for Uncorrected Significant Deficiencies: [Enter Special Notice for Uncorrected Significant Deficiencies]

Table 9. Violation of Groundwater TT

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
[Enter Violation]	[Enter Explanation]	[Enter Duration]	[Enter Actions]	[Enter Language]
[Enter Violation]	[Enter Explanation]	[Enter Duration]	[Enter Actions]	[Enter Language]

For Systems Providing Surface Water as a Source of Drinking Water**Table 10. Sampling Results Showing Treatment of Surface Water Sources. No Surface Water N/A**

Treatment Technique ^(a) (Type of approved filtration technology used)	[Enter Treatment Technique]
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	<p>Turbidity of the filtered water must:</p> <p>1 – Be less than or equal to [Enter Turbidity Performance Standard to Be Less Than or Equal to 95% of Measurements in a Month] NTU in 95% of measurements in a month.</p> <p>2 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded for More Than Eight Consecutive Hours] NTU for more than eight consecutive hours.</p> <p>3 – Not exceed [Enter Turbidity Performance Standard Not to Be Exceeded at Any Time] NTU at any time.</p>
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	[Enter No.]
Highest single turbidity measurement during the year	[Enter No.]
Number of violations of any surface water treatment requirements	[Enter No.]

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a Surface Water TT N/A**Table 11. Violation of Surface Water TT N/A**

Violation	Explanation	Duration	Actions Taken to Correct Violation	Health Effects Language
[Enter Violation]	[Enter Explanation]	[Enter Duration]	[Enter Actions]	[Enter Language]
[Enter Violation]	[Enter Explanation]	[Enter Duration]	[Enter Actions]	[Enter Language]

Summary Information for Operating Under a Variance or Exemption

[Enter Additional Information Described in Instructions for SWS CCR Document]

Summary Information for Federal Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct [Insert Number of Level 1 Assessments] Level 1 assessment(s). [Insert Number of Level 1 Assessments] Level 1 assessment(s) were completed. In addition, we were required to take [Insert Number of Corrective Actions] corrective actions and we completed [Insert Number of Corrective Actions] of these actions.

During the past year [Insert Number of Level 2 Assessment] Level 2 assessments were required to be completed for our water system. [Insert Number of Level 2 Assessments] Level 2 assessments were completed. In addition, we were required to take [Insert Number of Corrective Actions] corrective actions and we completed [Insert Number of Corrective Actions] of these actions.

[For Violation of the Total Coliform Bacteria TT Requirement, Enter Additional Information Described in Instructions for SWS CCR Document]

Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

We were required to complete a Level 2 assessment because we found *E. coli* in our water system. In addition, we were required to take [Insert Number of Corrective Actions] corrective actions and we completed [Insert Number of Corrective Actions] of these actions.

[For Violation of the *E. coli* TT Requirement, Enter Additional Information Described in Instructions for SWS CCR Document]

CA Drinking Water Watch

Links

Lead and Copper Next Sampling Due Dates

PS Code Transition

Water System Details

Water System Facilities

Water System No. :	CA2701940	Federal Type :	NTNC
Water System Name :	MONTEREY MUSHROOMS WS	State Type :	NTNC
Principal County Served :	MONTEREY	Primary Source :	GW
Status :	A	Activity Date :	08-01-2016
Distribution System Classification :	D1	Max Treatment Plant Classification :	TD

Monitoring Schedules

Monitoring Results

Monitoring Results By Analyte

Lead And Copper Sampling

Analyte Name	Required # Samples	Frequencies	Last Sampling Begin	Last Sampling End	Last 90th Percentile	Unit	Monitoring Period Begin Date	Monitoring Period End Date	Seasonal Collection Period	Next Sampling Due
COPPER, FREE	5	YR	09-17-2020	09-17-2020	0.2	MG/L	01-01-2021	12-31-2021	6/1 - 9/30	09-30-2021
LEAD	5	YR	09-17-2020	09-17-2020	0	MG/L	01-01-2021	12-31-2021	6/1 - 9/30	09-30-2021

- Summaries
- Next Sampling Due Dates
- All Lead Sampling Results
- All Copper Sampling Results

Violations/Enforcement Actions

Site Visits

Consumer Confidence Reports

Lead Service Line Documents

Return Links

Water System Search

County Map

Glossary

Contact Info

Monitoring Schedules for All Sampling Points Except Lead and Copper

Please click on the above link to view schedules of all sampling points (except lead and copper).

Monitoring Schedule for Individual Sampling Points

Please click on a PS Code below to view the monitoring schedule associated with it.

PS Code = Primary Station Code; used by laboratories to upload water quality data

WQM PS Code = (Water System Number)-(Sample Point ID)

CLIP PS Code* = (Water System Number)_(Facility ID)_(Sampling Point ID)

[Click here to bring back the list of sampling points.](#)

*CLIP PS Code = PS Code to be used by laboratories to upload water quality data when CLIP (California Laboratory Intake Portal) is implemented; estimated launch date mid- to late-2020.

**Please refer to the Stage 2 DBP Monitoring Plan Approval Letter for full sample point names.


1 of 2
Find | Next

DATE: 5/3/2021

STATE OF CALIFORNIA

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 2701940

NAME: MONTEREY MUSHROOMS WS

COUN

SOURCE NO: 004

NAME: WELL 05

CLAS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	CO
2701940 - 004	MONTEREY MUSHROOMS WS	004	WELL 05				
	IO INORGANIC						
	01105 ALUMINUM	0	UG/L	1000	50	2020/09/17	
	01097 ANTIMONY	0	UG/L	6	6	2020/09/17	
	01002 ARSENIC	0	UG/L	10	2	2020/09/17	
	01007 BARIUM	0	UG/L	1000	100	2020/09/17	
	01012 BERYLLIUM	0	UG/L	4	1	2020/09/17	
	01027 CADMIUM	0	UG/L	5	1	2020/09/17	
	01034 CHROMIUM (TOTAL)	13	UG/L	50	10	2020/09/17	
	00951 FLUORIDE (F) (NATURAL-SOURCE)	0.18	MG/L	2	.1	2020/09/17	
	71900 MERCURY	0	UG/L	2	1	2020/09/17	
	01067 NICKEL	0	UG/L	100	10	2020/09/17	
	A-031 PERCHLORATE	0	UG/L	6	4	2019/08/05	
	01147 SELENIUM	0	UG/L	50	5	2020/09/17	
	01059 THALLIUM	0	UG/L	2	1	2020/09/17	

Monitoring Schedules for All Sampling Points Except Lead and Copper

Please click on the above link to view schedules of all sampling points (except lead and copper).

Monitoring Schedule for Individual Sampling Points

Please click on a PS Code below to view the monitoring schedule associated with it.

PS Code = Primary Station Code; used by laboratories to upload water quality data

WQM PS Code = (Water System Number)-(Sample Point ID)

CLIP PS Code* = (Water System Number)_(Facility ID)_(Sampling Point ID)

[Click here to bring back the list of sampling points.](#)

*CLIP PS Code = PS Code to be used by laboratories to upload water quality data when CLIP (California Laboratory Intake Portal) is implemented; estimated launch date mid- to late-2020.

**Please refer to the Stage 2 DBP Monitoring Plan Approval Letter for full sample point names.


Find | Next



DATE: 5/3/2021

STATE OF CALIFORNIA

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 2701940

NAME: MONTEREY MUSHROOMS WS

COUN

SOURCE NO:

NAME: WELL 05

CLAS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE
2701940 - S1 004	REGULATED VOC					
	39180 TRICHLOROETHYLENE	0	UG/L	5	.5	2020/09/1
	34488 TRICHLOROFLUOROMETHANE FREON 11	0	UG/L	150	5	2020/09/1
	81611 TRICHLOROTRIFLUOROETHANE (FREON 113)	0	UG/L	1200	10	2020/09/1
	39175 VINYL CHLORIDE	0	UG/L	.5	.5	2020/09/1
	81551 XYLENES (TOTAL)	0	UG/L	1750	0.5	2020/09/1
	S2 REGULATED SOC					
	77443 1,2,3-TRICHLOROPROPANE (1,2,3-TCP)	0	UG/L	0.005	0.005	2020/01/2
	39730 2,4-D	0	UG/L	70	10	2020/09/1
	77825 ALACHLOR	0	UG/L	2	1	2020/09/1
	39033 ATRAZINE	0	UG/L	1	.5	2020/09/1
	38710 BENTAZON	0	UG/L	18	2	2020/09/1
	81405 CARBOFURAN	0	UG/L	18	5	2020/09/1
	78885 DIQUAT	0	UG/L	20	4	2020/09/1
	39055 SIMAZINE	0	UG/L	4	1	2020/09/1

Monitoring Schedules for All Sampling Points Except Lead and Copper

Please click on the above link to view schedules of all sampling points (except lead and copper).

Monitoring Schedule for Individual Sampling Points

Please click on a PS Code below to view the monitoring schedule associated with it.

PS Code = Primary Station Code; used by laboratories to upload water quality data

WQM PS Code = (Water System Number)-(Sample Point ID)

CLIP PS Code* = (Water System Number)_(Facility ID)_(Sampling Point ID)

[Click here to bring back the list of sampling points.](#)

*CLIP PS Code = PS Code to be used by laboratories to upload water quality data when CLIP (California Laboratory Intake Portal) is implemented; estimated launch date mid- to late-2020.

**Please refer to the Stage 2 DBP Monitoring Plan Approval Letter for full sample point names.


 1 of 2
 
 Find | Next
 

DATE: 5/3/2021

STATE OF CALIFORNIA

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 2701940

NAME: MONTEREY MUSHROOMS WS

COUN

SOURCE NO: 003

NAME: WELL 04 (STANDBY)

CLAS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	CO
2701940 - 003	MONTEREY MUSHROOMS WS	003	WELL 04 (STANDBY)				
	IO INORGANIC						
	01105 ALUMINUM	<	25.0000 UG/L	1000	50	2014/05/27	
	01097 ANTIMONY	<	.5000 UG/L	6	6	2014/05/27	
	01002 ARSENIC		1.7000 UG/L	10	2	2014/05/27	
	01007 BARIUM		28.0000 UG/L	1000	100	2014/05/27	
	01012 BERYLLIUM	<	1.0000 UG/L	4	1	2014/05/27	
	01027 CADMIUM	<	.2000 UG/L	5	1	2014/05/27	
	01034 CHROMIUM (TOTAL)		13.0000 UG/L	50	10	2014/05/27	
	00951 FLUORIDE (F) (NATURAL-SOURCE)		.1600 MG/L	2	.1	2014/05/27	
	71900 MERCURY	<	.0500 UG/L	2	1	2014/05/27	
	01067 NICKEL	<	10.0000 UG/L	100	10	2014/05/27	
	A-031 PERCHLORATE		ND UG/L	6	4	2016/11/29	
	01147 SELENIUM	<	1.0000 UG/L	50	5	2014/05/27	
	01059 THALLIUM	<	.5000 UG/L	2	1	2014/05/27	

NI NITRATE/NITRITE						
00618	NITRATE (AS N)		N/A mg/L	10	.4	2014/05/27
00620	NITRITE (AS N)	<	100.0000 UG/L	1000	400	2014/05/27
RA RADIOLOGICAL						
01501	GROSS ALPHA		.1960 PCI/L	15	3	2014/05/27
S1 REGULATED VOC						
34506	1,1,1-TRICHLOROETHANE	<	.0000 UG/L	200	.5	2014/05/27
34516	1,1,2,2-TETRACHLOROETHANE	<	.0000 UG/L	1	.5	2014/05/27
34511	1,1,2-TRICHLOROETHANE	<	.0000 UG/L	5	.5	2014/05/27
34496	1,1-DICHLOROETHANE	<	.0000 UG/L	5	.5	2014/05/27
34501	1,1-DICHLOROETHYLENE	<	.0000 UG/L	6	.5	2014/05/27
34551	1,2,4-TRICHLOROBENZENE	<	.0000 UG/L	5	.5	2014/05/27
34536	1,2-DICHLOROBENZENE	<	.0000 UG/L	600	.5	2014/05/27
34531	1,2-DICHLOROETHANE	<	.0000 UG/L	.5	.5	2014/05/27
34541	1,2-DICHLOROPROPANE	<	.0000 UG/L	5	.5	2014/05/27
34561	1,3-DICHLOROPROPENE (TOTAL)	<	.0000 UG/L	.5	.5	2014/05/27
34571	1,4-DICHLOROBENZENE	<	.0000 UG/L	5	.5	2014/05/27
34030	BENZENE	<	.0000 UG/L	1	.5	2014/05/27
32102	CARBON TETRACHLORIDE	<	.0000 UG/L	.5	.5	2014/05/27
77093	CIS-1,2-DICHLOROETHYLENE	<	.0000 UG/L	6	.5	2014/05/27
34423	DICHLOROMETHANE	<	.0000 UG/L	5	.5	2014/05/27
34371	ETHYL BENZENE	<	.0000 UG/L	300	.5	2014/05/27
46491	METHYL-TERT-BUTYL-ETHER (MTBE)	<	.0000 UG/L	13	3	2014/05/27
34301	MONOCHLOROBENZENE	<	.0000 UG/L	70	.5	2014/05/27
77128	STYRENE	<	.0000 UG/L	100	.5	2014/05/27
34475	TETRACHLOROETHYLENE	<	.0000 UG/L	5	.5	2014/05/27
34010	TOLUENE	<	.0000 UG/L	150	.5	2014/05/27
34546	TRANS-1,2-DICHLOROETHYLENE	<	.0000 UG/L	10	.5	2014/05/27

Monitoring Schedules for All Sampling Points Except Lead and Copper

Please click on the above link to view schedules of all sampling points (except lead and copper).

Monitoring Schedule for Individual Sampling Points

Please click on a PS Code below to view the monitoring schedule associated with it.

PS Code = Primary Station Code; used by laboratories to upload water quality data

WQM PS Code = (Water System Number)-(Sample Point ID)

CLIP PS Code* = (Water System Number)_(Facility ID)_(Sampling Point ID)

[Click here to bring back the list of sampling points.](#)

*CLIP PS Code = PS Code to be used by laboratories to upload water quality data when CLIP (California Laboratory Intake Portal) is implemented; estimated launch date mid- to late-2020.

**Please refer to the Stage 2 DBP Monitoring Plan Approval Letter for full sample point names.


 Find | Next

DATE: 5/3/2021

STATE OF CALIFORNIA

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 2701940

NAME: MONTEREY MUSHROOMS WS

COUN

SOURCE NO:

NAME: WELL 04 (STANDBY)

CLAS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE
2701940 - S1 003	REGULATED VOC					
	39180 TRICHLOROETHYLENE	<	.0000 UG/L	5	.5	2014/05/2
	34488 TRICHLOROFLUOROMETHANE FREON 11	<	.0000 UG/L	150	5	2014/05/2
	81611 TRICHLOROTRIFLUOROETHANE (FREON 113)	<	.0000 UG/L	1200	10	2014/05/2
	39175 VINYL CHLORIDE	<	.0000 UG/L	.5	.5	2014/05/2
	81551 XYLENES (TOTAL)	<	.0000 UG/L	1750	0.5	2014/05/2
	S2 REGULATED SOC					
	77443 1,2,3-TRICHLOROPROPANE (1,2,3-TCP)		0 UG/L	0.005	0.005	2020/01/2
	39730 2,4-D	<	.0000 UG/L	70	10	2014/05/2
	77825 ALACHLOR	<	.0000 UG/L	2	1	2014/05/2
	39033 ATRAZINE	<	.0000 UG/L	1	.5	2014/05/2
	38710 BENTAZON	<	.0000 UG/L	18	2	2014/05/2
	81405 CARBOFURAN	<	.0000 UG/L	18	5	2014/05/2
	78885 DIQUAT	<	.0000 UG/L	20	4	2014/05/2
	39055 SIMAZINE	<	.0000 UG/L	4	1	2014/05/2

NI NITRATE/NITRITE					
00618	NITRATE (AS N)	1.6 mg/L	10	.4	2020/09/17
00620	NITRITE (AS N)	0 mg/L	1	.4	2020/09/17
RA RADIOLOGICAL					
01501	GROSS ALPHA	1.1800 PCI/L	15	3	2014/04/28
S1 REGULATED VOC					
34506	1,1,1-TRICHLOROETHANE	0 UG/L	200	.5	2020/09/17
34516	1,1,2,2-TETRACHLOROETHANE	0 UG/L	1	.5	2020/09/17
34511	1,1,2-TRICHLOROETHANE	0 UG/L	5	.5	2020/09/17
34496	1,1-DICHLOROETHANE	0 UG/L	5	.5	2020/09/17
34501	1,1-DICHLOROETHYLENE	0 UG/L	6	.5	2020/09/17
34551	1,2,4-TRICHLOROBENZENE	0 UG/L	5	.5	2020/09/17
34536	1,2-DICHLOROBENZENE	0 UG/L	600	.5	2020/09/17
34531	1,2-DICHLOROETHANE	0 UG/L	.5	.5	2020/09/17
34541	1,2-DICHLOROPROPANE	0 UG/L	5	.5	2020/09/17
34561	1,3-DICHLOROPROPENE (TOTAL)	0 UG/L	.5	.5	2020/09/17
34571	1,4-DICHLOROBENZENE	0 UG/L	5	.5	2020/09/17
34030	BENZENE	0 UG/L	1	.5	2020/09/17
32102	CARBON TETRACHLORIDE	0 UG/L	.5	.5	2020/09/17
77093	CIS-1,2-DICHLOROETHYLENE	0 UG/L	6	.5	2020/09/17
34423	DICHLOROMETHANE	0 UG/L	5	.5	2020/09/17
34371	ETHYL BENZENE	0 UG/L	300	.5	2020/09/17
46491	METHYL-TERT-BUTYL-ETHER (MTBE)	0 UG/L	13	3	2020/09/17
34301	MONOCHLOROBENZENE	0 UG/L	70	.5	2020/09/17
77128	STYRENE	0 UG/L	100	.5	2020/09/17
34475	TETRACHLOROETHYLENE	0 UG/L	5	.5	2020/09/17
34010	TOLUENE	0 UG/L	150	.5	2020/09/17
34546	TRANS-1,2-DICHLOROETHYLENE	0 UG/L	10	.5	2020/09/17

Monitoring Schedules for All Sampling Points Except Lead and Copper

Please click on the above link to view schedules of all sampling points (except lead and copper).

Monitoring Schedule for Individual Sampling Points

Please click on a PS Code below to view the monitoring schedule associated with it.

PS Code = Primary Station Code; used by laboratories to upload water quality data

WQM PS Code = (Water System Number)-(Sample Point ID)

CLIP PS Code* = (Water System Number)_(Facility ID)_(Sampling Point ID)

[Click here to bring back the list of sampling points.](#)

*CLIP PS Code = PS Code to be used by laboratories to upload water quality data when CLIP (California Laboratory Intake Portal) is implemented; estimated launch date mid- to late-2020.

**Please refer to the Stage 2 DBP Monitoring Plan Approval Letter for full sample point names.


 of 1



DATE: 5/3/2021

STATE OF CALIFORNIA

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 2701940

NAME: MONTEREY MUSHROOMS WS

COUN

SOURCE NO: 800

NAME: DBP-MAX RESIDENCE TIME-WELL 5

CLAS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE
2701940 - 800	MONTEREY MUSHROOMS WS	800	DBP-MAX RESIDENCE TIME-WELL 5			
	DBP DISINFECTION BYPRODUCTS					
	32101 BROMODICHLOROMETHANE (THM)	< ND	UG/L	-----	1	2018/10/02
	32104 BROMOFORM (THM)	< ND	UG/L	-----	1	2018/10/02
	32106 CHLOROFORM (THM)	< ND	UG/L	-----	1	2018/10/02
	82721 DIBROMOACETIC ACID (DBAA)	< ND	UG/L	-----	1	2018/10/02
	32105 DIBROMOCHLOROMETHANE (THM)	< ND	UG/L	-----	1	2018/10/02
	77288 DICHLOROACETIC ACID (DCAA)	< ND	UG/L	-----	1	2018/10/02
	A-049 HALOACETIC ACIDS (5) (HAA5)	< ND	UG/L	60	-----	2018/10/02
	A-041 MONOBROMOACETIC ACID (MBAA)	< ND	UG/L	-----	1	2018/10/02
	A-042 MONOCHLOROACETIC ACID (MCAA)	< ND	UG/L	-----	2	2018/10/02
	82080 TOTAL TRIHALOMETHANES	< ND	UG/L	80	-----	2018/10/02
	82723 TRICHLOROACETIC ACID (TCAA)	< ND	UG/L	-----	1	2018/10/02